

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	GV research center pvt ltd	Block No.:	4500 block footings purpose
Project:	Imnopolis	Flat / Villa no.:	
Supplier:	R6 Infra	Slab no.:	
Requisition nos.:	20230520022	A. Estimated quantity:	145M3
PO nos.:	20230520029	B. Requisition quantity:	145M3
Sign of Security	Sign of Admin	C. Actual quantity poured	93M3
	<i>Nagarani</i>	D. Difference (C-A)	52M3

Details of RMC pour

Sl. No	Date	Time of dispatch h from RMC plant	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	10.06.2023	09:30	10:30	10:50	08m3	1493	19200	19470	-			
2	10.06.2023	09:50	10:45	11:10	08m3	1494	19200	19760	-			
3	10.06.2023	09:41	10:40	11:00	07m3	446	16800	16740	60			
4	10.06.2023	09:55	10:50	11:10	07m3	447	16800	17130				
5	10.06.2023	10:25	11:25	11:45	07m3	449	16800	16950				
6	10.06.2023	12:05	13:00	13:25	08m3	1495	19200	19290				
7	10.06.2023	12:25	13:30	13:55	08m3	1496	19200	19490				
8	10.06.2023	13:10	14:20	14:40	08m3	1497	19200	19330				
9	10.06.2023	13:30	14:20	14:50	08m3	1498	19200	19510				
10	10.06.2023	14:15	15:20	15:50	08m3	1500	19200	19190				
11	10.06.2023	15:20	16:20	16:40	08m3	1501	19200	19680				
12	10.06.2023	16:29	17:30	17:50	08m3	1503	19200	19590				

Total:					93m3		223200	226130				
Remarks		As per purchase order 145M3 but consumed 93M3 only										

1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weighment slips + pour reports + test reports + photographs at sit