



Plot No. 15, Markandeya Nagar, Kapra, Hyderabad, Telangana State - 500 062.
E-mail : r6infra05@gmail.com GSTIN : 36ABFFR9437A1Z6

GSTIN : 36ABFFR9437A1Z6

K.N.Rao.

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	GV Discovery center	Block No.:	Terrace closing slab
Project:	Genopolis	Flat / Villa no.:	ETP STP
Supplier:	R6 Infra	Slab no.:	
Requisition nos.:	20230530004	A. Estimated quantity:	30 cub meter
PO nos.:	20230530006	B. Requisition quantity:	30 cub meter
Sign of Security	Sign of Admin	C. Actual quantity poured	2.5 cum on 18-05-23 6 cum on 02-07-23
	Sign of Project Manager	D. Difference (C-A)	

Details of RMC pour

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured	De No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	02-07-23	07:35	07:42	08:20	6m3	1747	14400	14170				
2.												
3.												
4.					6m3		14400	14170				
Total		1 no										

Remarks

Note: 1. Report to be sent on a daily basis to purchase and supply and report on the day of pour and report on the day of receipt. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weight all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400 kg/m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.