

Annexure - B
RMC pour report

Company/ firm:	Modi Realty Mallapur LLP	Block No.:	E-Block
Project:	Gulmohar Residency	Flat / Villa no.:	-
Supplier:	R6 INFRA	Slab no.:	E Block PCC work purpose
Requisition nos.:	20230717033	A. Estimated quantity:	50M3(M10)
PO nos.:	20230718014	B. Requisition quantity:	50M3
	Sign of Admin	C. Actual quantity poured	40M3
	Sign of Project Manager	D. Difference (C-A)	10M3

Details of RMC pour

Sl.	Date	Time of dispatch RMC plant	Time of receipt at site	Time of pour	Quantity poured	De No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	16.08.23	20:57	23:39	23:50	8		19200	19710	510			
2.	16.08.23	20:54	23:29	23:40	8		2249	19200	20010	810		
3.	16.08.23	01:25	02:59	03:10	8		2251	19200	20180	980		
4.	17.08.23	02:23	03:50	04:05	8		2252	19200	19860	660		
5.	17.08.23	02:48	04:46	05:00	8		2253	19200	19970	770		
6.												
7.												
Total:					40		96000	99730	3730			
Remarks	Po not to be closed.											

Note: 1. Report to be sent on a daily basis to purchase/modiproperties.com and report-audit/modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs (eg 2,400kgs/m³). If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at

DELIVERY CHALLAN

R6 Infra
READY MIX CONCRETE AND BRICKS

D.C. No.: 2250

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

Date: 16/08/2023
Mallapragada-20230718014

Modi Realty
TS307A-5505

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
02	M10		8M3	16M3	puccing

INWARD
MODI REALTY MALLAPUR LLP
Ward No 13030, 16/8/23
MRN No 20930816579-17/8/23

Receiver's Signature
For R6 Infra
Authorised Signatory