



DELIVERY CHALLAN

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

Date : 25/08/2023

D.C. No. : 2324

To, grome. huompauf ponu - 20230821072

M/s. TS30TA 4848

Vehicle No. :

S.No. Grade

PARTICULARS

Qty.

Cum.

Value

TS30TA 4848

8m3

8m3

ponu

INWARD

INWARD No: 1663

Dr: 25/8/23

MAIN NO:

Dr:

Received by: RE

Sig: RE

CRESIDENTIALABS PVT LTD

M.R.N: 20230825001

Receiver's Signature

For **R6 Infra**

Authorised Signatory

Company/ firm:		Crescentia Labs Pvt. Ltd.			Block No:							
Project:		GV ONE			Flat / Villa no:							
Supplier:		R6 Infra			Slab no:		North side column-3casting					
Requisition nos:		20230821048			A. Estimated quantity:		145 cum					
PO nos.:		20230821048			B. Requisition quantity:		145 cum					
Sign of Security		Sign of Admin		Sign of Project Manager		C. Actual quantity poured 31 cum						
					D. Difference (C-A)		114 cum					
Details of RMC pour		S. V. Subba Reddy Project Manager										
Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	25-08-20230	9:00	9:10	10:10	8m3	2324	19,200	20,250	-1,050			
2	25-08-20230	9:35	9:47	10:59	8m3	2326	19,200	19,920	-720			
3	25-08-20230	11:17	11:25	12:18	7m3	1789	16,800	16,690	110			
4	25-08-20230	11:30	11:42	12:50	8m3	2329	19,200	20,140	-940			
5												
6												
					Total	31 m3	74,400	77,000	-2,600			
Remarks		Balanced quantity to be used later										

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weight all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.