

(Signature)

Office of the
Director General
Telangana State Disaster Response
& Fire Services, Hyderabad.
Dated: 2-08-2023.

Re.No.15009 MSB/CR/RR/2013

CIRCULAR MEMORANDUM

Sub:-Telangana State Disaster Response and Fire Services Department
MSB Section - Issuance of No Objection Certificates - Certain
instructions - Issued - Reg.

- Ref: 1. G.O.Ms.No.168 MA&UD Department, dt. 07-04-2012.
2. This Office Re.No.15009 MSB/CR/RR/2013, Dated 16-12-2019.

to all:

In continuation of this office circular issued vide reference 2nd cited, and in view of the information received from M's.Brij Basi, India, authorized Indian Representative of Bronto Sky lift the manufacturing company of Hydraulic Platform, the attention of inspecting officers (District Fire Officers/Asst. District Fire Officers) is drawn to the reference cited, and they are instructed to ensure the following parameters, in the Highrise buildings with regard to Fire Vehicle driveway and turning radius for conducting firefighting and rescue operations during Fire and Other emergencies.

Sl.No	Height of the building	Driveway	Turning Radius
a.	Up to 54 Mtrs	7 Mtrs	12 Mtrs.
b.	55 Mtrs to 100 Mtrs	11 Mtrs	14 Mtrs.
c.	Above 100 Mtrs	11 Mtrs	15 to 17 Mtrs
d.	Load bearing capacity of the slab shall be designed	up to 70 Mtrs 45 tones. above 70 Mtrs 65 tones.	

2. All the inspecting officers must follow the above instructions and inform the same to the builders.
3. The receipt of the Memorandum should be acknowledged.

for *(Signature)* 2/8/23
Director General,

Telangana State Disaster Response and
Fire Services, Hyderabad.

To,
The Regional Fire Officer, Central Region, Hyderabad
All the District Fire Officers
Copy to the Asst. District Fire Officers
Copy to the Station Fire Officers.
Copy to upload on the website of Telangana State Fire Department.

Regards,

Soham Modi