

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	SOV LLP	Block No.:	V no 213 Pedestal
Project:	SOV-III	Flat / Villa no.:	V no 213 Pedestal
Supplier:	R6 Infra	Slab no.:	Pedestal
Requisition nos.:	20230830063	A. Estimated quantity:	12
PO nos.:	20230830073	B. Requisition quantity:	12
Sign of Security	Sign of Admin	Sign of Project Manger	C. Actual quantity poured
			D. Difference (C-A)

Details of RMC pour

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	25/09/23	12:20	01:00	01:02	06	2562	14400	14540				
2.												
3.												
4.												
5.												
6.												
7.												
8.												
9.												
10.												
Total:					06		14400	14540				
Remarks		Part received.Remaining required										

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weighment slips + pour reports + test reports + photographs at sit

DELIVERY CHALLAN



R6 Infra

READY MIX CONCRETE AND BRICKS

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

D.C. No. **2562**

Date : 25/09/2023

To,

M/s.

Silver oak villas. cherlapally

Vehicle No. :

TS0800 7383 vimlesh.ky doro - 20230830073

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
01	M25	4313 25/09/2023 6m3	6m3		Dumping.

For **R6 Infra**

Authorised Signatory

Receiver's Signature