QC - Concrete Cube Testing Report.																
Company:		MRGV														
Project:		BRGV														
Report for Month:		(Aug - Sept) = - 2023														
Prepared By:		QC Team														
Date:		29-09-2023														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
21043	17-08-2023	RMC	M20	Homeline		1	Slab	6(507-516)	16-9-23	30	20.0	485.0	21.6			
											20.0	488.0	21.7	21.3		
											20.0	465.0	20.7			