

GOVERNMENT OF TELANGANA
ELECTRICAL INSPECTORATE

From:
The Chief Electrical Inspector
to Government of Telangana,
Flat No. 127, Block No. 7,
New MLA Quarters, Adarshnagar,
Hyderabad - 500 063

To:
M/s Mehul V Mehtha & Bhavesh V
Mehtha,
Sy. No. 82/1,
Mallapur (V), Uppal (M),
Medchal Dist

Lr.No. CEIG/TS/MSB-MDL-2021-20386/D.No. 1822 /2021 dated 21-09-2021.

Sir,

Sub: The Electricity Act, 2003 and Central Electricity Authority(Measures relating to Safety and Electric Supply)Regulations 2010 -Multistoried Building of M/s Mehul V Mehtha & Bhavesh V Mehtha, Sy. No. 82/1, Mallapur (V), Uppal (M), Medchal Dist- Statutory Approval under regulation 36 of Central Electricity Authority(Measures relating to Safety and Electric Supply) Regulations 2010-Accorded.

Ref: - 1) Inspection Dated:- 15-09-2021
2) Your letter received on:- 20-09-2021

Under regulation 36 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations 2010, the following equipment of your MultistoriedBuilding are approved for energisation.

S.No.	Equipment	Capacity	Voltage
I.	L.V.Installation:		
	1. Total 3 BHK flats 189 Nos X 5 KW	945 KW	230V
	2. Common LV Load	4 KW	230V
II.	M.V.Installation:		
	1. MV Load	48 HP	415V

Any additions or alterations to existing installation shall not be connected to supply unless and until such alterations or additions have been approved in writing by the Chief Electrical Inspector to Government and offer for inspection under Regulation 30 of Central Electricity Authority(Measures relating to Safety and Electric Supply)Regulations, 2010 once in every threeyears to the concerned Deputy Electrical Inspector.

Under Regulations 13 (4) and 36(4) of the Central Electricity Authority (Measures relating to Safety and Electric Supply)Regulations 2010, you are at all times be solely responsible for the maintenance of the above installation in such condition as to be free from danger.

The above approval accorded is without prejudice to the statutory / mandatory obligations to be fulfilled by you under various other acts and rules as the case may be.

The approval accorded for energizing the electrical equipment is for the safety of men and Machinery from electrical hazards in your installation and ipso facto, does not confer any right to be used for any other purpose other than for which the approval is accorded.

Yours faithfully

S. Sini - 21/9/21
CHIEF ELECTRICAL INSPECTOR
TO GOVERNMENT

Copy to the Divisional Engineer/Operation/TSSPDCL/Uppal. The date of release of supply may be intimated to Dy. Electrical Inspector/ Ranga Reddy-2 Subdivision.

Copy to the Deputy Electrical Inspector/ Ranga Reddy-2 Sub division

MEHUL V. MEHTHA & BHAVESH V. MEHTHA

SY.NO: 82/1, MALLAPUR VILLAGE, UPPAL MANDAL, MEDCHAL DISTRICT.

LOAD DETAILS

TRIPLE BED ROOM FLATS LIGHTING LOAD DETAILS

S.NO.	DESCRIPTION	WATTS		NUMBERS	WATTS OR KW
1	Tube lights	40	X	3	120
2	Fans	60	X	6	360
3	LED	40	X	13	520
4	6A Sockets	125	X	16	2000
5	16A Sockets	500	X	4	2000
	TOTAL				5000W OR 05KW

Triple Bed Room Flats Load	05KW	X	189NOS	945KW
Common Lighting Load			-	4KW
TOTAL			189NOS	949KW

M.V. LOAD DETAILS:

S.NO.	M/C NAME	HP	VOLTS	CABLE SIZE/LENGTH
1	service Lift Motor - 1	10	415	4c x 4sq.mm Cu. 11Mtrs
2	Passinger Lift Motor - 2	6	415	4c x 4sq.mm Cu. 11Mtrs
3	Bore Well	5	415	3c x 2.5sq.mm Cu. 13mts
4	Sump Pump	3	415	3c x 2.5sq.mm Cu. 13mts
5	Passinger Lift Motor - 3	6	415	4c x 4sq.mm Cu. 11Mtrs
6	Passinger Lift Motor - 4	6	415	4c x 4sq.mm Cu. 11Mtrs
7	Passinger Lift Motor - 5	6	415	4c x 4sq.mm Cu. 11Mtrs
8	Bore Well	3	415	3c x 2.5sq.mm Cu. 13mts
9	Sump Pump	3	415	3c x 2.5sq.mm Cu. 13mts
	TOTAL	48		

For MEHUL V. MEHTHA & BHAVESH V. MEHTHA

For RAJESH TECHNICAL SERVICES

(Authorized Signatory)

APPROVED

LIC No. A 4870 1-1247

Chief Electrical
Inspector to Govt.