

DELIVERY CHALLAN

R6 Infra

READY MIX CONCRETE AND BRICKS

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

D.C. No.:

၁၁၁၁

Date: 17-11-23

To,

M/S. CIV ONE thukareddy POHO - 20231114023

Vehicle No.: TS 30TA 4848

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
-------	-------	-------------	------	------	-------

Qty.

Cum.

Value

833

83

Pranjal

29.30

UNIVERSITY

Inwarding: 3144

04/17/1925

MRN No:

Dr:

Received By:-

Sign: ∇

Receiver's Signature

CRESCENTIA LABS PVT LTD

3.2.2. 2021

For R6 Infra

Authorised Signatory

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	Crescentia Lab Pvt Ltd	Block No.:	Northern block column-4 casting
Project:	GV One	Flat / Villa no.:	-
Supplier:	R6 INFRA	Slab no.:	-
Requisition nos.:	20231114009	A. Estimated quantity:	300 cum
PO nos.:	20231114023	B. Requisition quantity:	300 cum
Sign of Security	Sign of Admin	C. Actual quantity poured	24 m3
Sign of Security	Sign of Admin	D. Difference (C-A)	276 m3

Details of RMC pour

S.V. Subba Reddy
Project Manager

Sl. No	Date	Time of dispatch of RMC plant	Time of receipt at site	Time of pour	Quantity poured	Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	17-11-23	8:25	8:35	9:49	8m3	3322	19200	19770	-570			
2.	17-11-23	8:45	8:55	10:14	8m3	3323	19200	19320	-120			
3.	17-11-23	11:28	11:39	12:34	8m3	3324	19200	19480	-280			
Total:					24m3		57600	58570	-970			
Remarks	Balanced quantity to be delivered later.											

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.