

Company/ firm:		Crescentia Labs Pvt. Ltd				Block No:						
Project:		GV ONE				Flat / Villa no:						
Supplier:		R6 Infa										
Requisition nos:		20231114009				Slab no:		Northern block column-4 casting				
PO nos.:		20231114023				A. Estimated quantity:		300 cum				
						B. Requisition quantity:		300 cum				
Sign of Security		Sign of Admin		Sign of Project Manager		C. Actual quantity poured		24 M3 used on (17-11-23), 28m3 used on(22-11-23)				
Details of RMC pour						D. Difference (C-A)		248m3				
Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of completion of pouring	Quantity poured (Cum)	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	22-11-2023	8:00	8:11	9:05	8m3	3354	19,200	19,280	-80			
2	22-11-2023	11:10	11:21	12:22	8m3	3363	19,200	19,400	-200			
3	22-11-2023	9:40	9:51	10:41	8m3	3361	19,200	19,270	-70			
4	22-11-2023	1:40	1:46	14:47	4m3	3370	9,600	9,840	-240			
					Total	28m3	67,200	67,790	-590			

Remarks

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.

Balanced quantity to be used later

R6 Infra
READY MIX CONCRETE AND BRICKS

DELIVERY CHALLAN

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

NO. : **3363**

F - 20231114069

Date : 22-11-2023

M/S. one hydraulic pump
Vehicle No. : TS08DY-7382

S.No.	Grade	PARTICULARS		Qty.	Cum.	Value	
03	60-30	INWARD Inward No: 3177 MRN No. Received By:  CRESCENTIALABS PVT LTD Dr: Date: 22/11/23 Sign: 		8093	24093	24093	
Receiver's Signature							
For R6 Infra  Authorised Signatory							