

Company/ firm:		Crescentia Labs Pvt. Ltd.		Block No:			
Project:		GV ONE		Flat / Villa no:			
Supplier:		R6 Infra		Slab no:		Northern block column-4 casting	
Requisition nos:		20231114009		A. Estimated quantity:		300 cum	
PO nos.:		20231114023		B. Requisition quantity:		300 cum	
Sign of Security		Sign of Admin		C. Actual quantity poured		24 M3 used on (17-11-23), 28m3 used on (22-11-23), 54m3 used on (24-11-23)	
		29/11/23		D. Difference (C-A)		194m3	

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Quantity poured (Cum)	Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	24-11-2023	6:58	7:10	8m3	3383	19,200	18,700	500			
2	24-11-2023	8:40	8:51	8m3	3384	19,200	19,020	180			
3	24-11-2023	10:30	10:42	8m3	3386	19,200	19,460	-260			
4	24-11-2023	13:45	13:46	8m3	3388	19,200	19,040	160			
5	24-11-2023	16:32	16:43	8m3	3392	19,200	19,100	100			
6	24-11-2023	14:42	14:50	7m3	3366	16,800	17020	-220			
7	24-11-2023	15:00	15:08	7m3	3367	16,800	17040	-240			
				Total		1,29,600	1,29,380	220			

Remarks	Balanced quantity to be used later
---------	------------------------------------

Note: 1. Report to be sent on a daily basis to purchase@modiproproperties.com and report-audit@modiproproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 Kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weighment slips + pour reports + test reports + photographs at site.



R6 Infra
READY MIX CONCRETE AND BRICKS

DELIVERY CHALLAN

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

D.C. No. :

3383

Date : 24-11-2023

To,

Grome Hyderabad P.O. - 20231114023

Vehicle No. :

T508UG-7383

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value																				
1	20mm	<table><tr><th colspan="4">INWARD</th></tr><tr><td>Inward No:</td><td>3191</td><td>Di:</td><td>24/11/23</td></tr><tr><td>MRN No:</td><td></td><td>Di:</td><td></td></tr><tr><td>Received By:</td><td>gpc</td><td>Sign:</td><td>gpc</td></tr><tr><td colspan="4">CRESCENTIALARS PVT LTD</td></tr></table>	INWARD				Inward No:	3191	Di:	24/11/23	MRN No:		Di:		Received By:	gpc	Sign:	gpc	CRESCENTIALARS PVT LTD				20m ³	20m ³	20m ³
INWARD																									
Inward No:	3191	Di:	24/11/23																						
MRN No:		Di:																							
Received By:	gpc	Sign:	gpc																						
CRESCENTIALARS PVT LTD																									

Signature

M-R-20231124001

For **R6 Infra**

Authorised Signatory