

Company/ firm:	Crescentia Labs Pvt. Ltd.			Block No:								
Project:	GV ONE			Flat / Villa no:								
Supplier:	R6 Infra			Slab no:	Northern block column-4 casting							
Requisition nos:	20231114009			A. Estimated quantity:	300 cum							
PO nos.:	20231114023			B. Requisition quantity:	300 cum							
Sign of Security	Sign of Admin	Sign of Project Manager		C. Actual quantity poured	24 M3 used on (17-11-23), 28m3 used on (22-11-23), 54m3 used on (24-11-23), 24m3 used on (27-11-23), 37m3 used on (29-11-23), 23m3 used on (06-12-23).							
Details of RMC pour				D. Difference (C-A)	110m3							
Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	De No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	06-12-2023	9:05	9:15	10:07	8m3	3524	19,200	19,600	-400			
2	06-12-2023	13:00	13:10	13:52	8m3	3525	19,200	19,040	160			
3	06-12-2023	15:20	15:30	16:36	7m3	3527	16,800	16,750	50			
4												
				Total	23m3		55,200	55,390	-190			
Remarks		Balanced quantity to be used later										

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.

DELIVERY CHALLAN

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

D.C. No. :

3524

Date : 06-12-2023

To,

Groove Hyderabad Pono - 20231114023

M/s.

Vehicle No. :

TS36TD. 4848

S.No.

Grade

PARTICULARS

Qty.

Cum.

Value

01

TS36TD

01, 15 Nos

01, 15 Nos

01, 15 Nos

01, 15 Nos

INWARD

Inward No: 2251

Dt: 06/12/23

MARN No: 20231210: 6023

Received By:

Sign:

Gowar

06/12/23

CRESCENTIA LABS PVT LTD

Receiver's Signature

For **R6 Infra**

Authorised Signatory