

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	GV research center pvt ltd	Block No.:	3600 column-04 purpose
Project:	Innopolis	Flat / Villa no.:	
Supplier:	R6 infra	Slab no.:	
Requisition nos.:	20231211015	A. Estimated quantity:	150M3
PO nos.:	20231211019	B. Requisition quantity:	150M3
Sign of Security	Sign of Admin	C. Actual quantity poured	14M3
	Sign of Project Manger	D. Difference (C-A)	136M3

Details of RMC pour

Details of RMC pour						Dc No. / Batch no.	Specified wt @2400 kgs/m ³	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m ²	28 days cube test strength in kN/m ²
Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	pour	Quantity poured							
1	19.12.2023	09:40	10:35	10:55	07m ³	3695	16800	16770				
2	19.12.2023	02:30	03:30	03:55	5.5m ³	3698	13200	13180				
Total:					12.5m ³		30000	29950				
Remarks	As per purchase order 150M ³ but consumed 12.5M ³ only.											

Remarks	As per purchase order
Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weighment slips + pour reports + test reports + photographs at sit	