QC - Concrete Cube Testing Report.																
Company:		GVRC														
Project:		Innopolis														
Report for Month:		(Nov - Dec) = - 2023														
Prepared By:		QC Team														
Date:		06-01-2024														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
14221	02-11-2023	RMC	M30	R6 Infra		3600	COL	3	2-12-23	30	30.0	689.0	30.6			
											30.0	695.0	30.9	30.7		
											30.0	690.0	30.7			