

Supplier:	R6 Infra(M30)	Slab no:	chemical&solvent block columns
Requisition nos:	20240130007	A. Estimated quantity:	70m3
PO nos:	20240130048	B. Requisition	70m3
Sign of Security	Sign of Admin	Sign of Project Manger	C. Actual quantity/pour
			67m3
		D. Difference (C-A)	3m3

Details of RMC pour												
Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	27-01-2024	9:09	9:21	10:04	8m3	4,181	19,200	18,350	850			
2	27-01-2024	11:49	11:59	12:46	8m3	4,187	19,200	19,280	-80			
3	27-01-2024	13:35	13:45	14:23	8m3	4,190	19,200	18,400	800			
4	27-01-2024	15:53	15:59	16:42	5m3	4,193	12,000	12,350	-350			
5	27-01-2024	18:00	18:09	19:03	7m3	4,746	16,800	17,740	-940			
6	28-01-2024	7:50	8:00	8:38	7m3	4,196	16,800	16,230	570			
7	28-01-2024	10:20	10:26	11:08	5m3	4,197	12,000	11,660	340			
8	29-01-2024	6:50	7:01	7:47	8m3	4,199	19,200	18,040	1,160			
9	29-01-2024	12:30	12:39	13:28	7m3	4,205	16,800	16,680	120			
10	29-01-2024	16:10	16:16	16:49	4m3	4,211	9,600	9,430	170			
				Total	67m3		1,60,800	1,58,160	2,640			

Remarks **Balanced quantity to be delivered later**

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-modi@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.

PO:- 20240130048

DELIVERY CHALLAN

R6 Infra

READY MIX CONCRETE AND BRICKS

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

No. : **4181**

PO: 2024012504

Date: 27/01/2024

M/S.

give tharakpally. PO No - 20240130048

Vehicle No.: H808UK 2590 -

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
01	6430	MRN-20240131001	8m ³	8m ³	8m ³ 8m ³

INWARD

Inward No: 3644

MRN No:

Received By:

Dt:

Sign:

For **R6 Infra**

Receiver's Signature

Authorised Signatory

CRESCENTIA LABS PVT LTD