

Company/ Firm:		Crescentia Labs Pvt. Ltd.				Block No:						
Project:		GV ONE				Flat / Villa no:						
Supplier:		CEMEX INFRA(M30)				Slab no:						
Requisition no:		20240124026				A. Estimated quantity		150m ³				
PO no.:		20240125011				B. Requisition		150m ³				
Sign of Security		Sign of Admin		Sign of Project Manager		C. Actual quantity poured		25.5m ³ used on (01-02-24), 52m ³ used (02-02-24), 39m ³ used on (05-02-24), 15.5m ³ used on (06-02-24), 21.5m ³				
Details of RMC pour		4/12		D. Difference (C-A)		3.5m ³ exceed						
Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	De No. / Batch no.	Specified wt @2400 kgs/m ³	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m ²	28 days cube test strength in kN/m ²
1	08-02-2024	10:21	10:35	13:13	6.5m ³	3496	15,600	15,510	90			
2	08-02-2024	18:07	18:20	19:33	2m ³	3497	4,800	3,900	900			
3	09-02-2024	9:24	9:35	12:49	6.5m ³	3499	15,600	15,750	-150			
4	09-02-2024	12:32	12:45	15:55	6.5m ³	3500	15,600	15,900	-300			
					Total		51600	51060	540			
Remarks		Balanced quantity to be delivered later										

Note: 1. Report to be sent on a daily basis to purchase@cmoproperties.com and Export-audit@cmoproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weight all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m³. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.

INFRA

PO: 2024012501

S. 312, Rampally (Vill), Keesara (Mdl)

Medchal (Dist), Hyderabad - 501301.

Ph. 9848 210 686 / 9133 333 5839

Email:-cemexinfra9@gmail.com



CEMEX INFRA

READY MIX CONCRETE

GSTIN : 36AANFC3197R1ZJ

DELIVERY CHALLAN

Customer Name: **CRESCENTIA LABS PVT LTD(GV ONE)**

Delivery Site: **THURKAPALLY**

S.No: **GRADE**

1

M30

Qty

6.50

Units,

Cum. Qty

Cum

6.50

GOOD

D.C. No:

3496

Date:

8/Feb/24

Truck No:

TS 08 UF 1527

Mode:

DUMP

Remarks

Other Documents Enclosed:

Driver Name:

ASHOK REDDY

1)
2)

MRN - 20240212013

Signature:

INWARD

Forward No: **37149**

Di: **08/02/24**

MRN No:

Di:

Received By:

Sign:

for Cemex Infra

Customer Signature

CRESCENTIA LABS PVT LTD

Authorised Signatory