

**GOVERNMENT OF TELANGANA**  
**ELECTRICAL INSPECTORATE**  
(An IS/ISO 9001: 2015 Certified Department)



FROM:  
The Deputy Chief Electrical Inspector  
To Government, Hyderabad  
5th Floor, R & B Building,  
Masabtank, A.C Guards,  
Hyderabad 500 004.

TO:  
**M/S MODI REALTY MALLAPUR LLP**  
Block-C, Sy.No:19P, Mallapur (Village),  
Nacharam, UPPAL Mandal  
MEDCHAL District-.

Lr.No: DCEIG-HYD/TS/EI Ex. 650V/5322 /D.No. 1457/2023 Dated: 09-06-2022.

Sir,

Sub:- The Electricity Act, 2003 and Central Electricity Authority( Measures relating to Safety and Electric Supply) Regulations 2010 – Multi - Storeyed Building of M/s MODI REALTY MALLAPUR LLP, Block-C, Sy.No:19P, Mallapur (Village), Nacharam, UPPAL Mandal, MEDCHAL District – Statutory Approval under regulation 36 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations 2010 – Accorded.

Ref: - 1). Inspection dated: 18-03-2023.  
2). Your Compliance report received on: 09-06-2022.

\*\*\*

Under Regulation 36 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, the following equipment of your Electrical Installation is approved for energisation.

**DETAILS OF EQUIPMENT**

| Sl. No: | Service              | No. of Service | Capacity | Voltage |
|---------|----------------------|----------------|----------|---------|
| I.      | <b>3 -Phase Load</b> |                |          |         |
| a)      | 3 BHK Flats          | 42 No's x 5 KW | 210 KW   | 415 V   |
| b)      | Common Meter         | 1 No x 20 KW   | 20 KW    | 415 V   |

Under the provisions of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, any additions or alterations to your above electrical installation shall not be connected to supply until the same are approved in writing by this Office.

Under Regulation 13(4), 46(7) of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, you are at all times solely responsible for the maintenance of the above installation on such condition as to be free from danger.

The above approval accorded is without prejudice to the statutory/ mandatory obligations to be fulfilled by you under various other acts and rules as the case may be.

The approval accorded for energizing the electrical equipment is the safety for men and machine from electrical hazards in your installation and ipso facto does not confer any right to be used for any other purpose other than for which the approval is accorded

Yours faithfully,

*J. Hine*  
9/6/23

DEPUTY CHIEF ELECTRICAL INSPECTOR  
TO GOVERNMENT, HYDERABAD

1) Copy to the Divisional Engineer/ Operation/ Of Telangana /HABSIGUDA, MEDCHAL.

The date of release of supply may be intimated to this Office. (Verify the approval in TSCEIG.CGG.GOV.IN website in third party verification column before the energization of the supply.)

2) Dy. Electrical Inspector, RR-II Sub-Division

**# Follow the Electricity Act & Regulations of CEA to avoid Electrical Fatal and Fire Accidents #**

## M/s Modi Realty Mallapur LLP

Block-C, Sy. No: 19P, Mallapur (V), Uppal (M), Medchal Dist.

| LOAD PARTICULARS |                          |      |          |                 |    |            |         |
|------------------|--------------------------|------|----------|-----------------|----|------------|---------|
|                  | Description              | Qty. |          | Rating in Watts |    | Total Load | Voltage |
| 1                | LED Lights               | 18   | Nos      | 30              | w  | 540 w      | 230V    |
| 2                | Tube Lights              | 4    | Nos      | 40              | w  | 160 w      | 230V    |
| 3                | Fans                     | 5    | Nos      | 60              | w  | 300 w      | 230V    |
| 4                | 6 amps power socket      | 16   | Nos      | 125             | w  | 2000 w     | 230V    |
| 5                | 16 amps socket           | 4    | Nos      | 500             | w  | 2000 w     | 230V    |
|                  | Each Flat load           |      |          |                 |    | 5000 w     | 230V    |
|                  | Total Flat Domestic Load |      |          | 42x5000W        |    | 210000 w   | 230V    |
|                  | Common Lighting Load     |      |          |                 |    | 2KW        | 230V    |
|                  | Motor Load               |      |          |                 |    |            |         |
| 1                | Bore                     | CG   | 1.5KNE2  | 3               | kw | 3 kw       | 415V    |
| 2                | sump                     | CG   | 1.0KNE4  | 2               | kw | 2 kw       | 415V    |
| 3                | Lift-1                   | CG   | 2.50KNE4 | 5               | kw | 5 kw       | 415V    |
| 4                | Lift-2                   | CG   | 2.50KNE5 | 5               | kw | 5 kw       | 415V    |
|                  | Total Load               |      |          |                 |    | 15 kw      | 415V    |

EQUIPMENT LOAD

DG SET

63KVA


Your's Faithfully

For M/s. Modi Realty Mallapur LLP

Authorized Signatory

MODI REALTY MALLAPUR LLP

Sy. No: 19, Mallapur,  
HYDERABAD - 500 076.



**APPROVED**

J. Kine - S  
9/6/23

Dy. Chief Electrical Inspector or to Govt  
HYDERABAD.