

547

GOVERNMENT OF TELANAGANA
OFFICE OF THE COMMISSIONER OF POLICE
CYBERABAD

RC.No. A4/47/256/Petroleum/Cyb/2023

Date: 01.02.2024

NO OBJECTION CERTIFICATE
(See Rule 144)

Sub: Petroleum Act & Rules – Cyberabad Commissionerate –
Grant of No Objection Certificate for Petroleum storage
(Class A) Non-Bulk (Drums/small quantities) storage at M/s
G.V. Discovery Centers Pvt Ltd, Plot No. 1A, Sy. No. 234 &
235, Turkapally village, Shamirpet mandal, Medchal
Malkajgiri District by M/s G.V. Discovery Centers Pvt Ltd –
Reg.

Ref: Application of M/s G. V. Discovery Centers Pvt Ltd 5-4-187/3
& 4, II Floor, Soham Mansion, M.G. Road, Secunderabad –
500003 Dt. 09.11.2023.

* * *

With reference to the application dated 09.11.2023 submitted by
Director M/s G. V. Discovery Centers Pvt Ltd and in pursuance of Rule 144 of
the Petroleum Rules, 2002, there is no objection for Petroleum storage (Class A)
Non-Bulk (Drums/small quantities) storage at M/s G.V. Discovery Centers Pvt
Ltd, Plot No. 1A, Sy. No. 234 & 235, Turkapally village, Shamirpet mandal,
Medchal Malkajgiri District by M/s G.V. Discovery Centers Pvt Ltd as shown in
the site plan duly endorsed and enclosed herewith.

The following particulars have been considered while issuing this no
objection certificate that-

- (a) Possession of the site by the applicant is lawful and authorization
from land owner or lease holder for developing premises under
these rules for storage of petroleum products;
- (b) Interest of public, specially the facilities like schools, hospital or
proximity to places of public assembly and the mitigating
measures, if any, is provided;
- (c) Traffic density and impact on traffic.
- (d) Conformity of proposal to the local or area development planning
- (e) Accessibility of the site to fire tenders in case of emergency and
preparedness of fire services for combating the emergencies.
- (f) Genuineness of purpose.
- (g) Any other matter pertinent to public safety.

Sd/-
Commissioner of Police,
Cyberabad.

Encl: (Annexure-I)

To

M/s. G. V. Discovery Centers Pvt Ltd 5-4-187/3 & 4, II Floor, Soham Mansion,
M.G. Road, Secunderabad - 500003.

Copy to the District Collector, Medchal Malkajgiri District for information.

Copy to Executive Engineer, R&B Roads Division, Medchal Malkajgiri District.


Copy to the Commissioner, HMDA and GHMC Hyderabad.

Copy to the Dist. Fire Officer, Medchal Malkajgiri District for information.

Copy to the SHO Genome valley PS L&O, SHO Medchal traffic PS, ACP Pet
Basheerabad Division, ACP Medchal Traffic Division, DCP Traffic Medchal Zone
and DCP Medchal Zone, Cyberabad.


Copy to the Jt.CP, Traffic, Cyberabad.

//t.c.f \\

 21/2/2024

**Addl. Dy. Commissioner of Police,
(Admin), Cyberabad.**

ADDL DY. COMMISSIONER OF POLICE
ADMIN. CYBERABAD



ANNEXURE-I

Explosive Rules, 1983:


- 1) The petroleum shall be stored only in one or more underground gas fight of capacity and in the position shown in the approved plan.
- 2) Every tank shall be outside any building and placed in a masonry or concrete and packed around with sand to be hung to stand, earth or clay so that no are space is left between than tank and the masonry or concrete pit and the tank is welded on and tested upto a pressure of 0.25 Kg per square centimeter and is buried and in no a private, leased or rented land and no part of the tank is less than 15 meters from any point of the marked boundary, of the premises on the approved attached hereto.
- 3) There shall be no openings I any tank other tank those necessary for the introduction or removal of the petroleum or for ventilating or dipping the tank. The filing and dipping pipes shall be carried down nearly to the bottom of the tank. Every tank shall be fitted with an independent vent pipe leading into the open air.
- 4) The vent pipe shall be securely supported and shall not be less than 4.0 meters in height and 4.0 meters from any adjoining land or property or from the nearest opening of the saleroom/kiosk or any other facility in which source of fire are likely to be present. Vent pipe of any tank shall not be interconnected with the vent pipe of another tank. The open end of every vent pipe shall be covered with two layers of non-corrodible metal wire gaze having not less than 11 meter per liner centimeter and shall be further protected from rain by a hood or by suitably bending it downward.
- 5) The petroleum shall enter a tank through close coupled electrically continuous and sound hose
- 6) The underground tank or tanks shall not be filled between the hours of sunset and sunrise except in a manner and under conditions specially endorses on his license by the licensing authority.
- 7) No artificial light capable of igniting flammable vapor shall at any time be present in the immediate vicinity of the tank/lorry/wagon during the transfer of the petroleum to tha tank and no person engaged in such light and no smoking shall be allowed within a distance of 9.0 meters from barrels.
- 8) No petroleum shall be removed from a tank except by means of the pump or pumps at the position marked on the plan hereto attached. Every pump shall together with its connections and fittings be so constructed and maintained as to be gas and petroleum tight.
- 9) Petroleum may be supplied to a major vehicle between the hours and sunset and sunrise from the pump provided that (i) the pump and the vehicle are adequately illuminated by electric light of filing this by some other form lighting, and (ii) no light capable igniting flammable vapour is situated or brought within the extent of hazardous areas as specified in part-B of Fourth schedule to the petroleum Rules 1976.
- 10) (a) Petroleum shall not be placed in any motor vehicle while the engine is running and, where the vehicle is licensed for the conveyance of more than six passengers on hire, while any passenger remains in the vehicle, and (b) person in and engaged in connected with any motor vehicle shall not be permitted to smoke while it is being refueled.
- 11) Every person managing or employed on or in connection with the licensed premises shall abstain from any act whatsoever which tends to cause fire or explosion and which is not reasonably necessary and to the best of his ability, shall prevent any other person from doing such act.
- 12) Every care shall be taken to prevent any petroleum escaping into any drain, sewer or public road.
- 13) At least 50 % of the employee shall undergo training in First Aid Fire Fighting for period of (3) days in the office of the District Fire Office on payment of prescribed fee by way to challan.

Part-B

GENERAL FIRE PRECAUTIONARY MEASURES FOR ALL PETROL/DIESEL OUTLETS/STORAGE:

- 1) A compound wall should be provided around the premises except at front side.
- 2) The Premises should be easily approachable to fire fighting appliances.
- 3) No overhead high tension lines should be passed through the compound.
- 4) It should be seen that the cell phone users are requested to switch off the cell phones before entering the Premises by means of sign boards at conspicuous places.
- 5) Certain boards exhibiting the slogans such as not to carry matches fuses or other appliances capable of producing ignition / explosion should be displayed at conspicuous places.
- 6) Care should be taken to prevent entry of petroleum products into drain/sewer/public road.
- 7) All the electrical fittings should be protected properly with approved pattern to prevent short circuit and they must be flame proof.
- 8) All the Staff working in the premises should be well aware of the usage and maintenance of firefighting equipment provided and they should be trained in first aid fire fighting courses.

- 9) If any spillage of fuel occurs immediately it should be covered with dry sand to be hung to a stand and cleared.
- 10) The vehicle engine should be stopped during loading and unloading process.
- 11) The customers should stop engine of vehicles before refilling petroleum products.
- 12) Static charges should be dissipated while unloading.
- 13) No welding / cutting should be allowed within 30 meters from the storage area.
- 14) All the staff / occupants must know the correct method of operation of the fire fighting system installed.
- 15) All the fire protection arrangements shall be maintained in good working condition as seen during inspection.
- 16) Any loss of life or property due to non-functioning of fire safety measures and other installations shall be responsibility of the management / owner.
- 17) All occupants / securing personnel shall be trained to operate the fire safety equipment's in case of emergency.
- 18) Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every six months.
- 19) After construction & Installation of the Fire Fighting equipment the trader shall apply for the clearance certificate.


for Commissioner of Police,
Cyberabad.

ADDL DY. COMMISSIONER OF POLICE
ADMIN. CYBERABAD

