



# Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &  
OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

## TEST REPORT

Page 1 of 1

<b>Name &amp; Address Of Customer:</b> M/s. Modi Realty Miryalaguda LLP Sy.No-786/P, Miryalaguda (V & M), Nalgonda, Telangana.	<b>Lab Ref. No:</b>	VIS/344/2024
	<b>Reporting Date:</b>	20/04/2024
<b>Sample Description: O.H.T-water</b>	<b>Sample Received On:</b>	16/04/2024
	<b>Your Ref No:</b>	Verbal
<b>Sample Condition At the time of Receipt: Found OK</b>	<b>Analysis Started On:</b>	16/04/2024
<b>Sample drawn By: Customer</b>	<b>Date of Sampling:</b>	16/04/2024
<b>Quantity Received: 2Ltr X 1No.</b>	<b>Analysis Completed On:</b>	20/04/2024

## TEST RESULTS

Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P <sup>H</sup> Value at 25°C	IS:3025(Part -11)-1983,RA 2017	7.32	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 <sup>rd</sup> Edn:2017) -2510 B	1150	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984,RA 2006	770	<500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984,RA 2017	1.30	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part - 4)-1983,RA 2017	02	< 05
6.	Odour	IS:3025(Part - 5)-1983,RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO <sub>3</sub> , mg/l	IS:3025(Part -21)-2009,RA 2014	424	< 200
8.	Alkalinity to Phenolphthalein as CaCO <sub>3</sub> , mg/l	IS:3025(Part -23)-1986,RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO <sub>3</sub> , mg/l	IS:3025(Part -23)-1986,RA 2014	280	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)1991,RA 2014	100	< 75
11.	Magnesium as Mg, mg/l	APHA (23 <sup>rd</sup> Edn:2017)-3500-Mg B	41.8	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993,RA 2014	62.6	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993,RA 2014	10.9	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988,RA 2014	85.2	< 250
15.	Sulphate as SO <sub>4</sub> , mg/l	IS:3025(Part -24)-1986,RA 2014	152.6	< 200
16.	Nitrate as NO <sub>3</sub> , mg/l	IS:3025(Part -34)-1988,RA 2014	19.8	< 45
17.	Fluoride as F, mg/l	APHA (23 <sup>rd</sup> Edn:2017)-4500-F D	1.20	< 1.0
18.	Total Silica as SiO <sub>2</sub> , mg/l	APHA (23 <sup>rd</sup> Edn:2017)- 4500 SiO <sub>2</sub> C	16.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 <sup>rd</sup> Edn:2017)- 3500 Fe B	0.080	< 0.3
<b>MICROBIOLOGICAL</b>				
1.	Total Coliform Bacteria, /100ml	IS:15185:2002, RA2018	Present	Shall be Absent
2.	Escherichia coli, /100ml	IS:15185:2002, RA2018	Absent	Shall be Absent


IS 10500: 2012 = Drinking water Specification

**Note:**

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) TWENTY ONE Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

\*\*\*\*\* End of Report\*\*\*\*\*



Checked By 

VIS/LAB/E/047

# 4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.  
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com