

Internal memo no. 903/35/A
Annexure - B
RMC pour report

Company/ firm:	Modi Reality Mallapur LLP	Block No.: E Block	Towards E Block column 3 concreting purpose
Project:	Gulmochar Residency	Flat / Villa no.:	-
Supplier:	KN Infra	Slab no.:	Towards E Block column 3 concreting purpos
Requisition nos.:	20240403038	A. Estimated quantity:	68M3(M25)
PO nos.:	20240403050	B. Requisition quantity:	68M3
	Sign of Admin	C. Actual quantity poured	28M3
	Sign of Project Manger	D. Difference (C-A)	40M3

Details of RMC pour

Sl.	Date	Time of dispatch h from RMC plant	Time of receipt at site	Time of pour	Quantity poured	Dc No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1.	17.04.24	10:20	14:08	14:20	8	19200	18970	-230				
2.	17.04.24	12:00	12:43	13:05	7	16800	17210	+410				
3.	17.04.24	13:39	17:16	17:30	6.5	15600	15990	+390				
4.	17.04.24	17:23	20:54	21:10	3	7200	7340	+140				
5.	03.05.24	09:10	13:00	13:15	3.5	8400	8760	-360				
6.												
Total:					28	67200	68270	350				
Remarks	Po not to be closed.											

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weight all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at

P.O -


Survey No: 294, Ramapally (V), Keesara(M)
Medchel Dist - 501 301



Email : kninfra1@gmail.com
Ph. No: 9100999994/9100755567

DELIVERY CHALLAN

Customer Name: GULMOHAR RESIDENCY			D.C. No: 0006		Date: 03-05-2024
Delivery Site: MALLAPUR			Truck No: TS08UG5054		Mode: DUMP
S.No:	Description	Qty	Units	Cum. Qty	Remarks
1	M-25 RMC	3.5	Cum	3.5	-
Other Documents Enclosed:			For Office use only		
1)			Driver Name:		V.KISHAN
2)			Signature:		
Note: No alterations will be accepted without supplier & Customer Signatures alongwith reasons.					
Received above material in good condition			for KN INFRA		
Customer Signature			Authorised Signatory		



	400	202	335	0	0	142	36	0	0	0	172	0	0	0	2.00	0.0	0.0	0.0
TOTAL											87	0	0	0	1.00	0.0	0.0	0.0
Act	0.0	2804.0	1439.0	2348.0	0.0	0.0	985.0	250.0	0.0	0.0	0.0	601.0	0.0	0.0	0.0	7.00	0.0	0.0
Tar	0.0	2800.0	1400.0	2345.0	0.0	0.0	980.0	245.0	0.0	0.0	0.0	595.0	0.0	0.0	0.0	7.00	0.0	0.0
Moisture Corection & Other Component Corection																		