QC - Concrete Cube Testing Report.																
Company:		Nrk-Biotech														
Project:		Nextopolis.														
Report for Month:		July - Aug= (2023).														
Prepared By:		QC Team														
Date:		01-09-2023														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
23130	31-07-2023	RMC	M3025	R6 Rmc plant		Chemical blo	slab	2	9-8-23	9	17.5	398.0	17.7			
											17.5	395.0	17.6	17.8		
											17.5	410.0	18.2			