



DELIVERY CHALLAN

Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

D.C. No. : **5448**

Date : 23/5/24

To, _____
M/s. GN ONE PONO - 20240510023

Vehicle No. : T509VF0993 Thuvaka Pally

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
1	M25		8m ³	8m ³	DUMP

MRN-20240524008

INWARD

Inward No: 5338 Dt: 23/5/24

MRN No:

Received By:

Sign:

CRESCENTIALABS PVT LTD

Receiver's Signature

For **R6 Infra**

Authorised Signatory

Company/ firm:	Crescentia Labs Pvt Ltd.	Block No:	south east headroom slab
Project:	GV ONE	Flat / Villa no:	
Supplier:	R6 Infra(M25)	Slab no:	-
Requisition nos:	20240510021	A. Estimated quantity:	120m ³
PO nos.:	20240510023	B. Requisition quantity:	120m ³
Sign of Security	Sign of Admin	Sign of Project Manger	C. Actual quantity poured 11m ³ used on (11-05-24), 8m ³
Details of RMC pour		D. Difference (C-A)	101m ³

Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	Batch no.	Specified wt @2400 kgs/m ³	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m ²	28 days cube test strength in kN/m ²
1	23-05-2024	9:10	9:21	10:13	8m ³	5448	19,200	18,890	310			
2												
3												
					Total		19200	18890	310			
Balanced quantity to be delivered later												

Note: 1. Report to be sent on a daily basis to purchase@modiproperties.com and report-audit@modiproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/ m³. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.