

DELIVERY CHALLAN



Plot No. 15, S.S. Villas,
Markandeya Nagar, Kapra,
Hyderabad, Telangana - 500 062.

D.C. No. :

5458

To,

M/s. GUN ONE

PONDI - 20260427032

Date : 24/5/24

Vehicle No. : T 509N E0997

T KUN KAPRAY

S.No.	Grade	PARTICULARS	Qty.	Cum.	Value
1	M20	<u>M20 - 20240525004</u> INWARD Inward No: <u>S369</u> Dt: <u>24/5/24</u>	<u>4m³</u>	<u>4m³</u>	<u>24m³</u>

Receiver's Signature

CRESCENTIALABS PVT LTD
received By: [Signature]

For **R6 Infra**

Authorised Signatory

[Signature]

Company/ firm:	Crescentia Labs Pvt. Ltd.			Block No:	Terrace screed concrete							
Project:	GV ONE			Flat / Villa no:								
Supplier:	R6 Infrac(M20)			Slab no:								
Requisition nos:	20240427024			A. Estimated quantity:	200m3							
PO nos.:	20240427032			B. Requisition quantity:	200m3							
Sign of Security:	Sign of Admin	Sign of Project Manger	BY	C. Actual quantity poured	45m3 used on(04-05-24), 43m3 used on(20-05-24), 3.5m3 used on(21-05-24), 47m3 used on(23-05-24), 4m3							
Details of RMC pour				D. Difference (C-A)	57.5m3							
Sl. No	Date	Time of dispatch from RMC plant	Time of receipt at site	Time of pour	Quantity poured (Cum)	De No. / Batch no.	Specified wt @2400 kgs/m3	Measured weight (kgs)	Short fall in weight in kgs	Deduction for shortfall in Rs.	7 day cube test strength in kN/m2	28 days cube test strength in kN/m2
1	24-05-2024	10:00	10:06	10:42	4m3	5458	9,600	9,820	-220			
					Total		9,600	9,820	-220			
Remarks				Balanced quantity to be used later								

Note: 1. Report to be sent on a daily basis to purchasc@modhproperties.com and report-audit@modhproperties.com. 2. Report must be prepared during pour and not later. 3. Report must be sent within one working day. 4. Multiple report can be sent for one PO. 5. Weigh all vehicles. 6. 6 cubic meters vehicle should have a net weight of 14,110 kgs @ 2,400kgs/m3. If the shortfall is more than 50 kgs per load purchase to debit supplier shortfall amount on pro-rata basis. 7. Site to calculate shortfall. 8. Maintain original report + weightment slips + pour reports + test reports + photographs at site.