QC - Concrete Cube Testing Report.																
Company:		GVRC														
Project:		Innopolis														
Report for Month:		(Apr - May) = 2024.														
Prepared By:		QC Team														
Date:		30-05-2024														
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks	
14230	04-05-2024	RMC	M30	R6 Infra		4500	footings		13-5-24	9	21.5	508.0	22.6			
											21.5	510.0	22.7	22.5		
											21.5	498.0	22.1			