

(A-Block)
3rd Lift

ASK GENUINE LIFTS
VENKATARAMANA COLONY ,NAGOLE

TO

Date: 20/1/2024

Gulmohar Residency
Survey No 19, Mallapur, Hyderabad. Next to NFC Rai
Hyderabad,Telangana,
BLOCK-A

HANDOVER LETTER

- | | |
|---|--|
| 1. Type of Lift | : 6 passenger Lift. |
| 2. Machine | : MRL MACHINE |
| | : 5 hp sharp |
| 3.Type of controller | : Automatic Rescue Device down collective |
| 4.Signals | : UP & DOWN arrows at all landings and position indicator |
| 5.Drive | : Make V3F Drive |
| 6.No of floors | : Ground+4 |
| 7.Landings and Openings. | :5 landings with 5 Openings |
| 8. Type of Car | : MS Cabin |
| car Door | : Ms collapsible gate |
| 9.Landing Door | : MS SWING DOOR |
| 10.Rope | : Usha Martin (8x19 construction (8mm) - 4No's) |
| 11.Cable | : 12 Core Wiring Cable Flat (0.5 sq.mm) |
| 12.Hardware | : 12x10x8 mm Bolts (Gold color coating) |
| 13.Car Operating Panel | : Stainless Steel Finish with Digital Floor Indicators Up and Down Arrow |
| | Time, Temperature, Emergency light with Dot Matrix LED Display |
| 14.Car Guide | : Heavy Duty T Section Steel Guides machined throughout
(Size 75x56x10mm) |
| 15.Voice Announcer. | : Automatic voice announcer for "Door Open" prefer music - instrumental |
| 16.All other components : Good quality product of standard quality (ISI) only should be used. | |

AMC: M/s Ask Genuine lifts will provide 1year warranty and free maintenance from hand over the lift date (20/01/2024 Hand over date),after one year maintenance vice at Rs 2000 per month which will cover servicing, inspection greasing / lubrication. Material or parts required if any will be charged extra however labour charges will be covered under the maintenance contract.

Yours Sincerely
For M/sAsk Genuine Lifts

For ASK GENUINE LIFTS

Shravan kumar A.
(A. Shravan kumar) Proprietor
Mob: 9248144240


Acknowledgement

MODI REALTY MALLAPUR LLP
Sy. No: 19, Mallapur,
HYDERABAD - 500 076.

Shravan
15/2/2024

(A-BLOCK)
3rd List

ROUTINE TEST REPORT

Machine :	SEG-10 S	Date :- 18/08/2023	
Sr. No. :	I/SEG-10 C 16		
Customer :	Shri Venkateshwara Ent.		
Product Type:- Permanent Magnet Synchronous Gearless Traction Machine			
MAIN SPECIFICATION			
Rated Power (KW) :	3.0	Phase :	3
Rated Voltage(VAC):	400 VAC	Duty :	S5 (40%)
Rated Current (A) :	7.0	Rated Torque(Nm):	230
Rated RPM :	119	Protection:	IP 40
Rated Frequency (Hz):	19.9	Motor Pole :	20
Rated Speed (m/sec):	1.00		
INSULATION TEST :-			
Phase - Phase	> 100 M Ohm	Pass	Winding Resistance (Ohm) :- 13.41Ω
Phase - Earth	> 100 M Ohm	Pass	
Phase - Phase	2 KV	1.0 Min	Pass
Phase - Earth	2 KV	1.0 Min	Pass
BRAKE SPECIFICATION :-			
Type :-	Disc	Brake Coil Current (A) :	1.80 A
Brake Coil Voltage (V):	110 V D.C	Brake Coil Torque (Nm) :	2 x 400 Nm
ENCODER SPECIFICATION:-			
Type :-	HEIDENHAIN	Supply Voltage:-	5 V
PPR:-	2048	Encoder Cable Length:-	7 mtr
ENCODER SR. NO :-	641971797A		
TRACTION MACHINE SPECIFICATION :-			
Max.Static Load (Kg) :	3400	Traction Sheave Dia.	320 mm
Duty Load (Kg) :	408	No of Groove & Rope Dia.	4 Grv & 8mm
No Load Noise Test:	56 Db	Manual Release Brake Test:	Ok
Painting :-	Ok	Encoder Test:-	Pass
MODI REALTY MALLAPUR LLP Sy. No. 19, Mallapur, HYDERABAD-500076 Sign:  Date: 18/08/2023		Appr.by: Mr. Ashok Prajapati Sign: Date: 18/08/2023	

For GENUINE LISTS
sharan den
proprietor

15/2/24



SHARPTM
ENGINEERS

AN ISO 9001:2015 CERTIFIED COMPANY

WARRANTY CERTIFICATE

OWNER DETAILS

Customer Name :

Address :

City :

State :

Pin Code :

Country :

Telephone No. :

Cell No.

E-mail ID :

The warranty on products is valid for a period of One year from the date shown on the shipping papers.

SEG-05
Home Lift Gearless



SEG-10
GEARLESS



SEG-20
GEARLESS



SEG-30
GEARLESS



SEG-40
GEARLESS



SEG-50
GEARLESS



SEG-60
GEARLESS



SEG-70
GEARLESS



SEG-B1
Belt Drive Gearless



552, 'A' Road, Cross Road - 12, G.I.D.C., Kathwada, Ahmedabad - 382430. Guj. India,
Phone : +91 - 79 - 22901711 (5 Lines) Fax : +91 - 79 - 22901716

Email : info@sharpengineers.com
www.sharpengineers.com

MODI REALTY MALLAPUR L.
Sy. No: 19, Mallapur,
HYDERABAD - 500 076

Shiny
15/2/24

PERIODIC MAINTENANCE CHART FOR ELEVATOR TRACTION MACHINE

PREVENTIVE MAINTENANCE CHECK POINTS

Date	EVERY YEAR					
	EVERY 6 MONTHS					
	EVERY 3 MONTHS		Brake Air Gap	Bearing	Electrical Connections	Check Traction Sheave for wear out
	Cleaning	Visual Check of all fastners				

BREAK DOWN MAINTENANCE CHART

BREAK DOWN				
Reporting Date & Time (T1)	Re-commissioning Date & Time (T2)	Total Break Down Time (T1-T2)	Brief Description Of Break Down & Repair	Name & Sign of Maintenance Engg.