


IRN : c5a879a92ec2e4d59ae28ec464d2304ae96c1bf727d29-4c093947b7ed96483d5
 Ack No. : 112317801766805
 Ack Date : 12-Oct-23



ECOGEN GENERATORS INDIA PRIVATE LIMITED - 23-24 Sy. No. 298/2, Shed B4/Part-3, Road No.3, Phase-1, IDA Jeedimetla, Hyderabad - 500 055. GSTIN/UIN: 36AAFCE9876L1ZT State Name : Telangana, Code : 36 E-Mail : admin@ecogen.co.in Consignee (Ship to) MODI REALTY MALLAPUR LLP GULMOHAR RESIDENCY, Sy No:19,Mallapur, Hyderabad., Next to NFC Rai,Hyderabad. State Name : Telangana, Code : 36 Buyer (Bill to) MODI REALTY MALLAPUR LLP 2ND FLOOR, 5-4-187/3 AND 4, SOHAM, MANTION, M G ROAD, SECUNDERABAD, GSTIN/UIN : 36AAEFM1459R1ZP PAN/IT No : AAEFM1459R State Name : Telangana, Code : 36 Place of Supply : Telangana Contact person : Mr.N.Srinivas Contact : 83097 24627		Invoice No. 187 e-Way Bill No. 161726696688 Dated 12-Oct-23 Delivery Note Mode/Terms of Payment 100% in Advance Reference No. & Date. 20230603019 dt. 3-Jun-23 Other References EGIPL/2023-24/267 Buyer's Order No. 20230603019 Dated 3-Jun-23 Dispatch Doc No. Delivery Note Date Dispatched through Local Transporter Destination Mallapur,Hyderabad. Bill of Lading/LR-RR No. dt. 12-Oct-23 Motor Vehicle No. AP28TD0276 Terms of Delivery Door Delivery Driver:Shaik Apsar Ph:63026 65152	
---	--	---	--

Sl No.	Description of Goods	HSN/SAC	GST Rate	Quantity	Rate	per	Amount
1	82.5kVA, 3 Phase Diesel Power Generating Set Supply of 82.5kVA, 3 Phase DG Set Powered by Ashok Leyland Engine Coupled with Leroy Somer Make Alternator Mounted on A Common Base Frame Along with Standard Accessories FIP, C/alternator, S/motor, Battery, Controller Installed in an acoustic enclosure Together with Radiator, Integrated Fuel Tank and Silencer. Tested and in Ready To use Condition. Serial no. Engine model: AL4CTIDG3 Engine S/n: PJHM416010 Alternator: LSAP 44.3B2 S/n: LCS3B223H22609 FIP: STANADYNE FHL00700 FIP S/n: 00620078 TC: Holset-HE221-3792253 S/n: D2305103141 C/alternator: SEG F0C00400 F002 G90 300 S/n: 7204192 S/motors: LTVS-26024719-2023A1195 Controller: SEDEMAC-GC1202 FEB/2023-37606 Battery: EXIDE FGPO-GP110D31R S/n: A4E3A044335-4F31 DG Set No. EGIPL/2023-24/267	85021200	18 %	1 No	5,35,000.00	No	5,35,000.00
							48,150.00

CGST

INWARD

MODI REALTY MALLAPUR LLP

13530 dt.13/10/23

2023/10/30/18

Jaye

HYDERABAD

INDIA PVT. LTD.

continued to page number 2

(ORIGINAL FOR RECIPIENT)

Invoice No.	e-Way Bill No.	Dated
187	161726696688	12-Oct-23
Delivery Note	Mode/Terms of Payment	
	100% in Advance	
Reference No. & Date.	Other References	
20230603019 dt. 3-Jun-23	EGIPL/2023-24/267	
Buyer's Order No.	Dated	
20230603019	3-Jun-23	
Dispatch Doc No.	Delivery Note Date	
Dispatched through	Destination	
Local Transporter	Mallapur,Hyderabad.	
Bill of Lading/LR-RR No.	Motor Vehicle No.	
dt. 12-Oct-23	AP28TD0276	
Terms of Delivery		
Door Delivery		
Driver:Shaik Apsar		
Ph:63026 65152		

SI No.	Description of Goods	HSN/SAC	GST Rate	Quantity	Rate	per	Amount
	SGST						48,150.00
	INWARD RETAILTY MALLAPUR LLP 13530 DU 13/10/23						
	Total			1 No			₹ 6,31,300.00

Amount Chargeable (in words). _____ E. & O.E

INR Six Lakh Thirty One Thousand Three Hundred Only

HSN/SAC	Taxable Value	CGST		SGST/UTGST		Total
		Rate	Amount	Rate	Amount	Tax Amount
85021200	5,35,000.00	9%	48,150.00	9%	48,150.00	96,300.00
Total	5,35,000.00		48,150.00		48,150.00	96,300.00

Tax Amount (in words) : **INR Ninety Six Thousand Three Hundred Only**

Remarks:

Encl. Engine & Main alternator Test Certificate and user manual.

Company's PAN : AAFCE9876L

Declaration

Declaration
We declare that this invoice shows the actual price of the goods described and that all particulars are true and correct.

Customer's Seal and Signature

Company's Bank Details

Bank Name

A/c No.

Branch & IFS Code

for ECOGEN GENERATORS INDIA PRIVATE LIMITED - 23-24

Authorised Signatory

This is a Computer Generated Invoice



ASHOK LEYLAND

ENGINE TEST CERTIFICATE

THIS IS TO CERTIFY THAT

AL4CTIDG3

ENGINE MODEL & TYPE : _____

CMO NUMBER : _____

PJHM416010

SERIAL NUMBER : _____

BS 5514

HAS BEEN TESTED AS PER : _____

CORRECTED POWER OUTPUT AS PER REFERENCE CONDITIONS OF THE TEST

78.0 KW

STANDARD IS : _____

1500

CONTINUOUS / MAXIMUM AT : _____ RPM. WITH / WITHOUT AUXILIARIES

GENSET

THE ENGINE IS PASSED FOR FITMENT IN _____

DATE : **31/05/2023**



For ASHOK LEYLAND LTD.

Quality Incharge

Regd. Office : No. 1, Sardar Patel Road, Guindy, Chennai-600 032, India. Tel : (91) 44 - 2220 6000 Fax : (91) 44 - 2220 6001 www.ashokleyland.com



HINDUJA GROUP

Factory at : Ennore, Hosur, Bhandara & Alwar

**NIDEC INDUSTRIAL AUTOMATION
INDIA PRIVATE LTD.**

No. 45, Nagarur, Huskur Road, Off Tumkur Road, Bengaluru - 562 162.

TEST CERTIFICATE

For

Frame: LSAP 44.3B2 Machine No.: LCS3B223H22609

Salient Pole, Self-Excited & Self-Regulated Single / Double bearing brushless AC Generator. It is certified that the above machine has been tested and found to be electrically and mechanically sound and in good working order on all particulars. It has passed all appropriate high voltage tests and generally complies with the requirements of ISO 8528 - 1&3, IS/IEC 60034-1 standards.

The band of regulated voltage is +/-1% of the rated voltage. Type test has been carried on the machine built to the same specification.



**For Nidec Industrial Automation
India Private Ltd.**

Date: 10-08-2023

[Signature]

**NIDEC INDUSTRIAL AUTOMATION
INDIA PRIVATE LTD.**

No. 45, Nagarur, Huskur Road, Off Tumkur Road, Bengaluru - 562 162.

ROUTINE TEST CERTIFICATE FOR BRUSHLESS AC GENERATOR / ALTERNATOR

Sl. No.	LCS3B223H22609	Frame	LSAP 44.3B2	Report No.	22609
Rated kVA	82.5	Rated Volts	415	Rated Amps	114.8
Rated kW	66	Phase	3	Power factor	0.8
Frequency	50 Hz	RPM	1500	Ph. Seq. / DOR from DE	CW
Connection	STAR	Duty	S1	Amb. Temp	40°C
Enclosure	IP 23	Excitation Type	SELF	Th. Class	H
Altitude	1000m	Bearing DE	—	Bearing NDE	63082RSC3

Standard Reference: ISO 8528 - 1&3, IS/IEC 60034-1

WO : DEV739R4

RESISTANCE, IR & HV TEST

PARTICULAR	RESISTANCE IN OHMS @ 25 °C	INSLN. RESISTANCE IN MEGA OHMS	HV TEST	REMARKS
STATOR	0.079 (L-N)	>300	2.0kV	Tested & found OK
ROTOR	0.635	>300	1.5kV	Tested & found OK
EX-STATOR	12.48	>300	1.5kV	Tested & found OK
EX-ROTOR	0.100 (L-L)	>300	1.5kV	Tested & found OK

TEST RESULT

kVA	kW	Volts	Amps	PF	Freq.	Exc. Volt	Exc. Amp	% Load
82.4	67	412.6 416.2	115.4	0.8	50 50	34 8	2.73 0.66	FL NL

Regulation @ 0.8 PF 0.86%

AVR Type / No: R 120 / 22313A3526

SAE - 3/10"

Date: 10-08-2023

TESTED BY

KRISHNAMURTHI

**For Nidec Industrial Automation
India Private Ltd.**

[Signature]

e-Way Bill



1. E-WAY BILL Details

eWay Bill No 1617 2669 6688

Generated Date 12/10/2023 04:59 PM

Generated By: 36AAF CE987 6L1ZT
Valid Upto: 13/10/2023

Mode Road

Approx Distance: 25km

Type: Outward - Supply

Document Details Tax Invoice - 187 - 12/10/2023 Transaction type: Combination of 2 and 3

IRN: c5a879a92ec2e4d59ae28ec464d2304ae96c1bf727d294c093947b7ed96483d5

2. Address Details

From

GSTIN : 36AAF CE987 6L1ZT
ECOGEN GENERATORS INDIA PRIVATE LIMITED - 23-24
TELANGANADispatch From :
Sy No. 298/2, Shed B4/Part-3, Road No.3,, Phase-1, IDA Jeedimetla, Hyderabad
- 500 055

IDA JEEDIMETLA HYDERABAD TELANGANA-500055

To

GSTIN : 36AAE FM145 9R1ZP
MODI REALTY MALLAPUR LLP
TELANGANAShip To :
GULMOHAR RESIDENCY, Sy No.19,Mallapur,Hyderabad , Next to NFC
Rai,Hyderabad.

Mallapur Hyderabad TELANGANA-500076

3. Goods Details

Please Refer IRN Print to view Goods Details.

Tot. Tax'ble Amt	CGST Amt	SGST Amt	IGST Amt	CESS Amt	CESS Non.Advol Amt	Other Amt	Total Inv.Amt
535000.00	48150.00	48150.00	0.00	0.00	0.00	0.00	631300.00

4. Transportation Details

Transporter ID & Name: SHAIK APSAR

Transporter Doc. No & Date : & 12/10/2023

5. Vehicle Details

Mode	Vehicle / Trans Doc No & Dt.	From	Entered Date	Entered By	CEWB No. (If any)	Multi Veh.Info (If any)
Road	AP28TD0276	IDA JEEDIMETLA, HYDERABAD	12/10/2023 04:59 PM	36AAFCE9876L1ZT	-	-



161726696688

