

ASK GENUINE LIFTS
VENKATARAMANA COLONY ,NAGOLE

TO

Date: 12/07/2024

Gulmohar Residency
Survey No 19, Mallapur, Hyderabad. NExt to NFC Rai
Hyderabad,Telangana,
BLOCK-F

HANDOVER LETTER


- | | |
|--------------------------|---|
| 1. Type of Lift | : 6 passenger Lift. |
| 2. Machine | : MRL MACHINE |
| | : 5 hp sharp |
| 3.Type of controller | : Automatic Rescue Device down collective |
| 4.Signals | : UP & DOWN arrows at all landings and position indicator |
| 5.Drive | : Make V3F Drive |
| 6.No of floors | : Ground+5 |
| 7.Landings and Openings. | : 6 landings with 6 Openings |
| 8. Type of Car | : MS Cabin |
| car Door | : Ms collapsible gate |
| 9.Landing Door | : MS SWING DOOR |
| 10.Rope | : Usha Martin (8x19 construction (8mm) - 4No's) |
| 11.Cable | : 12 Core Wiring Cable Flat (0.5 sq.mm) |
| 12.Hardware | : 12x10x8 mm Bolts (Gold color coating) |
| 13.Car Operating Panel | : Stainless Steel Finish with Digital Floor Indicators Up and Down Arro |
| w | |
| | Time, Temperature, Emergency light with Dot Matrix LED Display |
| 14.Car Guide | : Heavy Duty T Section Steel Guides machined throughout
(Size75x56x10mm) |
| 15.Voice Announcer. | : Automatic voice announcer for "Door Open" prefer music - instru |
| mental | |
| 16.All other components | : Good quality product of standard quality (ISI) only should be used. |

AMC: M/s Ask Genuine lifts will provide 1year warranty and free maintenance from hand over the lift date (20/01/2024 Hand over date),after one year maintenance vice at Rs 2000 per month which will cover servicin g, inspection greasing / lubrication. Material or parts required if any will be charged extra however labour cha rges will be covered under the maintenance contract.

Yours Sincerely
For M/sAsk Genuine Lifts




Acknowledgement

For ASK GENUINE LIFTS


(A. Shravan kumar) **Proprietor**
Mob: 9248144240

F-Block

ROUTINE TEST REPORT

Machine :	SEG-10 S	Date :- 01/03/2024	
Sr. No. :	3/SEG-10 B 88		
Customer :	Shri Venkateshwara Ent.		
Product Type:- Permanent Magnet Synchronous Gearless Traction Machine			
MAIN SPECIFICATION			
Rated Power (KW) :	3.0	Phase :	3
Rated Voltage(VAC):	400 VAC	Duty :	S5 (40%)
Rated Current (A) :	7.0	Rated Torque(Nm):	230
Rated RPM :	119	Protection:	IP 40
Rated Frequency (Hz):	19.9	Motor Pole :	20
Rated Speed (m/sec):	1.00		
INSULATION TEST :-			
Phase - Phase	> 100 M Ohm	Pass	Winding Resistance (Ohm) :- 13.48Ω
Phase - Earth	> 100 M Ohm	Pass	
Phase - Phase	2 KV	1.0 Min	Pass
Phase - Earth	2 KV	1.0 Min	Pass
BRAKE SPECIFICATION :-			
Type :-	Disc	Brake Coil Current (A) :	1.80 A
Brake Coil Voltage (V):	110 V D.C	Brake Coil Torque (Nm) :	2 x 400 Nm
ENCODER SPECIFICATION:-			
Type :-	HEIDENHAIN	Supply Voltage:-	5 V
PPR:-	2048	Encoder Cable Length:-	7 mtr
ENCODER SR. NO :-	643709858A		
TRACTION MACHINE SPECIFICATION :-			
Max.Static Load (Kg) :	3400	Traction Sheave Dia.	320 mm
Duty Load (Kg) :	408	No of Groove & Rope Dia.	4 Grv & 8mm
No Load Noise Test:	52 Db	Manual Release Brake Test:	Ok
Painting :-	Ok	Encoder Test:-	Pass
Prep by: Mr. Bharat Khokhar		Appr.by: Mr. Ashok Prajapati	
Sign: 		Sign:	
Date: 01/03/2024		Date: 01/03/2024	
		For ASK GENUINE LIFTS  Proprietor	



SHARP
ENGINEERS

f b b o e

AN ISO 9001:2015 CERTIFIED COMPANY

WARRANTY CERTIFICATE

OWNER DETAILS

Customer Name :

Address :

City :

State :

Pin Code :

Country :

Telephone No. :

Cell No.

E-mail ID :

The warranty on products is valid for a period of One year from the date shown on the shipping papers.

(SEG-05)
Home Lift Gearless



(SEG-10)
GEARLESS



(SEG-20)
GEARLESS



(SEG-30)
GEARLESS



(SEG-40)
GEARLESS



(SEG-50)
GEARLESS



(SEG-60)
GEARLESS



(SEG-70)
GEARLESS



(SEG-B1)
Belt Drive Gearless



552, 'A' Road, Cross Road - 12, G.I.D.C., Kathwada, Ahmedabad - 382430, GULI INDIA LIFTS
Phone : +91 - 79 - 22901711 (5 Lines) Fax : +91 - 79 - 22905106

Email : info@sharpengineers.com

www.sharpengineers.com

Proprietor

W
SW
SW
SW
SW
SW
SW
SW
S