


Tax Invoice

e-Invoice




IRN : 96e80854ce223e9d83a871419f2b04bc3e48fd34745a7-5da26fef42a5f7d30f3
 Ack No. : 11242285130841
 Ack Date : 18-Oct-24

MIRANT AUTOMATION PRIVATE LIMITED PLOT NO:6A/5, IDA PHASE-I, PATANCHERU, HYDERABAD, TS (36) 502319 GSTIN/UIN: 36AAKCM0817G1ZK State Name : Telangana, Code : 36 E-Mail : accounts@mirrant.com		Invoice No. 2317 Delivery Note		e-Way Bill No. 121961835932 Reference No. & Date.		Dated 18-Oct-24 Mode/Terms of Payment	
Consignee (Ship to) CRESCENTIA LABS PRIVATE LIMITED Plot. No. 15-B, Sy. No. 230 to 243, Turkapally village, Shamirpet mandal, Medchal Malkajgiri District, 500078 GSTIN/UIN : 36AADCB2608M1ZO State Name : Telangana, Code : 36		Buyer's Order No. 20240926005 Dispatch Doc No.		Dated 26-Sep-24 Delivery Note Date		Other References	
Buyer (Bill to) CRESCENTIA LABS PRIVATE LIMITED 5-4-187/ 3 & 4, M G Road, Secunderabad - 500003, 81215 51388, . GSTIN/UIN : 36AADCB2608M1ZO State Name : Telangana, Code : 36		Terms of Delivery					
SI No.	Description of Goods	HSN/SAC	Quantity	Rate	per	Amount	
1	100MM BTU METER MAKE:MIRANT; MODEL:BTU 2900 SR NO : M923102024	90261010	1 NO'S	55,000.00	NO'S	55,000.00	
	CGST					4,950.00	

continued to page number 2

This is a Computer Generated Invoice

MRN-20241019007



Tax Invoice(Page 2)

MIRRAnt AUTOMATION PRIVATE LIMITED PLOT NO:6A/5, IDA PHASE-I, PATANCHERU, HYDERABAD, TS (36) 502319 GSTIN/UIN: 36AAKCM0817G1ZK State Name : Telangana, Code : 36 E-Mail : accounts@mirrant.com Consignee (Ship to)	Invoice No.	e-Way Bill No.	Dated
	2317	121961835932	18-Oct-24
	Delivery Note		Mode/Terms of Payment
CRESCENTIA LABS PRIVATE LIMITED Plot. No. 15-B, Sy. No. 230 to 243, Turkapally village, Shamirpet mandal, Medchal Malkajgiri District, 500078 GSTIN/UIN : 36AADCB2608M1ZO State Name : Telangana, Code : 36	Reference No. & Date.		Other References
	Buyer's Order No.		Dated
	20240926005		26-Sep-24
Buyer (Bill to) CRESCENTIA LABS PRIVATE LIMITED 5-4-187/3 & 4, M G Road, Secunderabad - 500003, 81215 51388, . GSTIN/UIN : 36AADCB2608M1ZO State Name : Telangana, Code : 36	Dispatch Doc No.		Delivery Note Date
	Dispatched through		Destination

Terms of Delivery

Sl No	Description of Goods	HSN/SAC	Quantity	Rate	per	Amount
	SGST					4,950.00
Total			1 NO'S			₹ 64,900.00

Amount Chargeable (in words)

E. & O.E

INR Sixty Four Thousand Nine Hundred Only

HSN/SAC	Taxable Value	Central Tax		State Tax		Total Tax Amount
		Rate	Amount	Rate	Amount	
90261010	55,000.00	9%	4,950.00	9%	4,950.00	9,900.00
Total	55,000.00		4,950.00		4,950.00	9,900.00

Tax Amount (in words) : INR Nine Thousand Nine Hundred Only

Company's Bank Details

A/c Holder's Name: Mirrant Automation Private Limited

Bank Name : ICICI BANK

A/c No. : 180605000774

Branch & IFS Code: PATANCHERU & ICIC0007318

Company's PAN : AAKCM0817G


Declaration

We declare that this invoice shows the actual price of the goods described and that all particulars are true and correct.

for MIRRAnt AUTOMATION PRIVATE LIMITED

Authorised Signatory

This is a Computer Generated Invoice



e-Way Bill

e-Way Bill



Doc No. : Tax Invoice - 2317
Date : 18-Oct-24

IRN : 96e80854ce223e9d83a871419f2b04bc3e48fd34745a75da26fef42a5f7d30f3
Ack No. : 112422285130841
Ack Date : 18-Oct-24

1. e-Way Bill Details

e-Way Bill No. : 121961835932 Mode : Generated Date : 18-Oct-24 11:59 AM
Generated By : 36AAKCM0817G1ZK Approx Distance : 40 KM Valid Upto :
Supply Type : Outward-Supply Transaction Type : Bill To - Ship To

2. Address Details

From
MIRRANT AUTOMATION PRIVATE LIMITED
GSTIN : 36AAKCM0817G1ZK
Telangana

To
CRESCENTIA LABS PRIVATE LIMITED
GSTIN : 36AADCB2608M1ZO
Telangana

Dispatch From

PLOT NO:6A/5, IDA PHASE-I, PATANCHERU,,
HYDERABAD, TS (36) 502319
hyderabad Telangana 502319

Ship To

Plot. No. 15-B, Sy. No. 230 to 243, Turkapally village,,
Shamirpet mandal, Medchal Malkajgiri District,, 500078
Turkapally Telangana 500078

3. Goods Details

HSN Code	Product Name & Desc	Quantity	Taxable Amt	Tax Rate (C+S)
90261010	100MM BTU METER & 100MM BTU METER	1 NOS	55,000.00	9+9

Tot.Taxable Amt : 55,000.00 Other Amt : Total Inv Amt : 64,900.00
CGST Amt : 4,950.00 SGST Amt : 4,950.00

4. Transportation Details


Transporter ID : 36AAKCM0817G1ZK
Name : MIRRANT AUTOMATION PRIVATE LIMITED

Doc No. :
Date :

5. Vehicle Details

Vehicle No. : From : hyderabad

CEWB No.:



e-Way Bill

e-Way Bill

Doc No. : Tax Invoice - 2317
Date : 18-Oct-24



IRN : 96e80854ce223e9d83a871419f2b04bc3e48fd34745a75da26fef42a5f7d30f3
Ack No. : 112422285130841
Ack Date : 18-Oct-24

1. e-Way Bill Details

e-Way Bill No.: 121961835932 Mode : Generated Date : 18-Oct-24 11:59 AM
Generated By: 36AAKCM0817G1ZK Approx Distance : 40 KM Valid Upto :
Supply Type : Outward-Supply Transaction Type: Bill To - Ship To

2. Address Details

From

MIRRAnt AUTOMATION PRIVATE LIMITED
GSTIN : 36AAKCM0817G1ZK
Telangana

To

CRESCENTIA LABS PRIVATE LIMITED
GSTIN : 36AADCB2608M1ZO
Telangana

Dispatch From

PLOT NO:6A/5, IDA PHASE-I, PATANCHERU,,
HYDERABAD, TS (36) 502319
hyderabad Telangana 502319

Ship To

Plot. No. 15-B, Sy. No. 230 to 243, Turkapally village.,
Shamirpet mandal, Medchal Malkajgiri District,, 500078
Turkapally Telangana 500078

3. Goods Details

HSN Code	Product Name & Desc	Quantity	Taxable Amt	Tax Rate (C+S)
90261010	100MM BTU METER & 100MM BTU METER	1 NOS	55,000.00	9+9

Tot. Taxable Amt : 55,000.00 Other Amt : Total Inv Amt : 64,900.00
CGST Amt : 4,950.00 SGST Amt : 4,950.00

4. Transportation Details

Transporter ID : 36AAKCM0817G1ZK
Name : MIRRAnt AUTOMATION PRIVATE LIMITED

Doc No. :
Date :

5. Vehicle Details

Vehicle No. : From : hyderabad

CEWB No.:





MIRRANT

Mirrant Automation Pvt.Ltd.
Plot No:6A/5,IDA Phase-I, Patancheru, Sangareddy Dist.,
Hyderabad-502319, Telangana, INDIA

Calibration Certificate

Certificate No : MAPL/MAGFLOW/2024

O.A.No : MAPL/SAL24-25 / M923102024

Calibration Date : 17-10-2024

Due Date : 16-10-2025

Product : MagFlow 2400

Sr No : M923102024

Customer Name : Crescentia Labs Pvt Ltd

Details of Flow meter

Type of Flowmeter :	Electromagnetic/ BTU	Power Supply :	230 V AC
Line Size :	DN 100	Accuracy :	(+/-) 0.5% of measured value
Calibration Factor:	0.13065858	Output Signal:	4 - 20 mA DC
Calibrated Range :	0 - 150 m3/h	Calibrated Range :	0 - 150 m3/h

List of Formulae

$$1) Q_c = \frac{(C-4) \times \text{Calibration range}}{16} \quad (\text{m}^3/\text{h})$$

$$2) \% \text{ of Deviation} = \frac{(Q_c - Q_m) \times 100}{Q_m} \quad \text{in } Q_c$$

Nomenclature

Q_m = Master Flow Rate

Q_c = Flow Rate Calculated from
Current c

C = Current output of UUC

Calibration Method : Comparison Method

Traceability : All the instrument used or traceable to National standards through reference
Standards and their calibrations are valid.

Calibration Results

Sr.No	Master Flow Rate (Q _m)	Calculated Flow Rate (Q _c)	Deviation in (Q _c)
	m ³ /h	m ³ /h	%
1	37.823	37.851	0.074
2	75.403	75.418	0.020
3	115.561	115.582	0.018

Calibrated By :- SURYA

Verified By :- AKASH

Signature :

Surya

Signature :



It is hereby certified that the equipment mentioned above has been tested and found to meet its specifications.
The Performance of the above equipment is guaranteed for period of 12 months from the date of installation
or 18 months from the date of dispatch, whichever is earlier, against any manufacturing defects only.