

GOVERNMENT OF TELANGANA
ELECTRICAL INSPECTORATE
(An IS/ISO 9001: 2015 Certified Department)



FROM:
The Deputy Chief Electrical Inspector
To Government, Hyderabad
5th Floor, R & B Building,
Masabtank, A.C Guards,
Hyderabad 500 004.

TO:
Modi Realty Pocharam LLP
Sy No. 27
Pocharam
Ghatkesar, Medchal

Lr.No: DCEIG-HYD/TS/EI Ex. 650V/5623 /D.No. 1764/2024 Dated: 20-09-2024

Sir,

Sub:- The Electricity Act, 2003 and Central Electricity Authority(Measures relating to Safety and Electric Supply) Regulations 2010 – Multi - Storeyed Building of Modi Realty Pocharam LLP, Sy.No.27 Pocharam, Ghatkesar, Medchal District – Statutory Approval under regulation 36 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations 2010 – Accorded.

Ref: - 1). Inspection dated: 12-09-2024
2). Your Compliance report received on: 20-09-2024

Under Regulation 36 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, the following equipment of your Electrical Installation is approved for energisation.

DETAILS OF EQUIPMENT

Sl. No:	Service	No. of Service	Capacity	Voltage
I.	3 -Phase Load			
a)	3 BHK Flats	90x5 KW	450 KW	415 V
b)	Domestic Load	1x20 KW	20 KW	415 V

Under the provisions of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, any additions or alterations to your above electrical installation shall not be connected to supply until the same are approved in writing by this Office.

Under Regulation 13(4), 46(7) of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, you are at all times solely responsible for the maintenance of the above installation on such condition as to be free from danger.

The above approval accorded is without prejudice to the statutory/ mandatory obligations to be fulfilled by you under various other acts and rules as the case may be.

The approval accorded for energizing the electrical equipment is the safety for men and machine from electrical hazards in your installation and ipso facto does not confer any right to be used for any other purpose other than for which the approval is accorded

Yours faithfully,

J. hani - P
20/09/24

**DEPUTY CHIEF ELECTRICAL INSPECTOR
TO GOVERNMENT, HYDERABAD**

- 1) Copy to the Divisional Engineer/ Operation/ Of Telangana / Keesara Medchal
The date of release of supply may be intimated to this Office. (Verify the approval in TSCEI .CGG.GOV.IN website in third party verification column before the energization of the supply.)
- 2) Dy. Electrical Inspector, RR-II Sub-Division

Follow the Electricity Act & Regulations of CEA to avoid Electrical Fatal and Fire Accidents