Test Certificate

FOR

SALIENT POLE, SELF EXCITED / PMG EXCITED AND SELF REGULATED AC GENERATOR

Machine No. N23E202296

Type Test has been conducted on similar design machine STANDARDS: Generator generally conforms to BS 5000 : Part 3, Tested in accordance with BS EN 60034-1/IS/IEC 60034-1 Rotor dynamically balanced to BS ISO 1940 - 1

	ROUTINE TEST C	ERTIFICAT	E FOR BRUSHLE	SS AC GENERATOR:		
FRAME: S7L1D-C41	AVR: None	AVR NO: NA ENCLOSURE: IP23		23		
RATED KVA: 1500	RATED VOLTS: 415	RATED AMPS: 2086.8		FREQUENCY: 50	PHASE: 3	
	STR CONN: Star	STR WINDING: 312		DUTY: Base Cont	inuous WIRE: 4-Wire	
EXC. VOLTS: 70	EXC.AMPS: 2.8	AMB TEMP: 40				
FOR 3 PH	ASE SEQUENCE LOOK	NG FROM [DRIVE END FOR C	CLOCKWISE ROTATION	ON :U-V-W	
VACINIDING	COLD DESISTA		INSIII ATION	HV TEST 2KV	INSULATION CLASS	

FOR 3 PHASE	SEQUENCE LOOKING FROM	DRIVE END FOR CLO	OCKWISE ROTATION	ON :U-V-VV	
WINDING	COLD RESISTANCE IN Ohm(+/- 10 %) AT 22°C (MAX VALUES)	INSULATION RESISTANCE (M- Ohm)	HV TEST 2KV FOR 1 MIN	INSULATION CLASS	
STATOR (Phase to Phase)	0.001145	2+	OK	Н	
ROTOR	1.69	2+	OK	Н	

HOTON							
		REGUL	ATION TE	ST			
VOLTS	AMPS	KVA	PF	KW	EXC.VOLT	EXC.AMP	% LOAD
416.4	0.00	0.00	0.00	0.00	13.8	0.61	0.00
	2086.8	1500	0.8	1200	70	2.8	100.00
		VOLTS AMPS 416.4 0.00	VOLTS AMPS KVA 416.4 0.00 0.00	VOLTS AMPS KVA PF 416.4 0.00 0.00 0.00	VOLTS AMPS KVA PF KW 416.4 0.00 0.00 0.00 0.00	REGULATION TEST VOLTS AMPS KVA PF KW EXC.VOLT 416.4 0.00 0.00 0.00 0.00 13.8	REGULATION TEST VOLTS AMPS KVA PF KW EXC.VOLT EXC.AMP 416.4 0.00 0.00 0.00 13.8 0.61 2.8 0.00 0.00 0.00 0.00 0.00 0.00

REGULATION = (N.L.VOLTAGE-F.L.VOLTAGE / RATED VOLTAGE)*100 = 0.34 %

Item Description: AC Generator.S7L1D.4.C.1.312.,0,.,18,.None.Thierry Green

Remarks:

AUTHORISED BY

Date: 17-MAY-23 Job No: 5602668-001

Rahul Kumar R Kushwaha Quality Assurance

Certificate Of Conformity

Quality System Certification ISO 9001:2015

Frame Size: S7L1D-C41

Serial Number: N23E202296

Manufactured Date: 17-MAY-23

KVA: 1500

Authorized By Quality Assurance: Rahul Kumar R Kushwaha

This document is electronically generated, hence signature not required.

Print Date: 17-MAY-23



Cummins India Limited

Registerd Office: Kothrud, Pune 411 038 (India)

Engine Test Certificate

This Is to Certify that Engine Model KTA-50-G8-I serial Number 25486544 has been tested using diesel as per ISO-3046 standard. Corrected Full Load B.H.P. to N.T.P. conditions as per the test standard is 1735 B.H.P. @ 1500 R.P.M

Date: 03/07/2023

Executive Product Conformance

F: 4302: 11:07/P.No.503341



Jakson Limited

Test Certificate

FOR

ELECTRIC GENERATOR SET

NGINF MO	DEL	ENGINE MAKE CUMMINS INDIA LIMITED STAMFORD A.C. GENERATOR MAKE
This is model	to certify CJ1500D5P	that the Electric Generator Set CJG07236007522 has been electrically and mechanically sound and in
Date :	31.07.2023	For Jakson Limited Je etel Authorised Signatory

WORKS: Survey No. 199/1 & Other, Village Kalsar, Taluka Pardi, Dist. Valsad - 396 185. (Gujarat) INDIA REGD. OFFICE: A 626, 6th Floor, DLF Tower-A, Jasola, New Delhi - 110 076 INDIA Website: www.jakson.com