

ANNEXURE-01

TECHNOCRAFTS JOB ID - 3283

CLIENT: M/S MODI PROPERTIES PVT. LTD.

LOCATION : GV RESEARCH CENTERS PVT LTD

33kV, 1250A, 25kA/1SEC, INDOOR VCB 2-PANEL SWITCHBOARD

PANEL S.NO & TYPE	BREAKER SR NO	P127 & P111 (SCHNEIDER)	VAJH13 & VAX31 (ALSTOM)	DIGITAL MULTIFUNCTION METER (SECURE)	AMMETER & VOLTMETER (SCHNEIDER)	POWER PACK, ANNUNCIATOR, HOOTER (ALAN)	CT (PRAGATI)	PT (PRAGATI)
PNLNO: 21093283-00/01 INCOMING PANEL	1VYN020221003494	P127 39768019	VAJH13 35399193 VAX31 35406214	X1696606	AMMETER 54212350446 VOLTMETER 54211060653	POWER PACK PP21022876 ANNUNCIATOR AN210905492 HOOTER EH210806493	21/601157 21/601156 21/601158	21/601153 21/601155 21/601154
PNLNO: 21093283-00/02 OUTGOING PANEL	1VYN020221003506	P111 500025448	VAJH13 35399185 VAX31 35406222	X1696634	AMMETER 54213120216	ANNUNCIATOR AN210905814	21/601160 21/601161 21/601159	N/A



ROUTINE TEST CERTIFICATE

Purchaser's Name : TECHNOCRAFTS SWITCHGEARS PVT LTD

Sale Order No. 4202384303

Type of Breaker	VD4/W 36.12.32
Serial Number of Breaker	1VYN020221003506
Rated Voltage	36 kV
Insulation Level	70/170 kV/kVpk
Rated Current	1250 A
Breaking Capacity	31.5 kA
Rated Frequency	50 Hz
Mass	300 Kg
Rated Control Voltage for Trip Coil	24 V DC
Rated Control Voltage for Close Coil	24 V DC
Rated Control Voltage for Motor	230 V AC
Year of Manufacture	2021

ROUTINE TESTS ACCORDING TO IEC 62271-100


1. MECHANICAL OPERATION TESTS : Satisfactory.
- 1.1 5 closing and 5 opening operations at 110% of control voltage
- 1.2 5 closing and 5 opening operations at 85% of control voltage
- 1.3 5 closing and 5 opening operations at rated control voltage
- 1.4 5 opening operations at 70% control voltage
- 1.5 5 closing - opening operations at 100% of control voltage
- 1.6 5 opening - 0.3 sec- closing operations at 100% control voltage

P.T.O



1.7 Opening - 0.3 sec - closing operation at rated control voltage.

1.7.1 Travel and contact diagrams 1 DIV = 10mm



1.7.2	Operating Speed (m/s)			
Parameter	R	Y	B	
Open	1.36	1.33	1.3	
Close	1.15	1.18	1.13	

1.7.3	Operating time (ms)			
Pole	R	Y	B	
Open	44.6	44.9	44.6	
Close	68.2	67.9	68.2	

1.7.4	Travel (mm)	R	Y	B
Total Travel		21.86	20.99	21.27
Max. Over Travel on Opening		19.86	18.39	19.01
Max. Over Travel on Closing		4.71	4.49	4.37
Max. Bounce on Opening		0.3	0.34	0.28
Contact Spring Travel		3.69	3.64	3.69

2. RESISTANCE OF MAIN CIRCUIT : Satisfactory Resistance in micro Ohms measured at 100A DC.

R - Pole =	26	Y - Pole =	27	B - Pole =	26
------------	----	------------	----	------------	----

3. DIELECTRICAL TESTS : Satisfactory

3.1 Main circuit : 70 kV, 50Hz for 60s

Breaker Position	Test Voltage connected to	Earth connected to
Close	R and B-poles	Frame and Y-pole
Close	Y - pole	Frame, R and B-pole
Open	Top Terminal	Frame and Bottom terminal
Open	Bottom Terminal	Frame and Top terminal

3.2 Auxiliary circuits : 2 kV, 50 Hz, for 60 s (Motor disconnected)

4. VISUAL INSPECTION : Satisfactory

The Circuit Breaker has been successfully tested and accepted as described above

✓ Digitally signed by ABB
Date: 2021.08.23 13:39:10 +05:30
Location: Nashik

INBT-007

Toll Free no: 18004200707
Email: ppmvsupport@in.abb.com

Note: This is Computer generated RTC. No Signature is required.

ROUTINE TEST CERTIFICATE

Purchaser's Name : TECHNOCRAFTS SWITCHGEARS PVT LTD

Sale Order No. 4202384303

Type of Breaker	VD4/W 36.12.32
Serial Number of Breaker	1VYN020221003506
Rated Voltage	36 kV
Insulation Level	70/170 kV/kVpk
Rated Current	1250 A
Breaking Capacity	31.5 kA
Rated Frequency	50 Hz
Mass	300 Kg
Rated Control Voltage for Trip Coil	24 V DC
Rated Control Voltage for Close Coil	24 V DC
Rated Control Voltage for Motor	230 V AC
Year of Manufacture	2021

ROUTINE TESTS ACCORDING TO IEC 62271-100

1. MECHANICAL OPERATION TESTS : Satisfactory.
- 1.1 5 closing and 5 opening operations at 110% of control voltage
- 1.2 5 closing and 5 opening operations at 85% of control voltage
- 1.3 5 closing and 5 opening operations at rated control voltage
- 1.4 5 opening operations at 70% control voltage
- 1.5 5 closing - opening operations at 100% of control voltage
- 1.6 5 opening - 0.3 sec- closing operations at 100% control voltage

P.T.O



ROUTINE TEST CERTIFICATE

Purchaser's Name : TECHNOCRAFTS SWITCHGEARS PVT LTD

Sale Order No. 4202397676

Type of Breaker	VD4/W 36.12.32
Serial Number of Breaker	1VYN020221003494
Rated Voltage	36 kV
Insulation Level	70/170 kV/kVpk
Rated Current	1250 A
Breaking Capacity	31.5 kA
Rated Frequency	50 Hz
Mass	300 Kg
Rated Control Voltage for Trip Coil	24 V DC
Rated Control Voltage for Close Coil	24 V DC
Rated Control Voltage for Motor	230 V AC
Year of Manufacture	2021

ROUTINE TESTS ACCORDING TO IEC 62271-100


1. MECHANICAL OPERATION TESTS : Satisfactory.
- 1.1 5 closing and 5 opening operations at 110% of control voltage
 - 1.2 5 closing and 5 opening operations at 85% of control voltage
 - 1.3 5 closing and 5 opening operations at rated control voltage
 - 1.4 5 opening operations at 70% control voltage
 - 1.5 5 closing - opening operations at 100% of control voltage
 - 1.6 5 opening - 0.3 sec- closing operations at 100% control voltage

P.T.O



1.7 Opening - 0.3 sec - closing operation at rated control voltage.

1.7.1 Travel and contact diagrams 1 DIV = 10mm



1.7.2	Operating Speed (m/s)			
Parameter	R	Y	B	
Open	1.37	1.35	1.35	
Close	1.27	1.18	1.19	

1.7.3	Operating time (ms)			
Pole	R	Y	B	
Open	45.5	45.7	45.3	
Close	67.2	67.2	67.4	

1.7.4	Travel (mm)	R	Y	B
Total Travel		22.02	21.5	21.77
Max. Over Travel on Opening		19.86	18.54	19.38
Max. Over Travel on Closing		4.98	4.7	4.69
Max. Bounce on Opening		0.64	0.47	0.54
Contact Spring Travel		3.65	3.75	3.63

2. RESISTANCE OF MAIN CIRCUIT : Satisfactory
Resistance in micro Ohms measured at 100A DC.

R - Pole =	26	Y - Pole =	25	B - Pole =	26
------------	----	------------	----	------------	----

3. DIELECTRICAL TESTS : Satisfactory

3.1 Main circuit : 70 kV, 50Hz for 60s

Breaker Position	Test Voltage connected to	Earth connected to
Close	R and B-poles	Frame and Y-pole
Close	Y - pole	Frame, R and B-pole
Open	Top Terminal	Frame and Bottom terminal
Open	Bottom Terminal	Frame and Top terminal

3.2 Auxiliary circuits : 2 kV, 50 Hz, for 60 s (Motor disconnected)

4. VISUAL INSPECTION : Satisfactory

The Circuit Breaker has been successfully tested and accepted as described above

✓ Digitally signed by ABB
Date: 2021.08.23 09:12:56 +05:30
Location: Nashik

INBT-007

Toll Free no: 18004200707
Email: ppmvsupport@in.abb.com

Note: This is Computer generated RTC, No Signature is required.

CERTIFICATE OF CONFORMITY AND TESTS



Manufacturer

Schneider Electric Power Monitoring
#12A, Attibele Industrial Ara,
Neralur (PO)
562107, Bangalore

Date of Issue

8/21/2021

The equipment detailed below has been manufactured, inspected and tested in accordance with a quality system certified to the requirements of ISO 9001:2008. Where appropriate, testing is in accordance with published data and relevant EN/IEC 60255-1.

Item Code P111E1N0N91N1NN11N

Model Model E

Vx Vx=24-60V AC/DC 50/60Hz

In In = 1A/5A (0,1In-40In)

Ion Ion = 1A/5A (0,01Ion-2Ion)

Serial Number SN50025448

Quantity 1

Test Summary

Results

1. Insulation Test

1.1 3,11kV DC; 1s-Between each independent circuits

Passed

2. Functional Test

2.1 Power Supply Test

Passed

2.2 Checking for Errors

Passed

2.3 Front Panel Test

Passed

2.4 Front Panel Switch Test

Passed

2.5 Output Contacts Test

Passed

2.6 Inputs Test

Passed

2.7 Current Accuracy Test

Passed

2.8 Communication Test

Passed

Regd Office

Schneider Electric India Pvt. Ltd.,
Plot Bo. B-12, Ground Floor,
Phase-1, New Delhi - 110064



RESULT OF MEASUREMENTS

Test : Calibration and test
Device name : MICOM P127
Serial number : 39768019
Order number : 2004779376/000020
Product code : P127BA0Z112GB0
Software version : BQ03
Operator : 011
Date (dd/mm/yyyy) : 27/04/2021
Result : ACCEPTED

STEP	MEAS.	RESULT	DESCRIPTION	VALUE OF MEASURE			MEASUREMENT	
				VALUE	TOL -	TOL +	VALUE	TOL
0		ACCEPTED	Dielectrical tests by other equip.	3000V= 1s				
1		ACCEPTED	Initialisation - Load soft					
	1	ACCEPTED	Verif Relay WD(tc1) NC closed(P125)	TRUE			TRUE	
	2	ACCEPTED	Power drain	1.500W	0.000W	2.500W	0.5616W	-62.56%
	3	ACCEPTED	Application programm loading	TRUE			TRUE	
	4	ACCEPTED	Setting product address	TRUE			TRUE	
	6	ACCEPTED	Test parameter - write	TRUE			TRUE	
	7	ACCEPTED	Communications EIA-485/RJ45	TRUE			TRUE	
	8	ACCEPTED	Test/Calibration programm loading	TRUE			TRUE	
2		ACCEPTED	Preliminary tests					
3		ACCEPTED	Calibration initialisation					
	2	ACCEPTED	Switch to calibration mode	0.000	0.000	0.000	0.000	0.000
	3	ACCEPTED	Analog circuit Ia	0.000A	0.000A	0.4000A	20.00mA	20.00mA
	4	ACCEPTED	Analog circuit Ib	0.000A	0.000A	0.4000A	2.227mA	2.227mA
	5	ACCEPTED	Analog circuit Ic	0.000A	0.000A	0.4000A	20.00mA	20.00mA
	6	ACCEPTED	Analog circuit It	0.000A	0.000A	80.00mA	0.6103mA	0.6103mA
	7	ACCEPTED	Analog circuit Va	0.000V	0.000V	2.600V	0.2500V	0.2500V
	8	ACCEPTED	Analog circuit Vb	0.000V	0.000V	2.600V	0.2381V	0.2381V
	9	ACCEPTED	Analog circuit Vc	0.000V	0.000V	2.600V	82.84mV	82.84mV
4		ACCEPTED	Current transformers cable					
	1	ACCEPTED	1A Ia	4.000A	15.00%	15.00%	3.721A	-6.97%
	2	ACCEPTED	1A Ib	2.000A	15.00%	15.00%	1.864A	-6.81%
	3	ACCEPTED	1A Ic (open)	0.000A	0.000A	0.4000A	2.500mA	2.500mA
	4	ACCEPTED	1A IO	0.5000A	15.00%	15.00%	0.4580A	-8.39%
	5	ACCEPTED	1A Ic (close)	2.000A	15.00%	15.00%	1.855A	-7.25%
	6	ACCEPTED	5A Ia	4.000A	15.00%	15.00%	3.731A	-6.72%
	7	ACCEPTED	5A Ib	2.000A	15.00%	15.00%	1.850A	-7.50%
	8	ACCEPTED	5A Ic (open)	0.000A	0.000A	0.4000A	6.250mA	6.250mA
	9	ACCEPTED	5A IO	0.5000A	15.00%	15.00%	0.4547A	-9.06%
	10	ACCEPTED	5A Ic (close)	2.000A	15.00%	15.00%	1.869A	-6.56%
5		ACCEPTED	Voltage transformers cable					
	1	ACCEPTED	Va	30.00V	25.00%	-5.00%	25.04V	-16.53%
	2	ACCEPTED	Vb	45.00V	25.00%	-5.00%	37.60V	-16.46%
	3	ACCEPTED	Vc	60.00V	25.00%	-5.00%	49.51V	-17.49%
	5	ACCEPTED	Va / Ia	0.000deg	-3.000deg	3.000deg	-16.23mdeg	-16.23mdeg
	6	ACCEPTED	Vbc / Vab	-120.0deg	-123.0deg	-117.0deg	-120.2deg	-0.1678deg
	7	ACCEPTED	Vca / Vab	120.0deg	117.0deg	123.0deg	120.6deg	0.6066deg
6		ACCEPTED	I (1A) and V calibration measure					
	1	ACCEPTED	Ia Error Gain 1 46Hz	10.50A	20.00%	20.00%	9.665A	-7.95%
	2	ACCEPTED	Ib Error Gain 1 46Hz	10.50A	20.00%	20.00%	9.690A	-7.71%
	3	ACCEPTED	Ic Error Gain 1 46Hz	10.50A	20.00%	20.00%	9.641A	-8.18%
	4	ACCEPTED	Io Error Gain 1 46Hz	5.600A	20.00%	20.00%	5.078A	-9.31%
	5	ACCEPTED	Va Error Gain 1 46Hz	125.0V	25.00%	-5.00%	103.3V	-17.36%

	6	ACCEPTED	Vb Error Gain 1 46Hz	125.0V	25.00%	-5.00%	103.4V	-17.31%
	7	ACCEPTED	Vc Error Gain 1 46Hz	125.0V	25.00%	-5.00%	102.1V	-18.29%
7		ACCEPTED	I (5A) calibration measure					
	1	ACCEPTED	Ia Error Gain 16 46Hz	8.750A	20.00%	20.00%	8.106A	-7.36%
	2	ACCEPTED	Ib Error Gain 16 46Hz	8.750A	20.00%	20.00%	8.050A	-8.00%
	3	ACCEPTED	Ic Error Gain 16 46Hz	8.750A	20.00%	20.00%	8.125A	-7.14%
	4	ACCEPTED	Io Error Gain 16 46Hz	1.750A	20.00%	20.00%	1.584A	-9.50%
8		ACCEPTED	I (1A) and V R/L calibration data calculation					
	1	ACCEPTED	Ia R/L	80.00	60.00	100.0	71.10	-11.13%
	2	ACCEPTED	Ib R/L	80.00	60.00	100.0	68.45	-14.44%
	3	ACCEPTED	Ic R/L	80.00	60.00	100.0	69.66	-12.93%
	4	ACCEPTED	Io R/L	80.00	60.00	100.0	74.25	-7.19%
	5	ACCEPTED	Va R/L	80.00	60.00	100.0	71.19	-11.01%
	6	ACCEPTED	Vb R/L	80.00	60.00	100.0	70.60	-11.75%
	7	ACCEPTED	Vc R/L	80.00	60.00	100.0	74.98	-6.27%
9		ACCEPTED	I (1A) and V K calibration data calculation					
	1	ACCEPTED	Ia K	1.000	0.9000	1.100	1.055	5.53%
	2	ACCEPTED	Ib K	1.000	0.9000	1.100	1.055	5.46%
	3	ACCEPTED	Ic K	1.000	0.9000	1.100	1.059	5.88%
	4	ACCEPTED	It K	1.000	0.9000	1.100	1.069	6.86%
	5	ACCEPTED	Va K	1.150	0.9500	1.350	1.176	2.26%
	6	ACCEPTED	Vb K	1.150	0.9500	1.350	1.176	2.25%
	7	ACCEPTED	Vc K	1.150	0.9500	1.350	1.186	3.09%
10		ACCEPTED	I (5A) K calibration data calculation					
	1	ACCEPTED	Ia R/L	80.00	60.00	100.0	76.45	-4.44%
	2	ACCEPTED	Ib R/L	80.00	60.00	100.0	66.62	-16.73%
	3	ACCEPTED	Ic R/L	80.00	60.00	100.0	68.42	-14.48%
	4	ACCEPTED	Io R/L	80.00	60.00	100.0	72.06	-9.93%
	7	ACCEPTED	Ia K	1.000	0.9000	1.100	1.050	5.01%
	8	ACCEPTED	Ib K	1.000	0.9000	1.100	1.065	6.51%
	9	ACCEPTED	Ic K	1.000	0.9000	1.100	1.053	5.35%
	10	ACCEPTED	It K	1.000	0.9000	1.100	1.077	7.73%
11		ACCEPTED	(1A) I and V angle calibration measure					
	1	ACCEPTED	Angle Ia error 60Hz	0.000deg	-15.00deg	15.00deg	-0.1186deg	-0.1186deg
	2	ACCEPTED	Angle Ib error 50Hz	0.000deg	-15.00deg	15.00deg	-0.1092deg	-0.1092deg
	3	ACCEPTED	Angle Ic error 60Hz	0.000deg	-15.00deg	15.00deg	-0.2357deg	-0.2357deg
	4	ACCEPTED	Angle It error 50Hz	0.000deg	-15.00deg	15.00deg	0.6060deg	0.6060deg
	5	ACCEPTED	Angle Va error 50Hz	0.000deg	-15.00deg	15.00deg	-0.3533deg	-0.3533deg
	6	ACCEPTED	Angle Vb error 50Hz	0.000deg	-15.00deg	15.00deg	-0.7747deg	-0.7747deg
	7	ACCEPTED	Angle Vc error 50Hz	0.000deg	-15.00deg	15.00deg	0.000deg	0.000deg
12		ACCEPTED	(5A) I angle calibration measure					
	1	ACCEPTED	Angle Ia error 50Hz	0.000deg	-15.00deg	15.00deg	0.2260deg	0.2260deg
	2	ACCEPTED	Angle Ib error 60Hz	0.000deg	-15.00deg	15.00deg	70.57mdeg	70.57mdeg
	3	ACCEPTED	Angle Ic error 60Hz	0.000deg	-15.00deg	15.00deg	-0.2830deg	-0.2830deg
	4	ACCEPTED	Angle It error 50Hz	0.000deg	-15.00deg	15.00deg	0.6288deg	0.6288deg
13		ACCEPTED	Loadind calibration data					
	1	ACCEPTED	Write + end calibration mode	TRUE			TRUE	
14		ACCEPTED	Logic inputs test					
	1	ACCEPTED	Logic input TS1/3(9) at voltage 0.8min.	5H			5H	
	2	ACCEPTED	Logic input TS2/4(8) at voltage 0.8min.	aH			aH	
	3	ACCEPTED	Logic input TS5(12) at voltage 0.8min.	10H			10H	
	4	ACCEPTED	Logic input TS6(11) at voltage 0.8min.	20H			20H	
	5	ACCEPTED	Logic input TS7(10) at voltage	40H			40H	



			0.8min.					
	7	ACCEPTED	0.25 voltage min. (10V if TS 220V)	0H			0H	
	9	ACCEPTED	1.2 voltage max. (vmax code H)	7fH			7fH	
15		ACCEPTED	Relays					
	2	ACCEPTED	Relays test without tripping	1H			1H	
	3	ACCEPTED	Tripping on relay 1+3+5+7	155H			155H	
	4	ACCEPTED	Tripping on relay 2+4+6+8	2adH			2adH	
	10	ACCEPTED	Start WATCH-DOG	0.000	0.000	0.000	0.000	0.000
16		ACCEPTED	Angles measure					
	1	ACCEPTED	Angle Ib/Ia 1A	120.0deg	117.0deg	123.0deg	119.0deg	-1.000deg
	2	ACCEPTED	Angle Ic/Ia 1A	120.0deg	117.0deg	123.0deg	119.0deg	-1.000deg
	3	ACCEPTED	Angle It/Ia 1A	-120.0deg	-123.0deg	-117.0deg	-121.0deg	-1.000deg
	4	ACCEPTED	Angle Ib/Ia 5A	120.0deg	117.0deg	123.0deg	119.0deg	-1.000deg
	5	ACCEPTED	Angle Ic/Ia 5A	120.0deg	117.0deg	123.0deg	120.0deg	0.000deg
	6	ACCEPTED	Angle It/Ia 5A	-120.0deg	-123.0deg	-117.0deg	-121.0deg	-1.000deg
	7	ACCEPTED	Angle Va/Ia	0.000deg	-3.000deg	3.000deg	-1.000deg	-1.000deg
	8	ACCEPTED	Angle Vb/Va	120.0deg	117.0deg	123.0deg	119.0deg	-1.000deg
	9	ACCEPTED	Angle Vc/Va	-120.0deg	-123.0deg	-117.0deg	-121.0deg	-1.000deg
17		ACCEPTED	Fourier Measurement -1A 50Hz					
	1	ACCEPTED	Ia-Fourier	10.00A	0.40%	0.40%	10.00A	0.02%
	2	ACCEPTED	Ib-Fourier	10.00A	0.40%	0.40%	9.999A	-0.01%
	3	ACCEPTED	Ic-Fourier	10.00A	0.40%	0.40%	9.998A	-0.02%
	4	ACCEPTED	IO-Fourier	1.000A	0.50%	0.50%	1.001A	0.06%
18		ACCEPTED	measure I (1A) and V					
	1	ACCEPTED	Ia	1.000A	0.50%	0.50%	0.9992A	-0.08%
	2	ACCEPTED	Ib	1.000A	0.50%	0.50%	0.9992A	-0.08%
	3	ACCEPTED	Ic	1.000A	0.50%	0.50%	1.000A	0.04%
	4	ACCEPTED	IO	0.2500A	0.50%	0.50%	0.2503A	0.03%
	5	ACCEPTED	Va	57.00V	3.00%	3.00%	57.05V	0.08%
	6	ACCEPTED	Vb	57.00V	3.00%	3.00%	57.06V	0.10%
	7	ACCEPTED	Vc	57.00V	3.00%	3.00%	57.05V	0.09%
19		ACCEPTED	measure I (5A)					
	1	ACCEPTED	Ia	5.000A	0.50%	0.50%	5.002A	0.04%
	2	ACCEPTED	Ib	5.000A	0.50%	0.50%	4.998A	-0.04%
	3	ACCEPTED	Ic	5.000A	0.50%	0.50%	5.000A	0.00%
	4	ACCEPTED	IO	1.250A	0.50%	0.50%	1.249A	-0.02%
20		ACCEPTED	Test WD and Termination					
	1	ACCEPTED	Test WD	TRUE			TRUE	
	4	ACCEPTED	Parameter - write	TRUE			TRUE	
	5	ACCEPTED	Check of Langage	1H			1H	
	7	ACCEPTED	Test no alarm Default setting	TRUE			TRUE	
	8	ACCEPTED	Light / Screen / Switch	TRUE			TRUE	
	9	ACCEPTED	Pr?ence cover + screw	TRUE				

19200



Test Results VAX 21,31

Order No.: 10936581

Model No. VAX31ZG0250BA

Rating : 24/30-VX1DC,48/54-VX2DC

Serial No. : 35406222

Test Instruction VAX21/31,(For-----)

Date of test : 19 Jul 2021 04:30:40 PM



1. Di-Electric Test

The test voltage must be applied, ramped up and maintained for 1 second and ramped down to 0V as specified in IEC60255-27.
Dielectric test voltages are applied at 50Hz.

2.5kVrms for 1 second between all groups and case.

2.5kVrms for 1 second between individual groups.

2.5kVrms for 1 second between adjacent pair of contacts.

1.25kVrms for 1 second between normally open contacts.

2. Mechanical Setting: Contact Pressure, Gap, Follow Through Checked

3. Functional Tests

Pick-up Voltage

Apply 40% of LNV and check whether relay is operating satisfactorily - A/RL2

Apply 120 % of LNV and check whether relay is operating satisfactorily - A/RL2

Ramp up the voltage from 10% of LNV to until the relay picks-up - A/RL2

Apply 40% of LNV and check whether relay is operating satisfactorily - B/RL3

Apply 120% of LNV and check whether relay is operating satisfactorily - B/RL3

Ramp up the voltage from 10% of LNV to until the relay picks-up - B/RL3

Apply 80% of LNV and check whether relay is operating satisfactorily - C/RL1

Apply 120% of LNV and check whether relay is operating satisfactorily - C/RL1

Ramp up the voltage from 10% of LNV to until the relay picks-up - C/RL1

Drop-off Voltage:

Operate the relay, Ramp down the voltage from 40% to 25%, measure at drops-off

Operate coil current Test

Apply 120% of H.N.V. to the operating coil and check current for RL2

Apply 120% of H.N.V. to the operating coil and check current for RL3

Product Specific Tests

Drop-off time

Apply 80% of LNV to operate the relay and check Drop off time(A&C) (ms)

Apply 80% of LNV to operate the relay and check Drop off time(B&C) (ms)

Final Checks

Contact Continuity

Check all contacts N/O and N/C with a 10mA 12V continuity supply.

Flag operation

Check the flag operation when relay operates.

Note:

L.N.V. & H.N.V refers to Lower Nominal Volts & Higher Nominal Voltage respectively
All measured values must be within the limits specified in the Test Specification.

Tester Name : KUMAR

T&D INDIA LIMITED

19/1, GST Road,

Pallavaram, Chennai-600 043, India

Tel: 044 2264 8000

ga.support@nd@ge.com

Pass/Fail

Pass

Pass/Fail

Pass

Pass/Fail

Pass

Pass/Fail

Pass

Pass/Fail

Pass

VX1

VX2

Operate

NA

OK

Operate

NA

OK

Measured

6.96 V / PASS

13.2 V / PASS

Operate

NA

OK

Operate

NA

OK

Measured

8.4 V / PASS

15.36 V / PASS

Operate

NA

OK

Operate

NA

OK

Measured

16.32 V / PASS

30.48 V / PASS

Pass/Fail

NA

NA

Measured

0.135 A / PASS

NA

Measured

0.136 A / PASS

NA

Measured

NA

613.1 ms / PASS

Measured

NA

612.9 ms / PASS

Pass/Fail

PASS

NA

Pass/Fail

NA

NA

Overall Test Result

PASS

Tester Signature/Stamp : 3588





TEST AND CALIBRATION CERTIFICATE

Model Name : DM3110

Calibration Date : 04-Jun-2021

Meter Sl. No : 54212350446

Accuracy : Class 0.5

This is to certify that the meter has been tested, calibrated and found to be complying the mentioned accuracy standards. Reference meter used for this is traceable to international standards.



Saravana Janardhanan
Plant Director



ISO 9001 : 2015 Certified
ISO 14001 : 2015 Certified
ISO 45001 : 2018 Certified

Schneider Electric India Pvt Ltd
www.se.com

SYSTEM GENERATED DOCUMENT , DOES NOT REQUIRE SIGNATURES



TEST AND CALIBRATION CERTIFICATE

Model Name : DM3210

Calibration Date : 06-Mar-2021

Meter SI. No : 54211060653

Accuracy : Class 0.5

This is to certify that the meter has been tested, calibrated and found to be complying the mentioned accuracy standards. Reference meter used for this is traceable to international standards.




Saravana Janardhanan
Plant Director



ISO 9001 : 2015 Certified
ISO 14001 : 2015 Certified
ISO 45001 : 2018 Certified

Schneider Electric India Pvt Ltd
www.se.com

SYSTEM GENERATED DOCUMENT , DOES NOT REQUIRE SIGNATURES



TEST AND CALIBRATION CERTIFICATE

Model Name : DM3110

Calibration Date : 27-Jul-2021

Meter SI. No : 54213120216

Accuracy : Class 0.5

This is to certify that the meter has been tested, calibrated and found to be complying the mentioned accuracy standards. Reference meter used for this is traceable to international standards.




Saravana Janardhanan
Plant Director



ISO 9001 : 2015 Certified
ISO 14001 : 2015 Certified
ISO 45001 : 2018 Certified

Schneider Electric India Pvt Ltd
www.se.com

SYSTEM GENERATED DOCUMENT , DOES NOT REQUIRE SIGNATURES



H.A. RELAY TEST SHEET

Model No. <u>VAJH13/F0001300A</u>	Order No. <u>10933471</u>	Serial No. <u>35399185</u>
Order Qty. <u>50</u>	Rating <u>24-27 VDC</u> (LNV/HNV)*	Wiring Diagram <u>01VAJH13/F02</u>

1. Model Confirmation (VAJH 13 /23 only) Tick in the appropriate box

ABA Suffix (Low Burden) - Without 25W resistor and Magnet Contact ☐

BBA Suffix (High Burden) - With 25W resistor and Magnet Contact ☒

2. Di-electric Test

2.5kV 50Hz rms for 1 second (Between earth to each terminals) OK

1.25kV 50 Hz rms for 1 second (Across N/O Contacts) OK

3. Contact Setting

2.1 Contact Pressure / Gap / Follow Through : Checked OK ☐

2.2 When flag operated, gap between the armature head } Limit : 120 thou-min
and lower long contact Checked OK ☒

4. Functional Test

Pick up Volts : Limit : 28% to 35% of LNV				
LH (Top) RL1	RH (Top) RL2	CTR	LH (Bottom) RL3	RH (Bottom) RL4
		<u>702V</u>		

5. Satisfactory operation

Relay operated satisfactorily at 50% and 120% of LNV : Checked OK ☒

6. Contact Continuity Test : Checked OK ☐

Limits Reference

LNV	24 V	30 V	48 V	100 V	110 V	125 V	200V	220V	230V	240 V	250V
28% of LNV	6.72V	8.4V	13.44V	28V	30.8V	35V	55V	61.6V	64.4V	67.2V	70V
35% of LNV	8.4V	10.4V	16.8V	35V	38.5V	43.75V	70V	77V	80.5V	84V	87.5V
50% of LNV	12V	15V	24V	50V	55V	62.5V	100V	110V	115V	120V	125V
120% of LNV	28.8V	36V	57.6V	120V	132V	150V	240V	264V	276V	288V	300V

*(LNV – Lower nominal Voltage)

Tested By: [Signature]

Date: 12/7/24

T&D



GE T&D India Limited,
19/1, GST Road, Pallavaram, Chennai 600 043
Tel : +91 44 2264 8000
ga.supportIND@ge.com

VAJH/VAJHM13/23/33/53/MVAJM25/45



H.A. RELAY TEST SHEET

Model No. <u>VAJH13/f0001B2A</u>	Order No. <u>10933471</u>	Serial No. <u>35388123</u>
Order Qty. <u>50</u>	Rating <u>24-27 VDC</u> (LNV/HNV)*	Wiring Diagram <u>01VAJH13/f02</u>

1. Model Confirmation (VAJH 13 /23 only) Tick in the appropriate box

ABA Suffix (Low Burden) - Without 25W resistor and Magnet Contact ☐

BBA Suffix (High Burden) - With 25W resistor and Magnet Contact ☒

2. Di-electric Test

2.5kV 50Hz rms for 1 second (Between earth to each terminals) OK

1.25kV 50 Hz rms for 1 second (Across N/O Contacts) OK

3. Contact Setting

2.1 Contact Pressure / Gap / Follow Through : Checked OK ☒

2.2 When flag operated, gap between the armature head } Limit : 120 thou min
and lower long contact Checked OK ☒

4. Functional Test

Pick up Volts : Limit : 28% to 35% of LNV

LH (Top) RL1	RH (Top) RL2	CTR	LH (Bottom) RL3	RH (Bottom) RL4
		<u>80 V.</u>		

5. Satisfactory operation

Relay operated satisfactorily at 50% and 120% of LNV : Checked OK ☒

6. Contact Continuity Test : Checked OK ☒

Limits Reference

LNV	24 V	30 V	48 V	100 V	110 V	125 V	200V	220V	230V	240 V	250V
28% of LNV	6.72V	8.4V	13.44V	28V	30.8V	35V	55V	61.6V	64.4V	67.2V	70V
35% of LNV	8.4V	10.4V	16.8V	35V	38.5V	43.75V	70V	77V	80.5V	84V	87.5V
50% of LNV	12V	15V	24V	50V	55V	62.5V	100V	110V	115V	120V	125V
120% of LNV	28.8V	36V	57.6V	120V	132V	150V	240V	264V	276V	288V	300V

*(LNV – Lower nominal Voltage)

Tested By: [Signature]

Date : 12/7/24

T&D

GE T&D India Limited,
19/1, GST Road, Pallavaram, Chennai 600 043
Tel : +91 44 2264 8000
ga.supportIND@ge.com



VAJH/VAJHM13/23/33/53/MVAJM25/45



H.A. RELAY TEST SHEET

Model No. <u>VAX31ZG0250BA</u>	Order No : <u>10933497</u>	Serial No. <u>35406214</u>
Order Qty: <u>15</u>	Rating : VX1 <u>24-30</u> LNV/HNV* VX2 <u>48-54</u> <u>2</u> DC LNV/HNV*	Wiring Diagram : <u>01VAX31ZG001</u>

1. Di-electric Test : 2.5kV 50Hz rms for 1 second (Between earth to each terminals) ok
 1.25kV 50 Hz rms for 1 second (Across N/O Contacts) ok

2. Contact setting : Contact Pressure / Gap / Follow Through: Checked OK 3. Functional test ☒

VOLTAGE RANGE	UNIT A P/U volts (V)	UNIT A current For 24/30V @36V For 110/125V @150V	UNIT B P/U volts (V)	UNIT B current For 24/30V @36V 110/125V @150V	UNIT C P/U VOLTS (V)	D/O time A & C at 80% of LNV	D/O time B & C at 80% of LNV
Limits	Less than 40% of LNV	24/30V Vx (130-150mA) 110/125V Vx (21-26.5 mA)	Less than 40% of LNV	24/30V Vx (130-150mA) 110/125V Vx (21-26.5 mA)	Less than 80% of LNV	Should be 350 to 800 msec	Should be 350 to 800 msec
VX1	<u>8.6 v</u>	<u>130.8</u>	<u>8.9 v</u>	<u>140.6</u>	<u>14.7 v</u>	<u>NA</u>	<u>NA</u>
VX2	<u>16.1 v</u>	<u>NA</u>	<u>16.6 v</u>	<u>NA</u>	<u>26.9 v</u>	<u>563</u>	<u>569</u>

4. Satisfactory Operation:

A&B units satisfactorily operated at 40% and 120% of LNV : Checked OK ☒

C unit satisfactorily operated at 80% and 120% of LNV : Checked OK ☒

5. Contact Continuity Test : Checked OK ☒

Voltage Limits reference	24V	30V	48V	110V	220V
40% of LNV	9.6	12	19.2	44	88
80% of LNV	19.2V	24V	38.4V	88V	176V
120% of LNV	28.8V	36V	57.6V	132V	264V

* (LNV/HNV - Lower/Higher nominal Volts)

Limits specified above are production testing only

Construction Requirement Check: OK

For regular operation, limits specified in Catalogue are applicable.

Tested By : 5022
T&D

Date : 21-7-21



METER TEST CERTIFICATE



Serial number : X1696606

Accuracy Class : 0.2s Ref. Standard : IEC : 62053-22

1. AC VOLTAGE TEST
2. TEST OF NO LOAD CONDITION
3. TESTING OF STARTING CURRENT CONDITION
4. INSULATION RESISTANCE TEST
5. POWER CONSUMPTION TEST
6. TEST OF METER CONSTANT
7. LIMITS OF ERROR

:- PASS
:- PASS
:- PASS
:- PASS
:- PASS
:- PASS

- 7(a) Conditions-Vref = 57.7-240V Ib = 1-5A Amb. Temp. = 23°C +/- 2°C Relative Humidity < 70%.
7(b) Errors shown in the tables are given after accounting the error of reference meter.
7(c) Reference meter serial no. 050048407 class 0.02S traceable to national & international standards.
7(d) Errors shown in the tables are taken at Ib = 1A(100%)

IMPORT MODE ERRORS

(e) %Active Errors(Balance Mode)

Load % Ib	0.5 Lag	0.8 Lead	UPF
1000	-0.01	0.03	0.02
500	0.02	0.00	0.00
100	0.01	0.02	0.06
50	0.02	0.00	0.00
10	0.03	-0.01	0.00
5			-0.02
2	0.00	-0.10	
1			-0.16

(f) %Reactive Errors(Balance Mode)

Load % Ib	0.5 Lag	0.8 Lead
1000	0.00	0.01
500	-0.01	0.02
100	0.03	0.02
50	-0.01	0.02
10	0.00	0.04

EXPORT MODE ERRORS

(e) %Active Errors(Balance Mode)

Load % Ib	0.5 Lag	0.8 Lead	UPF
1000	0.00	0.02	0.01
500	0.01	0.00	0.00
100	0.02	0.03	0.04
50	0.01	0.00	0.00
10	0.06	0.01	0.02
5			-0.02
2	0.18	-0.02	
1			-0.01

Date :- 01/06/2021

This is a computer generated test certificate.No signature required.

Secure Meters Limited
Unit II, Village Bated,
Off Haripur Road, Barotiwala
Dist. Solan 174 103 (HP), India

p: +91 1792 255591
f: +91 1792 255593
e: unit2@securemeters.com

Regd. & Head Office
"E" Class
Prataphnagar Industrial Area
Udaipur 313 003, India
CIN No: U74899RJ1987PLC029106

p: +91 294 2492300-305
f: +91 294 2492310
e: mktg@securemeters.com
www.securemeters.com



METER TEST CERTIFICATE



Serial number : X1696634

Accuracy Class : 0.2s Ref. Standard : IEC : 62053-22

- | | |
|--|----------|
| 1. AC VOLTAGE TEST | : - PASS |
| 2. TEST OF NO LOAD CONDITION | : - PASS |
| 3. TESTING OF STARTING CURRENT CONDITION | : - PASS |
| 4. INSULATION RESISTANCE TEST | : - PASS |
| 5. POWER CONSUMPTION TEST | : - PASS |
| 6. TEST OF METER CONSTANT | : - PASS |
| 7. LIMITS OF ERROR | : - PASS |

7(a) Conditions-Vref = 57.7-240V Ib = 1-5A Amb. Temp. = 23°C +/- 2°C Relative Humidity < 70%.

7(b) Errors shown in the tables are given after accounting the error of reference meter.

7(c) Reference meter serial no. 050048407 class 0.02S traceable to national & international standards.

7(d) Errors shown in the tables are taken at Ib = 1A(100%)

IMPORT MODE ERRORS

(e) %Active Errors(Balance Mode)

Load % Ib	0.5 Lag	0.8 Lead	UPF
1000	0.00	0.02	0.02
500	0.02	0.01	0.01
100	0.00	0.01	0.07
50	0.02	0.00	0.01
10	0.03	0.00	0.01
5			0.00
2	-0.04	-0.10	
1			-0.19

(f) %Reactive Errors(Balance Mode)

Load % Ib	0.5 Lag	0.8 Lead
1000	0.00	-0.01
500	0.00	0.02
100	0.00	-0.04
50	-0.01	0.02
10	0.01	0.03

EXPORT MODE ERRORS

(e) %Active Errors(Balance Mode)

Load % Ib	0.5 Lag	0.8 Lead	UPF
1000	-0.02	0.00	0.00
500	0.01	0.00	0.01
100	-0.01	0.02	0.04
50	0.02	0.00	0.01
10	0.05	0.01	0.02
5			0.01
2	0.06	-0.07	
1			-0.15

Date :- 01/06/2021

This is a computer generated test certificate.No signature required.

Secure Meters Limited
Unit II, Village Bated,
Off Haripur Road, Barotiwala
Dist. Solan 174 103 (HP), India

p: +91 1792 255591
f: +91 1792 255593
e: unit2@securemeters.com

Regd. & Head Office
"E" Class
Pratapnagar Industrial Area
Udaipur 313 003, India
CIN No: U74899RJ1987P1C029106

p: +91 294 2492300-305
f: +91 294 2492310
e: mktg@securemeters.com
www.securemeters.com



1) Model : APP-230024-60Min

2) Serial Number/Numbers : **PP 21022876** to **2879** QTY : **4** Nos.

3) Date Of Manufacturing : **FEB - 2021**

4) Visual Inspection : O.K

5) Input Voltage : 230V AC

6) Output Voltage : 24V DC

7) Max. output Voltage : 50 W Continuous Load

8) Non Stored Power : 50 Watts

9) Stored Power : 50 Watts/60 Min

10) Load Regulation : Better than 2%

11) Output Over Voltage Protection : ☒

12) Output OverLoad & Short Circuit protection : ☒

13) Visual Indication

☒ Charger ON. ☒ Output switch Off.

☒ Battery Operation. ☒ Output Overload.

☒ Output ON.

14) High Voltage Test : ☒ 2KVAC for 1 minute between body to all terminals.

:

The warranty shall not apply to any product or parts which have been damaged on account of improper installation, improper connections, misuse, negligence, accident or any other abnormal conditions operation. Any attempt to tamper with the product as evidenced by disruption of warranty sticker and / or unauthorised repair / modification of the product shall render this warranty null & void.

Akolkar
Mrs. YOGITA AKOLKAR
Authorised Signatory
(Quality Assurance)

Dt: 02/04/2018



**Test report cum Warranty Certificate
for ALARM ANNUNCIATOR**

1) Model	: 3 D 0 B 18 S P R 0 0 0 L	
2) Number of Windows	: 18 WINDOWS WITH RS-485	
3) Serial Number / Numbers	: AN 210905814 to 5814	Qty : 1 Nos.
4) Date of Manufacturing	: SEP- 2021	
5) Visual Inspection	: O.K	
6) Supply Voltage	: 18~90V DC	
7) Window Configuration	: 5 C X 4 R	
8) Window Size	: SMALL SIZE: 34 X 32mm	
9) Operating Sequence	: M (MANUAL RESET)	
10) Fault Contact Selection	: NO/NC	
11) Audible Selection	: TRIP/GROUP1 ALL : NON TRIP/GROUP2	
12) Panel Cutout	: 210 mm X 138 mm	
13) High Voltage Test	: NA	

(2.5KVAC for 1 Minute between body To all terminals shorted together.)

It is hereby certified that the equipment / equipments mentioned above has been tested and found to meet it's specifications. This equipment / These equipments carries a warranty of twelve months from the date of Installation or eighteen months from the date of despatch, whichever is earlier against any manufacturing defects only. This warranty is limited to repair or replace unit at our works only, (Excluding battery if any).

The warranty shall not apply to any product or parts which have been damaged on account of improper installation, improper connections, misuse, negligence, accident or any other abnormal conditions operation. Any attempt to tamper with the product as evidenced by disruption of warranty sticker and / or unauthorised repair / modification of the product shall render this warranty null & void.

For Alan Electronic Systems Pvt.Ltd.



Mr.PANDURANG MAINGADE
Tested By



Mrs.YOGITA AKOLKAR
Authorised Signatory
(Quality Assurance)

Note : PLEASE MENTION SERIAL NO. OF THE UNIT IN ALL YOUR FUTURE CORRESPONDENCE.

<u>Equipments Used for Testing</u>	<u>Model / Make</u>	<u>Sr.No</u>	<u>Calibration Due</u>
1) Multi meter	RISH MULTI 13S	14149	19-01-2022

DOC: F/QAD/IND/TC_ANN/R03. Dt: 02/04/2018



**Test report cum Warranty Certificate
for ALARM ANNUNCIATOR**

1) Model	: 1 D 0 B 8 S S R 0 0 0 L	
2) Number of Windows	: 8 WINDOWS WITHRS-485	
3) Serial Number / Numbers	: AN 210905492 to 5493	Qty: 2 Nos.
4) Date of Manufacturing	: SEP- 2021	
5) Visual Inspection	: O.K	
6) Supply Voltage	: 18~90V DC	
7) Window Configuration	: 2 C X 4 R	
8) Window Size	: SMALL SIZE: 34 X 32mm	
9) Operating Sequence	: M (MANUAL RESET)	
10) Fault Contact Selection	: NO/NC	
11) Audible Selection	: TRIP/GROUP1 ALL : NON TRIP/GROUP2	
12) Panel Cutout	: 68 mm X 138 mm	
13) High Voltage Test	: NA	

(2.5KVAC for 1 Minute between body To all terminals shorted together.)

It is hereby certified that the equipment / equipments mentioned above has been tested and found to meet it's specifications. This equipment / These equipments carries a warranty of twelve months from the date of Installation or eighteen months from the date of despatch, whichever is earlier against any manufacturing defects only. This warranty is limited to repair or replace unit at our works only, (Excluding battery if any).

The warranty shall not apply to any product or parts which have been damaged on account of improper installation, improper connections, misuse, negligence, accident or any other abnormal conditions operation. Any attempt to tamper with the product as evidenced by disruption of warranty sticker and / or unauthorised repair / modification of the product shall render this warranty null & void.

For Alan Electronic Systems Pvt.Ltd.


Mr.PANDURANG MAINGADE
Tested By


Mrs.YOGITA AKOLKAR
Authorised Signatory
(Quality Assurance)

Note : PLEASE MENTION SERIAL NO. OF THE UNIT IN ALL YOUR FUTURE CORRESPONDENCE.

Equipments Used for Testing	Model / Make	Sr.No	Calibration Due
1) Multi meter	RISH MULTI 135	69477	06-06-2022

DOC: F/QAD/IND/TC_ANN/R03. Dt: 02/04/2018



**Test report cum Warranty Certificate
for ELECTRONIC HOOTER**

- 1) Model : AUH-01
 2) Serial Number/ Numbers : EH 210806488 to 6511 Qty : 24 Nos.
 3) Date Of Manufacturing : AUG - 2021
 4) Visual Inspection : O.K.
 5) Electrical Testing :


Input Voltage	Sound Level in dB at Nominal input Voltage (1 MTR distance)								
	Tone - 1			Tone - 2			Tone - 3		
	95 - 100	100 - 105	> 105	95-100	100-105	> 105	95-100	100-105	>105
18~285 V AC	☐	☒	☐	☐	☒	☐	☐	☒	☐
18~285 V DC	☐	☒	☐	☐	☒	☐	☐	☒	☐

It is hereby certified that the equipment / equipments mentioned above has been tested and found to meet it's specifications. This equipment / These equipments carries a warranty of twelve months from the date of Installation or eighteen months from the date of despatch, whichever is earlier against any manufacturing defects only . This warranty is limited to repair or replace unit at our works only, (Excluding battery if any).

The warranty shall not apply to any product or parts which have been damaged on account of improper installation, improper connections, misuse, negligence, accident or any other abnormal conditions operation. Any attempt to tamper with the product as evidenced by disruption of warranty sticker and / or unauthorised repair / modification of the product shall render this warranty null & void.

For Alan Electronic Systems Pvt.Ltd.


 Mr.PANDURANG MAINGADE
 Tested By


 Mrs. YOGITA AKOLKAR
 Authorised Signatory
 (Quality Assurance)

NOTE : PLEASE MENTION SERIAL NO. OF THE UNIT IN ALL YOUR FUTURE CORRESPONDENCE

Equipments Used for Testing	Model / Make	Sr.No	Calibration Due
1) Sound Level Meter	SL-4010	150522611	08.02.2022
2) Multi Meter	RISH MULTI 13S	14149	19.01.2022

DOC : F/QAD/IND/TC-AUD/R03, Dt : 02/04/2018



**PRAGATI ELECTRICALS PVT. LTD.**

Plot No. A-2/16, MIDC, Industrial Area,
Murbad-421 401. Dist - Thane (INDIA).
Telephone : 02524-660100. Fax : 02524-660131.

Test Certificate For Current Transformer

PRAGATI ELECTRICALS PVT. LTD.
ISO 9001: 2015 BR NO. 20002412

Cus Name : Technocrafts Switchgear Private Limited IL : 36/70/170 kVp
PO No. : PO08211652 Dt.13/08/2021 Core1 : 15 VA, Class 0.5....(At 100/1 A).
Project : 3283 Core2 : 15 VA, Class 5P20....(At 100/1 A).
Spec No : 3283 1
Ratio : 100-200/1-1 A
Qty : 3 No(s)
Type : Resin Cast, Indoor, wound primary current transformer to IS:2705/1992

WO : A29601 Item : 2
Drg : PR-6584 Type : 2
Freq. : 50 Hz
Ins Class: B
STC : 25 kA/1 Sec.
Sec.Terminals on : P1 Side

Current Transformer(s) were subjected to the following tests and were found to comply with the relevant standard.

* Verification of Terminal marking, Polarity and Overall dimensions.

* Overvoltage interturn Test : At rated secondary current for 1 min.

* H.V. Test on Primary winding 70 kV for 1 Min.

* H.V. Test on Secondary winding : 3 kV for 1 Min.

* Determination of errors according to the appropriate accuracy class.

Serial Number -				21/601156		21/601156		21/601157		21/601157		21/601158		21/601158		21/601158									
In (%)	Core	Burden (VA)	P.F.	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)
Ratio				100/1	200/1	100/1	200/1	100/1	200/1	100/1	200/1	100/1	200/1												
120	1	15	0.8	0.089	3.4	0.119	1.6	0.094	3.2	0.122	1.6	0.077	3.4	0.112	1.7										
100				0.078	3.9	0.116	1.7	0.083	3.7	0.119	1.7	0.065	4.0	0.109	1.9										
20				-0.033	7.3	0.082	2.9	-0.026	7.0	0.083	2.8	-0.048	7.7	0.074	3.0										
5				-0.204	11.2	0.019	4.4	-0.202	10.9	0.019	4.4	-0.219	11.7	0.011	4.6										
120		3.75	1	0.376	5.1	0.197	1.9	0.378	5.0	0.199	1.9	0.375	5.3	0.194	2.0										
100				0.373	5.2	0.197	2.0	0.376	5.1	0.198	2.0	0.373	5.5	0.193	2.1										
20				0.345	7.6	0.184	3.0	0.346	7.5	0.185	2.9	0.346	7.9	0.181	3.1										
5				0.280	11.7	0.156	4.8	0.279	11.7	0.156	4.9	0.280	12.0	0.151	4.9										
Ratio				100/1	200/1	100/1	200/1	100/1	200/1	100/1	200/1	100/1	200/1												
100	2	15	0.8	0.603	6.5	0.303	2.7	0.639	6.2	0.342	2.7	0.647	5.6	0.328	2.4										

■ PD Test

Composite Error Test

Serial Number	Sec. Wdg. Terminals	Sec. Wdg. Res. at (75°C) (Ohms)	Exciting Current at sec. limiting Voltage (Amp)	Composite Error (%)	P.D. Value in pC at (22.86 kV) as per IS 11322/1985



Tested By : Avinash Markad.

Checked By : Abdul Majeed.

Date : 06/09/2021

Page 1 of 2

F/QI/027

THIS IS SYSTEM GENERATED COPY HENCE SIGNATURE IS NOT REQUIRED.

21/601156	2S1-2S2	4.9501	0.0836	0.4182	4
	2S1-2S3	0.1005	0.0157	0.0787	
21/601157	2S1-2S2	5.0317	0.0938	0.4692	4
	2S1-2S3	10.1660	0.0169	0.0846	
21/601158	2S1-2S2	4.9274	0.0753	0.3764	4
	2S1-2S3	10.0842	0.0139	0.0697	



Tested By : Avinash Markad.

Checked By : Abdul Majeed.

Date : 06/09/2021

Page 2 of 2

**PRAGATI ELECTRICALS PVT. LTD.**

Plot No. A-2/16, MIDC, Industrial Area,
Murbad-421 401. Dist - Thane (INDIA).
Telephone : 02524-660100. Fax : 02524-660131.

Test Certificate For Current Transformer

PRAGATI ELECTRICALS PVT. LTD.
ISO 9001: 2015 BR NO. 20002412

Cus Name : Technocrafts Switchgear Private Limited
PO No. : PO08211652 Dt.13/08/2021
Project : 3283
Spec No : 3283 1
Ratio : 50/1-1 A
Qty : 3 No(s)

IL : 36/70/170 kVp
Core1 : 15 VA, Class 0.5.
Core2 : 15 VA, Class 5P20.

WO : A29601 Item : 3
Drg : PR-6584 Type : 2
Freq. : 50 Hz
Ins Class: B
STC : 25 kA/1 Sec.
Sec.Terminals on : P2 Side

Type : Resin Cast, Indoor, wound primary current transformer to IS:2705/1992

Current Transformer(s) were subjected to the following tests and were found to comply with the relevant standard.

* Verification of Terminal marking, Polarity and Overall dimensions.

* H.V. Test on Primary winding 70 kV for 1 Min.

* Determination of errors according to the appropriate accuracy class.

* Overvoltage interturn Test : At rated secondary current for 1 min.

* H.V. Test on Secondary winding : 3 kV for 1 Min.

Serial Number -				21/601159		21/601160		21/601161											
In (%)	Core	Burden (VA)	P.F.	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)
Ratio				50/1		50/1		50/1											
120	1	15	0.8	0.036	4.4	0.050	4.4	0.044	4.6										
100				0.023	5.1	0.038	5.0	0.031	5.2										
20				-0.097	9.1	-0.076	8.8	-0.089	9.2										
5				-0.278	13.6	-0.249	12.9	-0.273	13.5										
120		3.75	1	0.353	6.0	0.359	5.8	0.358	6.1										
100				0.351	6.2	0.357	6.0	0.356	6.3										
20				0.322	8.9	0.329	8.5	0.325	8.9										
5				0.248	13.4	0.255	12.9	0.239	13.7										
Ratio				50/1		50/1		50/1											
100	2	15	0.8	0.520	9.6	0.539	7.9	0.654	6.3										

Composite Error Test

Serial Number	Sec. Wdg. Terminals	Sec. Wdg. Res. at (75°C) (Ohms)	Exciting Current at sec. limiting Voltage (Amp)	Composite Error (%)	P.D. Value in pC at (22.86 kV) as per IS 11322/1985
21/601159	2S1-2S2	4.6832	0.1149	0.5745	4
21/601160	2S1-2S2	4.6526	0.1196	0.5978	4
21/601161	2S1-2S2	4.8697	0.1201	0.6007	4


Tested By : Avinash Markad

Checked By : Abdul Majeed

Date : 06/09/2021

Page 1 of 1

F/QI/027



THIS IS SYSTEM GENERATED COPY HENCE SIGNATURE IS NOT REQUIRED.

**PRAGATI ELECTRICALS PVT. LTD.**Plot No. R-230, TTC, MIDC, Indl. Area Rabale,
Navi Mumbai-400 701.(INDIA)

Telephone : 91-22-3092 3500 Fax : 91-22-2769 7225

Test Certificate For Voltage TransformerPRAGATI ELECTRICALS PVT. LTD.
ISO 9001: 2015 BR NO. 20002412**Client Name** : Technocrafts Switchgear Private Limited**PO No.** : PO08211652 dt : 13/08/2021**Project** : 3283**Spec No** : 3283 1**Ratio** : 33000/V3/110/V3/110/V3/110/3 V**Qty** : 3 Nos**Type** : Resin Cast, Indoor, Single Phase, Single Pole insulated 'Earthed Type' Voltage Transformer complete with Built in H.V Fuse (Phoenix Make) to IS:3156/1992.**IL** 36/70/170 kVp

Sec1.: 50 VA, Class 0.5.

Sec2.: 50 VA, Class 3P.

Sec3.: 50 VA, Class 3P.

WO : A29601 Item : 1**Drg.** : PR-3603 (C) Type :**V.F** : 1.2 Cont. & 1.9 for 8 hrs.**Freq.** : 50 Hz**Ins Class** : B

Voltage Transformer(s) were subjected to the following tests and were found to comply with the relevant standard.

* Verification of Terminal marking, Polarity and Overall Dimensions

* H.V. Test on Primary winding neutral **3.0 kV for 1 min.**

* Determination of errors according to the appropriate accuracy class.

* Induced Overvoltage Test : At **70 kV** and **150Hz.** for 40 Seconds* H.V. Test on secondary Winding : **3.0 kV for 1.0 min.**

Serial Number --			21/601153		21/601154		21/601155															
Vn (%)	Sec Wdg	Burden (VA)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)
120	1a - 1n	50	0.065	5.2	0.064	5.1	0.066	5.3														
100			0.080	4.7	0.078	4.6	0.080	4.7														
80			0.088	4.3	0.086	4.2	0.089	4.3														
120			0.393	3.1	0.385	3.0	0.397	3.1														
100			0.408	2.4	0.400	2.4	0.412	2.5														
80		12.5	0.415	2.1	0.407	2.1	0.419	2.2														
190	2a - 2n	50	-0.581	30.5	-0.570	29.9	-0.587	30.8														
120			-0.384	19.6	-0.376	19.2	-0.387	19.8														
5			-0.347	19.3	-0.340	18.9	-0.350	19.5														
2			-0.323	18.4	-0.317	18.0	-0.327	18.5														
190			0.079	18.8	0.077	18.4	0.079	19.0														
120	12.5		0.291	7.0	0.285	6.9	0.294	7.1														
5			0.344	6.7	0.337	6.6	0.347	6.8														
2			0.392	6.3	0.384	6.2	0.396	6.4														
190			0.407	25.6	0.399	25.1	0.411	25.9														
120			0.733	11.0	0.719	10.8	0.741	11.1														
5	da - dn	50	0.816	10.8	0.800	10.6	0.824	10.9														
2			0.831	10.6	0.815	10.4	0.839	10.7														
190			0.758	24.4	0.743	23.9	0.765	24.6														
120			1.207	5.0	1.183	4.9	1.218	5.0														
5			1.266	4.6	1.241	4.5	1.278	4.6														
2		12.5	1.297	4.3	1.272	4.2	1.310	4.3														
P.D. Value as per IS 11322/1985 22.86 kV			2pC		2pC		2pC															

Tested By : Gajanan
Nevrekar.

Checked By: Vasant Shingate.

Date : 02-09-2021

Page 1 of 2

F/QI/030

THIS IS SYSTEM GENERATED COPY HENCE SIGNATURE IS NOT REQUIRED.

Serial Number --			21/601153		21/601154		21/601155																					
Vn (%)	Sec Wdg	Burden (VA)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)	R.E. (%)	P.E. (Min.)



Tested By : Gajanan
Nevrekar.
F/QI/030

Checked By: Vasant Shingate.

Date : 02-09-2021

THIS IS SYSTEM GENERATED COPY HENCE SIGNATURE IS NOT REQUIRED.



CERTIFICATE OF CONFIRMITY

Ref: TSPL/COC-3283-SR

This is to certify that the following items confirm to the technical specifications and functional requirements as per Drawings and found suitable for use in the final product mentioned against the same.

S.No.	Item Description	Make	Final product
1	L/R Switch	KAYCEE	33kV HT PANEL
2	(T/N/C Switch)	KAYCEE	
4	MCB	ABB	
5	Indication Lamps	TEKNIC	
6	Push Button	TEKNIC	
7	FERRULES / STICKERS	TSPL	
8	Terminal	Connectwell	
9	5 PIN SOCKET + SWITCHES	PRESSFIT	
10	3 Point lock - BREAKER DOOR	TSPL	
11	1 Point lock - METERING DOOR	TSPL	

For TECHNOCRAFTS SWITCHGEARS PVT. LTD.,





JSW STEEL LIMITED

Vijayanagar Works, PO- Vidyannagar, Village-Toranagalli, Dist: Bellary, Karnataka-582275, INDIA
Regd. Office: JSW Centre, Bandra Kurla Complex, Bandra (East), Mumbai - 400 051



TEST CERTIFICATE FOR COLD REDUCED LOW CARBON STEEL SHEET & STRIP

(According to EN 10204 Type 3.1)

Test Certificate : CRCA/20-21/0001820143

Date : 10.01.2021
SO No./Item : 401292631/20
Product : CRCA
PO No. : RETAIL PRIME

SC/861

It is certified that the material described below fully conforms to IS 513, PART1. Chemical composition and Mechanical properties of the product, as tested in accordance with the Scheme of Testing & Inspection contained in the BIS certification marks Licence No. CML - 3330339 are as indicated below against each order No. Etc.
(PLEASE REFER TO IS 513, PART1 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

TEST RESULTS


Specification: IS 513_PART1_2016 CR2																	QTY				
																	(MT)				
Heat No.	Coil No.	Nominal Size (MM)					C %	Mn %	S %	P %	Si %	Al %	N %	Y'S (MPa)	UTS (MPa)	GL (mm)	EL %	Hard (HRB)	Ra µm		
		T	X	W	X	L															
F044727	L110541000	2.000 X 1540.0 X Coil					0.1200	0.50	0.035	0.040	0.070	0.0070	0.40	370	240	370	50	31.00	0.70		
							0.0340	0.21	0.008	0.013	0.010	0.010	0.0030	221	338	50	45-30	50.0	1.13		
Total Weight in Metric Tonnes																	Grand Total of Coils/Pkts/Bundles/Slab			1	
L110540000																					

This is to certify that the above mentioned product produced & supplied by JSW Steel Ltd do not contain any radio active element higher than the natural level and it conforms to Standard Rolling, Dimensional & Weight tolerances. The product or packing material does not contain any hazardous substances as per RoHS norms.

Delivery ID : 709581344
Invoice No. : 7103268639
GST Invoice No : 20VJ2900396489
Mode of Transport : Rail
Vehicle No. :
C. No. :

Legends: Chemistry = Laddic Sample analysis, 1Mpa= 1N/mm²; T x W x L = Thickness x Width x Length
YS= Yield Strength; UTS = Ultimate Tensile Strength, %El = %gtg Flangulation on standard gauge length

Remarks :



L. G. Naik
L. G. NAIDU
Authorised Signatory
For JSW Steel Ltd.





JSW STEEL LIMITED

Vijayanagar Works, PO- Vidyanagar, Village-Toranagallu, Dist: Bellary, Karnataka-583275, INDIA
Regd. Office: JSW Centre, Bandra Kurla Complex, Bandra (East), Mumbai - 400 051

TEST CERTIFICATE FOR COLD REDUCED LOW CARBON STEEL SHEET & STRIP (According to EN 10204 Type 3.1)

IS 513_PART1



CM/L - 3330339

Test Certificate : CRCA/19-20/0001547666

Date : 26.02.2020

SO No./ Item : 401143822 / 30

Product : CRCA

PO No. : RETAIL PRIME

It is certified that the material described below fully conforms to IS 513_PART1. Chemical composition and Mechanical properties of the product, as tested in accordance with the Scheme of Testing & Inspection contained in the BIS certification marks Licence No. CM/L - 3330339 are as indicated below against each order No. Etc.

(PLEASE REFER TO IS 513_PART1 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

TEST RESULTS

J-1005

Specification: IS 513_PART1_2016 CR2			QTY (MT)	C %	Mn %	S %	P %	Si %	Al %	N %	YS (Mpa)	UTS (MPa)	GL (mm)	EL %	Hard (HRB)	Ra µm
Cast / Heat No.	Coil Number	Nominal Size (MM)	Min	0.020 50 31.00 0.70												
Mother Coil		T X W X L	Max	0.1200	0.50	0.035	0.040		0.070	0.0120	240	370				1.60
A427341 K203530000	202S40509	3 000 X 1250.0 X Coil	10.535	0.0370	0.17	0.008	0.018	0.015	0.049	0.0022	191	300	50	48.00	48.3	0.98
Total Weight in Metric Tonnes			10.535													
Grand Total of Coils/Pkt/Bundles/Slab			1													

This is to certify that the above mentioned product produced & supplied by JSW Steel Ltd do not contain any radio active element higher than the natural level and it confirms to Standard Rolling, Dimensional & Weight tolerances. The product or packing material does not contain any hazardous substances as per RoHS norms.

Delivery ID : 708516159	Legends: Chemistry = Laddle Sample analysis; 1Mpa= 1N/mm ² ; T x W x L = Thickness x Width x Length YS= Yield Strength; UTS = Ultimate Tensile Strength, %EL= %ge Elongation on standard gauge length	
Invoice No. : 7102613533		
GST Invoice No : 19VJ2900541476		
Mode of Transport: Normal Trailer		
Vehicle No. : KA51AE4827	Remarks :	

L. G. Naidu
(L. G. NAIDU)
Authorised Signatory
For JSW Steel Ltd.



JSW STEEL LIMITED

Vijayanagar Works, PO- Vidyanagar, Village-Toranagallu, Dist: Bellary, Karnataka-583275, INDIA
 Regd. Office: JSW Centre, Bandra Kurla Complex, Bandra (East), Mumbai - 400 051

TEST CERTIFICATE FOR COLD REDUCED LOW CARBON STEEL SHEET & STRIP

(According to EN 10204 Type 3.1)

IS 513_PART1



CM/L - 3330339

Test Certificate : CRCA/20-21/0001836249

Date : 25.01.2021
 SO No./ Item : 401300012 / 20
 Product : CRCA
 PO No. : RETAIL PRIME

It is certified that the material described below fully conforms to IS 513 PART1. Chemical composition and Mechanical properties of the product, as tested in accordance with the Scheme of Testing & Inspection contained in the BIS certification marks Licence No. CM/L - 3330339 are as indicated below against each order No. Etc.
 (PLEASE REFER TO IS 513_PART1 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

TEST RESULTS

Specification: IS 513_PART1_2016 CR2			QTY (MT)	C %	Mn %	S %	P %	Si %	Al %	N %	YS (Mpa)	UTS (MPa)	GL (mm)	EL%	Hard (HRB)	Ra μ m
Heat No.	Coil No.	Nominal Size (MM)	Min	0.020										50	31.00	0.70
Mother Coil		T X W X L	Max	0.1200	0.50	0.035	0.040		0.070	0.0120	240	370				1.60
E845698 L135020000	L135022000	2.500 X 1500.0 X Coil	13.265	0.0460	0.28	0.006	0.012	0.008	0.060	0.0023	204	315	50	48.00	47.4	1.29
Total Weight in Metric Tonnes			13.265	Grand Total of Coils/Pkt/Bundles/Slab							1					

This is to certify that the above mentioned product produced & supplied by JSW Steel Ltd do not contain any radio active element higher than the natural level and it confirms to Standard Rolling, Dimensional & Weight tolerances. The product or packing material does not contain any hazardous substances as per RoHS norms.

Delivery ID : 709635188
 Invoice No. : 7103304224
 GST Invoice No : 20VJ2900419677
 Mode of Transport : Rail
 Vehicle No. :
 LC No. :

Legends: Chemistry = Ladle Sample analysis; 1Mpa= 1N/mm²; T x W x L = Thickness x Width x Length
 YS= Yield Strength; UTS = Ultimate Tensile Strength, %EL= %ge Elongation on standard gauge length

Remarks :





L. G. Naidu
 (L. G. NAIDU)
 Authorised Signatory
 For JSW Steel Ltd.

T. C. No.:	Apt Controls & Appliances Pvt. Ltd.			
ST/21-22 0574	Plot No. 120, Shahpur Industrial Estate, Village Pundhe, Post Atgaon, Taluka Shahpur 421601, Dist. Thane, Maharashtra Tel: +91 251 2710161/2/3 URL: www.apl-controls.com Email: info@apl-controls.com			
Date				
11/07/2021	TEST CERTIFICATE (FOR PANEL THERMOSTAT)			
Product Specification	Thermostat, Mk II, 140 mm, 20 A, 230 V, 0- 75 °C with L-Bkt.			
Certificate issued to	Technocrafts Switchgears Pvt. Ltd..			
P.O. No. & Date	PO06210807 Dated 7-Jun-2021 PO05210374 Dated 6-May-2021 PO07211145 dated 5-Jul-2021			
Customer's Item No	---			
Tax Invoice No. & Date	APT/0385/21-22 Dated 11/07/2021			
Quantity	75 Nos			
Test Details				
Sr. no.	Description	Requirement	Test Method	Result
1	Visual Inspection	Surface finish, marking & dimensions	Visual check	Passed
2	Operating temperature (Contact opening temperature)	Must be within set value $\pm 8^{\circ}\text{C}$	IS: 3017 Cl. 103.1	Passed
3	Differential temperature	Must not exceed 13°C	IS: 3017 Cl. 103.1	Passed
4	Insulation Level	Must withstand 2kV for 1 min.	IS: 302 Cl. 13.3	Passed
Tested by	<i>Shradha</i>	Approved by	<i>[Signature]</i>	



T. C. No.:	Apt Controls & Appliances Pvt. Ltd. Plot No. 120, Shahpur Industrial Estate, Village Pundhe, Post Atgaon, Taluka Shahpur 421601, Dist. Thane, Maharashtra Tel: +91 251 2710161/2/3 URL: www.apr-controls.com Email: info@apr-controls.com			
PSH/21-22 0573				
Date				
10/07/2021	TEST CERTIFICATE (FOR PANEL SPACE HEATER)			
Product Specification		Panel Space Heater, Mk II A, 100 W, 240 V, BE.		
Certificate issued to		Technocrafts Switchgears Pvt. Ltd..		
P.O. No. & Date		PO05210671 Dated 31-May-2021		
Customer's Item No		---		
Tax Invoice No. & Date		APT/0380/21-22 Dated 10/07/2021		
Quantity		50 Nos.		
Test Details				
Sr. no.	Description	Requirement	Test Method	Result
1	Visual Inspection	Surface finish, marking & dimensions	Visual check	Passed
2	Input at rated voltage	Must be within $\pm 5\%$ of rated Wattage	IS: 302 Cl.10.1	Passed
3	Leakage Current	Must not exceed 210 μ Amps	IS: 302 Cl.13.2	Passed
4	Insulation Level	Must withstand 2kV for 1 min.	IS: 302 Cl. 13.3	Passed
Tested by	<i>Shradha</i>	Approved by	<i>Sujit</i>	



T. C. No.:	Apt Controls & Appliances Pvt. Ltd. Plot No. 120, Shahpur Industrial Estate, Village Pundhe, Post Atgaon, Taluka Shahpur 421601, Dist. Thane, Maharashtra Tel: +91 251 2710161/2/3 URL: www.apr-controls.com Email: info@apr-controls.com			
PSH/21-22 0580				
Date				
11/07/2021	TEST CERTIFICATE (FOR PANEL SPACE HEATER)			
Product Specification		Panel Space Heater, Mk II A, 200 W, 240 V, BE.		
Certificate issued to		Technocrafts Switchgears Pvt. Ltd..		
P.O. No. & Date		PO06210807 Dated 7-Jun-2021 PO05210374 Dated 6-May-2021 PO07211145 Dated 5-Jul-2021		
Customer's Item No		---		
Tax Invoice No. & Date		APT/0385/21-22 Dated 11/07/2021		
Quantity		46 Nos.		
Test Details				
Sr. no.	Description	Requirement	Test Method	Result
1	Visual Inspection	Surface finish, marking & dimensions	Visual check	Passed
2	Input at rated voltage	Must be within $\pm 5\%$ of rated Wattage	IS: 302 Cl.10.1	Passed
3	Leakage Current	Must not exceed 210 μ Amps	IS: 302 Cl.13.2	Passed
4	Insulation Level	Must withstand 2kV for 1 min.	IS: 302 Cl. 13.3	Passed
Tested by		Approved by		



POLYCAB INDIA LIMITED

TYPE TEST CERTIFICATE

CUSTOMER :-

INVOICE NO :-

SIZE: 1 CORE X 1.5 SQ. MM

TYPE :Y (FR-LSH)

DATE: 10.07.2020

COIL LENGTH: 100 Mtrs.

Voltage Grade:- 1100 VOLTS

DESCRIPTION:- Polycab make 1100V, Flexible copper conductor, Type "D" FR-LSH PVC insulated single core unsheathed cable.

SR. NO.	DESCRIPTION	UNITS	REQUIREMENTS	OBSERVATIONS	
1	CONDUCTOR				
a.	Resistance at 20°C	Ohm/Km	Max.13.30	13.248	
b.	Annealing Test for Cu.*	%	Min: 13.5	21	
2	INSULATION				
2.1	Thickness				
a.	Minimum	mm	Min. 0.44	0.55	
b.	Average	mm	Min. 0.60	0.63	
2.2	Without Ageing.				
a.	Tensile Strength	N/Sq.mm	Min.10.0	14.83	
b.	Elongation at break	%	Min.150	235	
2.3	After Ageing in air oven.** (70 ± 2° C for 168 Hrs.)				
a.	Tensile Strength	N/Sq.mm	Min.10.0	15.33	
b.	Variation in T.S.	%	Max. + 20	-3.37	
c.	Elongation at break	%	Min.150	227	
d.	Variation in Elong.	%	Max. + 20	3.40	
2.4	Loss of mass test ** (80 ± 2°C for 168 Hours)	Mg/Cm ²	Max. 2	0.17	
2.5	Shrinkage Test. (150 ± 2°C for 15 Min.)	%	Max. 6	1.00	
2.6	Heat Shock Test. (150 ± 2°C for 1 Hour)	-	No Sign's of cracks or scales	PASS	
2.7	Hot Deformation Test. (80 ± 2°C for 4 Hours) Depth of Indentation	%	Max.65	14.49	
2.8	Thermal stability test (200 ± 0.5°C)	Minutes	Min. 80	106	
2.9	Cold bend test (for OD<12.5 mm) (- 15°C for 2 Hours)	-	No Signs of cracks or scales	PASS	
2.10	Volume Resistivity				
a.	At 27°C	Ohm-cm	Min.1 X 10 ¹²	6.94	X 10 ¹³
b.	At 70°C	Ohm-cm	Min.1 X 10 ⁹	15.84	X 10 ¹⁰
2.11	Insulation Resistance Constant				
a.	At 27°C	MΩ-km	Min. 3.67	256	
b.	At 70°C	MΩ-km	Min. 0.004	0.638	
3.0	High Voltage Test (3 Kv AC for 5 Minutes/On line spark Testing)	kV	Break down should not occur		
3.1	High Voltage Test ** Water Immersion A.C. Followed by D.C		6. kV AC For 5 Minutes 1.2 kV D.C. for 240 Hours	WITHSTOOD	
4.0	Flammability Test	Seconds	Period of burning after removal of flame:Max. 60 seconds	1	
		mm	Unaffected length Min.50 mm.	354	
5.0	Overall Diameter (OD)	mm	Approx. 2.67	2.78	
6.0	ADDITIONAL TEST - FR-LSH PVC				
a.	Oxygen index test-ASTMD2863-77	%	Min. 29	30.5	
b.	Temperature Index-ASTMD2863	°C	Min.250	356	
c.	Smoke density test -ASTMD2843	%	Max.60	53.61	
d.	HCL Gas Emission IEC-754-1	%	Max.20	13.71	
e.	Swedish Chimney SS 424 1475F3	mm	Unaffected length from the top 300 mm	491	

Note: The Cable has been tested for above tests and found meeting the requirements , as per IS 694-2010.

*Before stranding / **Batch Test.

Tested By:




Approved By:






POLYCAB INDIA LIMITED TYPE TEST CERTIFICATE

CUSTOMER :-

INVOICE NO :-

SIZE: 1 CORE X 2.5 SQ. MM

TYPE :Y (FR-LSH)

DATE: 14.07.2020

COIL LENGTH: 100 Mtrs.

Voltage Grade:- 1100 VOLTS

DESCRIPTION:- Polycab make 1100V, Flexible copper conductor, Type "D" FR-LSH PVC insulated single core unsheathed cable.

SR. NO.	DESCRIPTION	UNITS	REQUIREMENTS	OBSERVATIONS
1	CONDUCTOR			
a.	Resistance at 20°C	Ohm/Km	Max.7.98	7.917
b.	Annealing Test for Cu.*	%	Min: 13.5	22
2	INSULATION			
2.1	Thickness			
a.	Minimum	mm	Min. 0.53	0.63
b.	Average	mm	Min. 0.70	0.76
2.2	Without Ageing.			
a.	Tensile Strength	N/Sq.mm	Min.10.0	14.84
b.	Elongation at break	%	Min.150	246
2.3	After Ageing in air oven.** (70 ± 2° C for 168 Hrs.)			
a.	Tensile Strength	N/Sq.mm	Min.10.0	15.36
b.	Variation in T.S.	%	Max. + 20	-3.50
c.	Elongation at break	%	Min.150	235
d.	Variation in Elong.	%	Max. + 20	4.47
2.4	Loss of mass test ** (80 ± 2°C for 168 Hours)	Mg/Cm ²	Max. 2	0.24
2.5	Shrinkage Test. (150 ± 2°C for 15 Min.)	%	Max. 6	1.26
2.6	Heat Shock Test. (150 ± 2°C for 1 Hour)	-	No Sign's of cracks or scales	PASS
2.7	Hot Deformation Test. (80 ± 2°C for 4 Hours) Depth of Indentation	%	Max.65	19.73
2.8	Thermal stability test (200 ± 0.5°C)	Minutes	Min. 80	116
2.9	Cold bend test (for OD<12.5 mm) (- 15°C for 2 Hours)	-	No Signs of cracks or scales	PASS
2.10	Volume Resistivity			
a.	At 27°C	Ohm-cm	Min.1 X 10 ¹²	8.67 X 10 ¹³
b.	At 70°C	Ohm-cm	Min.1 X 10 ⁹	23.87 X 10 ¹⁰
2.11	Insulation Resistance Constant			
a.	At 27°C	MΩ-km	Min. 3.67	271
b.	At 70°C	MΩ-km	Min. 0.004	0.638
3.0	High Voltage Test (3 Kv AC for 5 Minutes/On line spark Testing)	kV	Break down should not occur	WITHSTOOD
3.1	High Voltage Test ** Water Immersion A.C. Followed by D.C		6. kV AC For 5 Minutes 1.2 kV D.C. for 240 Hours	WITHSTOOD
4.0	Flammability Test	Seconds	Period of burning after removal of flame:Max. 60 seconds	1
		mm	Unaffected length Min.50 mm.	352
5.0	Overall Diameter (OD)	mm	Approx. 3.3	3.39
6.0	ADDITIONAL TEST - FR-LSH PVC			
a.	Oxygen index test-ASTMD2863-77	%	Min. 29.0	30.5
b.	Temperature Index-ASTMD2863	°C	Min.250	356
c.	Smoke density test -ASTMD2843	%	Max.60	51.76
d.	HCL Gas Emission IEC-754-1	%	Max.20	12.61
e.	Swedish Chimney SS 424 1475F3	mm	Unaffected length from the top 300 mm	492

Note: The Cable has been tested for above tests and found meeting the requirements , as per IS 694-2010.

*Before stranding / **Batch Test.

Tested By:



Approved By:



**BANCO ALUMINIUM LIMITED**

BIL NR.BHAILI RAILWAY STATION,,PADRA ROAD, DIST

VADODARA, Gujarat (IN), India

Phone : +91 265 2477200 Fax : +91 265 2477462

Email : sales@bancoaluminium.com Website: http://www.bancoaluminium.com

TEST CERTIFICATE FOR EXTRUSION

CUSTOMER	Technocrafts Switchgears Private Limited	TC NO	TCE/21908
ORDER NO	PO06210993B	DATE	17/07/2021
ORDER DATE	30-06-2021	INVOICE NO	2102833
ORDER QUANTITY	135.0	INVOICE DATE	17/07/2021
ALLOY & TEMPER	63401 & WP R1		

S.NO	DRAWING NO / SECTION NO	LENGTH IN MM	QUANTITY.PACKED PCS(KG)
1	FBR-2006170 2006170 Flat Bar 50 X 10 R5	3,660 MM	24 PCS 116.60 KGS

CHEMICAL COMPOSITION(PERCENTAGE)

CAST NO	DESCRIPTION	Si	Mg	Fe	Mn	Cu	Zn	Cr	Ti	Al
8400	Required Values	0.300	0.400	0.000	0.000	0.000	0.000	0.000	0.000	Rem
		0.700	0.900	0.500	0.030	0.050	0.100	0.030	0.100	
	Actual Values	0.427	0.487	0.176	0.012	0.003	0.002	0.002	0.016	98.860

MECHANICAL PROPERTIES

CAST NO	DESCRIPTION	U.T.S(KG/MM2)	% ELONGATION IN 2 INCH	0.2% YIELD STRENGTH(KG/MM2)
8400	Required Values	17.340	12.000	13.770
		0.000		0.000
	Actual Values	18.3	19.1	15.45

DIMENSIONAL INSPECTION :

OTHER TEST IF ANY :

IDENTIFICATION OF EXTRUSION :

We hereby certify that items mentioned above have been tested and inspected in our presence and are found to be in accordance with the drawing specification and purchase order.

REMARKS : AS PER IS-5082

Actual Conductivity= 56.50 %IACS



AUTHORISED SIGNATURE (QAD)



SUDAL INDUSTRIES LTD.
A-5, MIDC, AMBAD, NASHIK-422010

TEST CERTIFICATE

Q - 14

SERIAL NO : 5463 DATE : 24/01/2021
INVOICE NO : SILG 202114453 DATE : 24/01/2021
PARTY NAME : TECHNOCRAFTS SWITCHGEAR PVT LTD
ORDER NO : PO12202373 ORDER DATE : 11/12/2020
STANDARD : IS5082:1998
SECTION NO : F60038 SIZE : AL FLAT 40.0 X 10.0 MM A/T : 6101 T6E91



QUANTITY

NO. OF PCS. : 448
QTY IN KGS : 1643.0
CUT LENGTH : 3660 MM

CHEMICAL COMPOSITION IN %

Si	Fe	Mn	Mg	Cu	Ti	Zn	Cr	Al
0.486	0.269	0.015	0.553	0.045	0.0089	0.034	0.012	REMAINDER

REQUIRED :

0.3-0.7 0.50 MAX 0.03 MAX 0.4-0.9 0.05 MAX 0.10 MAX 0.10 MAX 0.03 MAX REMAINDER

MECHANICAL & ELECTRICAL PROPERTIES

UTS Kg/mm ²	0.2%P.S. Kg/mm ²	% ELONG	CONDUCTIVITY	HARDNESS
24.727	22.349	15.42	57.8	56,57,58 BHN

REQUIRED :

20.40 MIN 17.34 MIN 10 % MIN 55 % IACS MI 55 BHN MIN

REMARKS : CAST NO. A55



FOR, SUDAL INDUSTRIES LTD.

This Certificate is computer generated no Signature required.

CIN NO : L21541MH1979PLC021541



S.D. Shobh

PREPARED BY

QUALITY ASSURANCE ENGINEER

QUALITY ASSURANCE MANAGER





BHARAT INDUSTRIES

MFG. BRASS & COPPER BUSBAR/ SHEETS OF ALL GRADE

Plot no 46, Ramtekadi Industrial Estate, Hadapsar, Pune - 411013

Ph. Telefax: (020) 26811119

bharatindustries00@ymail.com

MATERIAL TEST CERTIFICATE

Customer Name	Technocrafts Switchgears (P) Ltd BHIWANDI	TC NO	T/720/ 20/21	DATED	04.12.2020
		INVOICE NO	720	DATED	04.12.2020
		PO NO	8200932/1019	DATED	25.08.2020 28.08.2020
		QUANTITY	610.400 KGS	NOS	15 BDLS
		BATCH NO	12/11/EC/1219/1/	DATED	12.11.2020

SPECIFICATION: - ETP GRADE COPPER IS: 191 PART V

Material Description: COPPER ROD / BUSBAR/ SQUARE

Temper: Half Hard in Straight Length

A) Chemical Composition :-

Elements	Cu	Pb	Bi	Others	Remark
Specified	99.90 min	0.005 max	0.001 max	0.03 max	OK
Observed	99.97	0.003	0.001	0.026	OK

B) Dimensional Report :

Dimension ->	20X3		30X6		NA	
Parameters	Specified	Observed	Specified	Observed	Specified	Observed
Width	20.00	19.97	30.00	29.93	NA	NA
Thickness	3.00	2.97	6.00	6.01	NA	NA
Radius	R1	R1	FR	FR	NA	NA

C) Mechanical Properties:-

Parameter	Specified	Observed	Specified	Observed	Specified	Observed
Hardness	70 - 90 HV	88.10	70 - 90 HV	89.80	70 - 90 HV	NA
Bend Test	OK	OK	OK	OK	OK	NA

D) Electrical Properties :-

Parameter	Specified	Observed	Remark
Conductivity in % IACS	97 min	98.8 - 99.3 %	OK
Visual Remark	OK		
Checked By :- R GAJENDRA			
Authorised Signatory			



B-34, Nand Bhavan Industrial Estate,
Mahakali Caves Road, Andheri (East),
Mumbai - 400 093. INDIA
Email : pristine.engg@gmail.com
info@pristineengg.in
Tel.: 022 28398848/49/50
CIN No. : U51521MH2011PTC219234



Pristine

ENGG SERVICES PVT. LTD.
SOLUTION IN ELECTRICAL ENGG.
TRANSFORMER • CABLE JTG. KITS • ACCESSORIES
• MV/HVDC SWITCHGEAR • CROMPTON OLTC

Hongshang

QUALITY CERTIFICATE OF HEAT SHRINKABLE TUBING

Product Name: HBTM		Quantity: 255		
Product Size: $\Phi 50.0/20.0$		LOT No: 186471/210		
Colour: Red		Customer: Technocrafts Switchgears (P) Ltd.		
Item		Standard Value	Check Value	Check result
AS Supplied	ID(mm)	≥ 50.0	51.90	PASS
	Eccentricity(%)	≤ 30	20	PASS
After Shrinking	ID(mm)	≤ 20.0	19.95	PASS
	Wall thickness(mm)	≥ 2.5	2.8	PASS
L/C(%)		$\pm 10\%$	-0.4	PASS
Tensile strength(Mpa)		≥ 11.0	12.0	PASS
Ultimate Elongation(%)		≥ 200	650	PASS
Minimum Shrink Temperature		110°C	110°C	PASS
Appearance		No defects	No defects	PASS
Color		Homogenous	Homogenous	PASS

QC		Checked by
		

Date: 11.11.2020



**BARODA BUSHINGS & INSULATORS LLP****"EPOXY HOUSE", 746/1-2, G.I.D.C. Estate, Makarpura Road, Vadodara - 390 010.**
WORKS : A-2/628-629 G.I.D.C. Estate, Makarpura Road, Vadodara - 390 010.

Phone : (0265) 2642879/2641083

Fax : (0265) 2640821

E-mail : bbi@epoxyhouse.com

Web : www.epoxyhouse.com

T.C. NO. : BBI/TC/DA/21-22/01425

DATE : 12/06/2021

TEST CERTIFICATE

CUSTOMER NAME : M/s. TECHNOCRAFT SWITCHGEAR PRIVATE LIMITED

ITEM DESCRIPTION : 36 kV EPOXY INSULATOR WITH BRASS INSERT

DRAWING NO. : EPI : B4 : 578 , REV. : 01

PURCHASE ORDER NO. : PO05210681, DATE : 31/05/2021

QUANTITY SUPPLIED : 34 Nos.

OUR CHALLAN NO. : DA/21-22/01425, DATE : 12/06/2021

TESTS : AS PER IS 9431 - 1979 & SPECIFICATION MENTIONED IN DRAWING.

Sr. No.	Description of Tests Carried Out	Qty. Tested	Required Value	Observed Value	Instruments Used For the Tests
1)	Dry Power Frequency Voltage Withstand Test	34 Nos.	95 kV for one minute	Withstood	HV Tester
2)	Cantilever Withstand Load Test	01 Nos.	800 Kgs	Withstood upto 930Kgs	UTM
3)	Tensile Withstand Load Test	01 Nos.	5000 Kgs	Withstood upto 5320Kgs	UTM
4)	Creepage Distance	01 Nos.	1150 mm	1232 mm	By Cello Tape & Ruler scale
5)	Dimensional checking	02 Nos.	As per Drawing	Dimensions found within tolerances as per drg.	By Vernier Caliper & Height Gauge.
6)	Visual Inspection / Surface Finish	34 Nos.	Insulator should be free from Cracks, Pin holes, Blow holes, Moulding defects etc. Surface finish should be smooth.	No cracks, Pin holes, Blow holes & other moulding defects observed on the surface of insulators.	Visual

NOTE : We Guarantee the performance of the items as per above details for a period of 18 Months from date of despatch or 12 Months from the date of commissioning whichever is earlier and if any defect is noticed during this period we agree to give free replacement.

TESTED BY

DIMPLE PUWAR

APPROVED BY

HARISH MACHHI





**PRESSGEL INSULATIONS
PRIVATE LIMITED.**

System Manual Level - II (Q.C.I function)
FINISH PRODUCT TEST REPORT

Doc.No.:	Q.C.D./F/02/01
Rev.No.:	01
Effe. Date:	01/02/2005
Page No.:	01 OF 01

Customer Name: TECHNOCRAFTS SWITCHGEARS PVT.LTD,
Purchase Order No.: PO 06210847 dtd.09-jun-21
Description: 33KV EPOXY INSULATOR WITH MS INSERT SIZE: 70X300 PG 02
MGP NO. 139 Date: 25-06-2021 Inv.No.: 139 Qty.: 152 NOS

Sr No.	Parameters to be checked	Required	Observed	Remarks
1	Dimensions			
	Height	300 MM	300.07 MM	OK
	Diameter	70MM	70.03 MM	OK
2	Creepage Distance	410 MM	411MM	OK
3	H.V.Test	72 KV/1 MIN	100%	OK
4	Flashover voltage test	90 KV	obtained >90kv	OK
5	Cantilever Test /Tengential Load with Stand	850 KG	961KGF	OK
6	Tensile Failing Test	—	4840KGF	OK
7	Compression Failing Test	—	—	—
8	Partial Discharge Test	—	—	—
9	Insert Threding	—	—	—
10	Rated Voltage	M10,M8,M16	CHECKING	OK
11	Physical Apperance	33 KV	100%	OK
12	Finishing	100%	Satisfaction	OK
Approved/Rejected		Visually Good	Visually Good	OK

Inspected by:

Date: 25-06-2021

Approved by:

Note: We guarantee the performance of the items as per above details for a period of 12 months from the date of despatch or 18 months from the date of commissioning whichever is earlier if any defect is noticed during this period we agree to effect free replacement.

For PressGel Insulations Private Limited

AUTHORISED SIGNATURE





**PRESSGEL INSULATIONS
PRIVATE LIMITED.**

System Manual Level - II (Q.C.I function)
FINISH PRODUCT TEST REPORT

Doc.No.:	Q.C.D./F/02/01
Rev.No.:	01
Effe. Date:	01/02/2005
Page No.:	01 OF 01

Customer Name: TECHNOCRAFTS SWITCHGEARS PVT.LTD,
Purchase Order No.: PO 0121643, 4/1/21, PO 12202545, 30/12/20
Description: 33 KV POLY INSULATOR WITH MS INSERT SIZE OF INSU. (100x300) PG 028
Challan No.: 535 Date: 07-01-21 Inv.No.: 535 Qty.: 96 NOS

No.	Parameters to be checked		Required	Observed	Remarks
1	Dimensions	Height	300 MM	300.11 MM	OK
		Diameter	100 MM	100.07 MM	OK
2	Creepage Distance		490 MM	490MM	OK
3	H.V.Test		72 KV/1 MIN	100%	OK
4	Impulse withstand Voltage		—	—	—
5	Cantilever Test /Tengential Load with Stand		1000 KGF	1020 KGF	OK
6	Tensile Failing Test		—	—	—
7	Compression Failing Test		—	—	—
8	Partial Discharge Test		—	—	—
9	Insert Threding Brass insert		M16,M10,M20	CHECKING	OK
10	Rated Voltage		33 KV	100%	OK
11	Physical Apperance		100%	Satisfaction	OK
12	Pressure Test		—	—	—
13	Finishing		Visually Good	Visually Good	OK

Approved/Rejected

ected by:

Date: 07-01-21

Approved by:

Note: We guarantee the performance of the items as per above details for a period of 12 months from the date of despatch or 18 months from the date of commissioning whichever is earlier if any defect is noticed during this period we agree to effect free replacement.

For PressGel Insulations Private Limited

AUTHORISED SIGNATURE



Certificate of Analysis

Certificate Type:

Insp. certificate "3.1" EN

10204

Date printed: DEC/03/2020



Pranav Engineering Works
Sandhya Praveen Burkule
L-5, MIDC, Amabad
Maharashtra
422010
NASHIK
India

Shipped from details:

SABIC INNOVATIVE PLASTICS INDIA
PRIVATE LIMITED
Plastics Avenue
391320
VADODARA
India

Material Number	22050075
Material Description	SP-8230-2.800-1220.0-2440-000
Material Group	CARBORON™ sheet
Batch Number	0015743378
Manufacturing Plant	Vadodara
Manufacturing Date	NOV/02/2020
Sales Order	3513286
Delivery	803210701
Customer PO Number	PEW-041120-05

Characteristic	Unit	Value	Lower Limit	Upper Limit	Inspection method
GAUGE IN MM	mm	2.721 ✓	2.660	2.940	SABIC
TRANSMITTANCE	%	29.20 ✓	27.00	33.00	ASTM D1003

It is hereby stated that the material above has been found in accordance with the conditions and requirements of our standard/agreed quality specification.

General Note : This document is computer generated and does not require a signature. SABIC documents the authorized representatives and their independence necessary to release its products, according to the regulatory requirements. Contact information can be found on www.SABIC.com.

DISCLAIMER: THE MATERIALS, PRODUCTS AND SERVICES OF SAUDI BASIC INDUSTRIES CORPORATION (SABIC) OR ITS SUBSIDIARIES OR AFFILIATES ("SELLER") ARE SOLD SUBJECT TO SELLER'S STANDARD CONDITIONS OF SALE, WHICH ARE AVAILABLE UPON REQUEST. INFORMATION AND RECOMMENDATIONS CONTAINED IN THIS DOCUMENT ARE GIVEN IN GOOD FAITH. HOWEVER, SELLER MAKES NO EXPRESS OR IMPLIED REPRESENTATION, WARRANTY OR GUARANTEE (i) THAT ANY RESULTS DESCRIBED IN THIS DOCUMENT WILL BE OBTAINED UNDER END-USE CONDITIONS, OR (ii) AS TO THE EFFECTIVENESS OR SAFETY OF ANY DESIGN OR APPLICATION INCORPORATING SELLER'S MATERIALS, PRODUCTS, SERVICES OR RECOMMENDATIONS. UNLESS OTHERWISE PROVIDED IN SELLER'S STANDARD CONDITIONS OF SALE, SELLER SHALL NOT BE RESPONSIBLE FOR ANY LOSS RESULTING FROM ANY USE OF ITS MATERIALS, PRODUCTS, SERVICES OR RECOMMENDATIONS DESCRIBED IN THIS DOCUMENT. Each user is responsible for making its own determination as to the suitability of Seller's materials, products, services or recommendations for the user's particular use through appropriate end-use and other testing and analysis. Nothing in any document or oral statement shall be deemed to alter or waive any provision of Seller's Standard Conditions of Sale or this Disclaimer, unless it is specifically agreed to in a writing signed by Seller. Statements by Seller concerning a possible use of any material, product, service or design do not, are not intended to, and should not be construed to grant any license under any patent or other intellectual property right of Seller or as a



PRODUCT DATASHEET

LEXAN™ 9034 + 903xxx SHEET

DESCRIPTION

LEXAN™ 9034 based polycarbonate sheet is the standard grade of LEXAN sheet. Inherently high impact LEXAN 9034 sheet is an excellent candidate for glazing for economical protection against breakage or intrusion. As LEXAN has better insulation properties than glass it may contribute to lower energy costs. LEXAN 9034 sheet may be thermoformed, pressure formed, cold-formed or used in flat applications.

Applicable to:

- 9034* (applicable for all other uncoated LEXAN grades designated with 903xxx nomenclature)
- 9034V – with improved UL rating
- 9034HO – with improved optical specifications
- 90316, 90317 and 90318 – "Protect-A-Glaze" with one side textured

PRODUCT AVAILABILITY

Property	Test Method	Units	Value 9034 *	9034V	9034HO
Physical					
Specific Gravity	ASTM D792	-	1.20	1.20	1.20
Refractive Index @ 77°F	ASTM D542A	-	1.586	1.586	1.586
Light Transmission (Average at 0.118")	ASTM D1003	%	86	86	86
Initial Haze		HU	<1	<1	<1
Rockwell Hardness (M scale)	ASTM D785	-	70	70	70
Rockwell Hardness (R scale)	ASTM D785		118	118	118
Taber @ 100 cycles	ASTM D1044				
	(ANSI Z126.1)	% haze	10	10	10
Water Absorption, 24 hrs	ASTM D570	%	0.15	0.15	0.15
Water Absorption, Equilibrium	@ 73°F	%	0.35	0.35	0.35
Mechanical					
Tensile Strength, Yield	ASTM D638	psi	9,500	9,500	9,500
Tensile Modulus	ASTM D638	psi	345,000	345,000	345,000
Flexural Strength	ASTM D790	psi	13,500	13,500	13,500
Flexural Modulus	ASTM D790	psi	345,000	345,000	345,000
Compressive Strength	ASTM D695	psi	12,500	12,500	12,500
Compressive Modulus	ASTM D695	psi	345,000	345,000	345,000
Poisson's Ratio	ASTM E132	-	0.37	0.37	0.37
Izod Impact Strength Notched @ 0.118"	ASTM D256A	ft-lbs/in	12-16	12-16	12-16
Unnotched @ 0.118"			60	60	60
			(no failure)	(no failure)	(no failure)
Shear Strength @ Yield	ASTM D732	psi	6,000	6,000	6,000
Shear Modulus	ASTM D732	psi	114,000	114,000	114,000
Thermal					
Coefficient of Thermal Expansion	ASTM D696	in/in/°F	3.75 x10 ⁻⁵	3.75 x10 ⁻⁵	3.75 x10 ⁻⁵
Coefficient of Thermal Conductivity	ASTM C177	Btu•in/hr•ft²•°F	1.35		1.35
Specific Heat @ 40°C	ASTM C351	BTU/lb•°F	0.30		0.30
Heat Deflection Temperature @ 264 psi	ASTM D648	°F	270	266	270
@ 66 psi			280		280
Brittle Temperature (on resin)	ASTM D746	°F	-211	-211	-211
Flammability					
Horizontal Burn (Flame Spread) AEB	ASTM D635	in	<1		<1
Ignition Temperature, Self		°F	>1000	>1000	>1000
UL Flammability (File # 121562) Add link to the UL site	UL94HB	Pass/Fail		>0.236Y	
	UL94VO	Pass/Fail		>0.059Y	



PRODUCT DATASHEET

LEXAN™ 9034 + 903xxx SHEET


Electrical

Dielectric Constant @ 60 Hz	ASTM D150	—	3.17
Volume Resistivity	ASTM D257	Ohm-cm	8.2 x 10 ¹⁶
Dissipation Factor (@60 Hz) also known as Power Factor	ASTM D150		0.0009

◆ These typical values are not intended for specification purposes. If minimum certifiable properties are required please contact your local SABIC Innovative Plastics' representative.

™ Trademark of SABIC.

IMPACT RESISTANCE¶



¶) Drop Dart Test with a 5-lb steel dart and a 1" diameter tip.

CHEMICAL RESISTANCE

LEXAN 9034 sheet has sufficient resistance to most mineral oils, greases, aliphatic hydrocarbons and acids under low or moderate stress levels. Specific (application related) testing is always advised, especially in applications where the LEXAN 9034 sheet will come into contact with aggressive chemicals.

PROCESSING

LEXAN 9034 sheet can be used for thermoforming. It offers high, deep draw ratios, equal wall thickness distribution, and it can be formed into complex shapes using standard thermoforming equipment. Sandwich type heating systems give the best results. LEXAN 9034 sheet has a forming temperature range of 350–400°F. When forming, a draft angle of at least 3° should be allowed, and post mold shrinkage of .007–.009 in/in taken into account.

PRE-DRYING

It is important to ensure that LEXAN 9034 sheet is free of moisture prior to thermoforming. A hot air circulating oven set at 250°F is recommended. Pre-drying times vary from 3–24 hours, depending on sheet thickness.

ASSEMBLING / PAINTING

Parts made from LEXAN 9034 sheet can be assembled with plastics, metals, rubber and other materials using many types of adhesive bonding, welding and mechanical fastening techniques. Since some of these materials can cause environmental stress cracking, please consult SABIC Innovative Plastics, for advice on specific applications. A list of approved paint systems and suppliers is available upon request.





PRODUCT DATASHEET

LEXAN™ 9034 + 903xxx SHEET

CODE COMPLIANCE
Underwriters Laboratories

LEXAN 903x Sheet is listed as a Burglary-Resisting Glazing Material according to UL Standard 972.

UL File Number: E121562

Americas Headquarters

SABIC Innovative Plastics
One Plastics Avenue
Pittsfield, MA 01201
USA
T +1-413-448-7125
Toll-free: 1-800-323-3783
F +1 (888) 443-2033
sfs.customerservice@sabic-ip.com

European Headquarters

SABIC Innovative Plastics
Plasticslaan 1
4612 PX
Bergen op Zoom
The Netherlands
T +31 164 293684
F +31 164 293272
Sfs.info@sabic-ip.com

Pacific Headquarters

SABIC Innovative Plastics
Specialty Film & Sheet
1266 Nanjing Road (W)
16th Floor, Plaza 66
200040 Shanghai
China
T +86 21 62881088 ext. 6733
F +86 21 6288 0618

E-mail

sfs.customerservice@sabic-ip.com

Lexan* Tough
Polycarbonate Sheet Virtually
Unbreakable

* Trademark of SABIC Innovative Plastics, IP Co.

THE MATERIALS, PRODUCTS AND SERVICES OF SABIC INNOVATIVE PLASTICS HOLDING BV, ITS SUBSIDIARIES AND AFFILIATES ("SELLER"), ARE SOLD SUBJECT TO SELLER'S STANDARD CONDITIONS OF SALE, WHICH CAN BE FOUND AT <http://www.sabic-ip.com> AND ARE AVAILABLE UPON REQUEST. ALTHOUGH ANY INFORMATION OR RECOMMENDATION CONTAINED HEREIN IS GIVEN IN GOOD FAITH, SELLER MAKES NO WARRANTY OR GUARANTEE, EXPRESS OR IMPLIED, (i) THAT THE RESULTS DESCRIBED HEREIN WILL BE OBTAINED UNDER END-USE CONDITIONS, OR (ii) AS TO THE EFFECTIVENESS OR SAFETY OF ANY DESIGN INCORPORATING SELLER'S PRODUCTS, SERVICES OR RECOMMENDATIONS. EXCEPT AS PROVIDED IN SELLER'S STANDARD CONDITIONS OF SALE, SELLER SHALL NOT BE RESPONSIBLE FOR ANY LOSS RESULTING FROM ANY USE OF ITS PRODUCTS OR SERVICES DESCRIBED HEREIN. Each user is responsible for making its own determination as to the suitability of Seller's products, services or recommendations for the user's particular use through appropriate end-use testing and analysis. Nothing in any document or oral statement shall be deemed to alter or waive any provision of Seller's Standard Conditions of Sale or this Disclaimer, unless it is specifically agreed to in a writing signed by Seller. No statement by Seller concerning a possible use of any product, service or design is intended, or should be construed, to grant any license under any patent or other intellectual property right of Seller or as a recommendation for the use of such product, service or design in a manner that infringes any patent or other intellectual property right.

SABIC Innovative Plastics is a trademark of SABIC Holding Europe BV

™ Trademark of SABIC.

sabic-ip.com/sfs





ARIHANT Arihant panelfittings private limited

Date: -20/02/2021

Customer name: -Technocraft

Invoice number: -2021/04903

Invoice quantity: 500 mtr

TEST REPORT

Product Name		Clip-On Gasket EPDM Top bulb-FD 9925		
Material		EPDM		
Subject		Product Performance Test		
EPDM SPONGE				
Sr. No.	Characteristics checked	Standard Followed	Technical Spec. Specification	Technical Spec. Observed
1	Material		EPDM	EPDM
2	Specific Gravity	ISO 2781	0.65 ±0.05	0.66
3	Ozone Resistant's 50 PPHM/40 Degree/2% Strain/ 72 Hrs.	ASTM D- 1149	No Crack	No Crack
EPDM SOLID				
1	Material		EPDM	EPDM
2	Hardness (Shore A)	ASTM D- 2240	75 ± 5	70
3	Tensile Strength (Kg/Cm2)	ASTM D- 412	70 Minimum	102.12
4	Elongation @ Break %	ASTM D- 412	250 Minimum	480
5	Heat Ageing Test 70 Degree/70 Hrs.			
	Change in Hardness (Shore A)	ASTM D- 2240	+10/-5	-2
	Change in Tensile Strength (Kg/Cm2)	ASTM D- 412	-25 Maximum	+9.95
	Change in Elongation %	ASTM D- 412	-35 Maximum	-20.83
6	Compression Test at 70 Degree/24 Hrs.	ASTM D-395	50 Maximum	26.55
7	Ozone Resistant's 50 PPHM/40 Degree/2% Strain/ 72 Hrs.	ASTM D- 1149	No Crack	No Crack
Authorized By, For, Arihant panel fittings private limited				
				
Bimal shah- Quality Engineer				





Certificate No.
Chem : T-2329
Mech : T-2379



Sohm
Analytical

Sohm Analytical Services (I) Pvt Ltd.

CIN No.: U74900MH2015PTC266186
A-101/121,B-33/35, Amargian Industrial Estate,
Pokharan Road No.1, Opp. S.T. Work Shop,
Khopat, Thane (West) - 400601
Tel No.: + 91 22 2547 1293
Cell No.: + 91 7303790999
Telefax No.: + 91 22 2547 12 95
Email : thane.support@sohmanalytical.com
Web.: www.sohmanalytical.com

TEST CERTIFICATE

M/s Shiv Om Fastners

Shop No.9,Matruchaya Co Hsg Soc,Sector 8 A, Airoli Navi
Mumbai.

Ref. No.: SOF/20-21/05

Challan Dated: 28-09-2020

Description: Testing of Bolt sample

ULR-TC787920000014596F

Lab Ref. No.: U3252

Sample Received on: 29-09-2020

Report Completed on: 06-10-2020

Stamped By:

Specification: --IS 1367(PART-3) CLASS 8.8

Size M12 X 75
Description ZYP 8.8 BOLT

CHEMICAL ANALYSIS BY SPECTRO (OES) Test Method : ASTM E 415:2017

Eqpt. Sr. No:18006596

Elements	Result	Required Value
% Carbon	0.25	0.25-0.55
% Phosphorus	0.014	0.035 max.
% Sulphur	0.005	0.035 max.

Remarks: THE ABOVE MATERIAL CONFORMS TO IS 1367(PART-3) CLASS 8.8 WITH RESPECT TO ELEMENT ANALYSED

Hardness Test Test Method : IS 1586-1:2012

Eqpt. Sr. No:179-0211 Calibration Date: 10-09-2020 Due On: 09-09-2021

Description	Result	Required Value
Location	Surface	
Hardness In HRC	29,29,30	22-32
Remark	Satisfactory	

-----End of Report-----

FOR SOHM ANALYTICAL SERVICES (I) Pvt Ltd.

Authorised Signatory

O.P. Singh
(HOD Chemical)

Authorised Signatory

Vishal Bhapkar
(Metallurgist)

Checked by



Notes:

- The above test reports relate only to sample submitted. • Sample shall not drawn by Sohmanalytical Services (I) Pvt Ltd.
- No part of this test reports may be reproduced without the written permission of the QM.
- The company or it's directors shall not be responsible in any way for any financial liability due to omission or error made in the report.
- # Not covered under NABL Scope. • Accredited as per ISO/IEC 17025 : 2005 by NABL.



Certificate No.
Chem : T-2329
Mech : T-2379



Sohm
Analytical

Sohm Analytical Services (I) Pvt Ltd.

CIN No.: U74900MH2015PTC266186

A-101/121,B-33/35, Amargian Industrial Estate,

Pokharan Road No.1, Opp. S.T. Work Shop,

Khopat, Thane (West) - 400601

Tel No.: + 91 22 2547 1293

Cell No.: + 91 7303790999

Telefax No.: + 91 22 2547 12 95

Email : thane.support@sohmanalytical.com

Web.: www.sohmanalytical.com

TEST CERTIFICATE

M/s Shiv Om Fastners

Shop No.9,Matruchaya Co Hsg Soc,Sector 8 A, Airoli Navi
Mumbai.

Ref. No.: SOF/20-21/05

Challan Dated: 28-09-2020

Description:Testing of Bolt sample

ULR-TC787920000014602F

Lab Ref. No.:U3253

Sample Received on: 29-09-2020

Report Completed on:06-10-2020

Stamped By:

Specification:IS 1367(PART-3) CLASS 8.8

Size M10 X 95
Description ZYP 8.8 BOLT HT


Hardness Test Test Method : IS 1586-1:2012


Eqpt. Sr. No:179-0211 Calibration Date: 10-09-2020 Due On: 09-09-2021


Description	Result	Required Value
Location	Surface	
Hardness In HRC	23,24,24	22-32
Remark	Satisfactory	

-----End of Report-----

FOR SOHM ANALYTICAL SERVICES (I) Pvt Ltd.


Authorized Signatory
Vishal Bhapkar
(Metallurgist)


Checked by



Page 1 of 1

Notes:

- The above test reports relate only to sample submitted. • Sample shall not drawn by Sohmanalytical Services (I) Pvt Ltd.
- No part of this test reports may be reproduced without the written permission of the QM.
- The company or it's directors shall not be responsible in any way for any financial liability due to omission or error made in the report.
- # Not covered under NABL Scope. • Accredited as per ISO/IEC 17025 : 2005 by NABL.



Certificate No.
Chem : T-2329
Mech : T-2379



Sohm
Analytical

Sohm Analytical Services (I) Pvt Ltd.

CIN No.: U74900MH2015PTC266186
A-101/121,B-33/35, Amargian Industrial Estate,
Pokharan Road No.1, Opp. S.T. Work Shop,
Khopat, Thane (West) - 400601
Tel No.: + 91 22 2547 1293
Cell No.: + 91 7303790999
Telefax No.: + 91 22 2547 12 95
Email : thane.support@sohmanalytical.com
Web.: www.sohmanalytical.com

TEST CERTIFICATE

M/s Shiv Om Fastners

Shop No.9,Matruchaya Co Hsg Soc,Sector 8 A, Airoli Navi
Mumbai.

Ref. No.: SOF/20-21/05

Challan Dated: 28-09-2020

Description:Testing of Bolt sample

ULR-TC787920000014601F

Lab Ref. No.:U3254

Sample Received on: 29-09-2020

Report Completed on:06-10-2020

Stamped By:

Specification:IS 1367(PART-3) CLASS 8.8

Size M10 X 75
Description ZYP 8.8 BOLT HT


Hardness Test Test Method : IS 1586-1:2012

Eqpt. Sr. No:179-0211 Calibration Date: 10-09-2020 Due On: 09-09-2021

Description	Result	Required Value
Location	Surface	
Hardness In HRC	24,24,24	22-32
Remark	Satisfactory	

-----End of Report-----

FOR SOHM ANALYTICAL SERVICES (I) Pvt Ltd.


Authorised Signatory
Vishal Bhapkar
(Metallurgist)


Checked by



Page 1 of 1

Notes:

- The above test reports relate only to sample submitted. • Sample shall not drawn by Sohmanalytical Services (I) Pvt Ltd.
- No part of this test reports may be reproduced without the written permission of the QM.
- The company or it's directors shall not be responsible in any way for any financial liability due to omission or error made in the report.
- # Not covered under NABL Scope. • Accredited as per ISO/IEC 17025 : 2005 by NABL.



Certificate No.
Chem : T-2329
Mech : T-2379



Sohm
Analytical

Sohm Analytical Services (I) Pvt Ltd.

CIN No.: U74900MH2015PTC266186

A-101/121,B-33/35, Amargian Industrial Estate,

Pokharan Road No.1, Opp. S.T. Work Shop,

Khopat, Thane (West) - 400601

Tel No.: + 91 22 2547 1293

Cell No.: + 91 7303790999

Telefax No.: + 91 22 2547 12 95

Email : thane.support@sohmanalytical.com

Web.: www.sohmanalytical.com

TEST CERTIFICATE

M/s Shiv Om Fastners

Shop No.9,Matruchaya Co Hsg Soc,Sector 8 A, Airoli Navi
Mumbai.

Ref. No.: SOF/20-21/05

Challan Dated: 28-09-2020

Description:Testing of Nut sample

ULR-TC787920000014598F

Lab Ref. No.:U3258

Sample Received on: 29-09-2020

Report Completed on:06-10-2020

Stamped By:

Specification:--

Size M10
Description ZYP NUT

Hardness Test Test Method : IS 1501-1:2013

Eqpt. Sr. No:2011/144 Calibration Date: 10-09-2020 Due On: 09-09-2021

Description	Result
Location	Surface
Hardness In Hv-10	202,206,206

-----End of Report-----

FOR SOHM ANALYTICAL SERVICES (I) Pvt Ltd.

Authorised Signatory

Vishal Bhapkar
(Metallurgist)

Checked by



Page 1 of 1

Notes:

- The above test reports relate only to sample submitted. • Sample shall not drawn by Sohmanalytical Services (I) Pvt Ltd.
- No part of this test reports may be reproduced without the written permission of the QM.
- The company or it's directors shall not be responsible in any way for any financial liability due to omission or error made in the report.
- # Not covered under NABL Scope. • Accredited as per ISO/IEC 17025 : 2005 by NABL.



Certificate No.
Chem : T-2329
Mech : T-2379



Sohm
Analytical

Sohm Analytical Services (I) Pvt Ltd.

CIN No.: U74900MH2015PTC266186
A-101/121,B-33/35, Amargian Industrial Estate,
Pokharan Road No.1, Opp. S.T. Work Shop,
Khopat, Thane (West) - 400601
Tel No.: + 91 22 2547 1293
Cell No.: + 91 7303790999
Telefax No.: + 91 22 2547 12 95
Email : thane.support@sohmanalytical.com
Web.: www.sohmanalytical.com

TEST CERTIFICATE

M/s Shiv Om Fastners

Shop No.9,Matruchaya Co Hsg Soc,Sector 8 A, Airoli Navi
Mumbai.

Ref. No.: SOF/20-21/05

Challan Dated: 28-09-2020

Description: Testing of Bolt sample

ULR-TC787920000014599F

Lab Ref. No.: U3257

Sample Received on: 29-09-2020

Report Completed on: 06-10-2020

Stamped By:

Specification: IS 1367(PART-3) CLASS 8.8

Size M8 X 25
Description GI 8.8 BOLT


Hardness Test Test Method : IS 1586-1:2012


Eqpt. Sr. No:179-0211 Calibration Date: 10-09-2020 Due On: 09-09-2021

Description	Result	Required Value
Location	Surface	
Hardness In HBW	31,31,30	22-32
Remark	Satisfactory	

-----End of Report-----

FOR SOHM ANALYTICAL SERVICES (I) Pvt Ltd.


Authorised Signatory
Vishal Bhapkar
(Metallurgist)


Checked by



Notes:

- The above test reports relate only to sample submitted. • Sample shall not drawn by Sohmanalytical Services (I) Pvt Ltd.
- No part of this test reports may be reproduced without the written permission of the QM.
- The company or it's directors shall not be responsible in any way for any financial liability due to omission or error made in the report.
- # Not covered under NABL Scope. • Accredited as per ISO/IEC 17025 : 2005 by NABL.