



TELANGANA STATE POLLUTION CONTROL BOARD
REGIONAL OFFICE: HYDERABAD
4th Floor, PODUPU BHAVAN, Hyderabad Collectorate Complex NS.Road, Hyderabad-500 001.

Dr. B. Sangeetha,
Environmental Engineer

Phone No.: 040-23205367,
e-mail: ee-hyd-tspcb@telangana.gov.in

Order No. 1/TSPCB/ROH/HYD/ACK/DGsets/2023- 51

Date: 17.04.2023

REGISTERED POST WITH ACK DUE
ACKNOWLEDGEMENT

(For I.T. industry / Telecommunications related)

See Rule No.32 B of the Telangana State Water (Prevention and Control of Pollution) Rules 1976 and Rule No.29 B of the Telangana State Air (Prevention and Control of Pollution) Rules, 1982.

The Consent application submitted by M/s. Green Towers, 1-10-176, Begumpet Main Road, Opposite Hyderabad Public School, Hyderabad is hereby acknowledged. This acknowledgment shall be treated as Consent of T.S. Pollution Control Board subject to the following conditions.

- i. The minimum stack height shall be calculated based on the following formula i.e. as per CPCB guidelines.

$$H = h + 0.2 \sqrt{KVA}$$

H = height of stack in meters

h = height of the building in meters, where D.G.set is installed

KVA = Total generator capacity.


- ii. Suitable acoustic enclosures to the DG set shall be provided to meet the following ambient air quality standards.

Area code	Category of Area / Zone	Limits in dB(A) Leq	
		Day time	Night time
(A)	Industrial area	75	70
(B)	Commercial area	65	55
(C)	Residential area	55	45
(D)	Silence Zone	50	40

- a) Daytime shall mean from 6:00 AM to 10:00 PM.
- b) Nighttime shall mean from 10:00 PM to 6:00 AM.
- c) Silence zone is defined as an area comprising not less than 100 meters around hospitals, which are declared as such by the competent authority.
- d) Mixed categories of areas may be declared as one of the four above mentioned categories by the competent authority.

To
Hear
Pollution
Control
Board
No C
DG set

- iii. All the rules / standards notified by the State and Central Government under Environmental laws from time to time, which are applicable to this unit shall be complied with.
- iv. The T.S. Pollution Control Board may inspect the unit at any time to issue consent order stipulating such Standards / conditions as are deemed fit.
- v. The acknowledgement shall automatically stand cancelled in case the industry violates any of the conditions stipulated.


ENVIRONMENTAL ENGINEER



To
M/s. Green Towers,
1-10-176, Begumpet Main Road,
Opposite Hyderabad Public School,
Hyderabad - 500016.

Copy to: The Joint Chief Environmental Engineer, TSPCB, Zonal Office, Begumpet, Hyderabad for kind information.

The list of Site Address, DG Set Capacity are as follows:

S. No.	Capacity	Site Address	DISTRICT
1.	2 x 500 KVA, 1 x 250 KVA & 1 x 125 KVA	M/s. Green Towers, 1-10-176, Begumpet Main Road, Opposite : Hyderabad Public School, Hyderabad.	Hyderabad District

To
Sri. Sharad Jayatilal &
Sri. Rajesh Jayantilal Kadakia
both represented by their GPA Holder
Sri. Soham Modi, Green Towers,
1-10-176, Begumpet Main Road,
Opposite Hyderabad Public School,
Hyderabad - 500016.

ENVIRONMENTAL ENGINEER

