

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		Oct&Nov-19													
Prepared By:		S.Sunil Kumar													
Date:		06-12-2019													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7258	20-09-2019	Sitemix	M25	Scpl		29	col	2	28-9-19	8	17.5	400.0	17.8		
											17.5	395.0	17.6	17.7	
											17.5	400.0	17.8		
7258	20-09-2019	Sitemix	M25	Scpl		29	col	2	18-10-19	28	25.0	570.0	25.3		
											25.0	570.0	25.3	25.3	
											25.0	565.0	25.1		
7259	21-09-2019	Sitemix	M25	Scpl		32	col	3	28-9-19	7	17.5	395.0	17.6		
											17.5	395.0	17.6	17.6	
											17.5	400.0	17.8		
7259	21-09-2019	Sitemix	M25	Scpl		32	col	3	18-10-19	27	25.0	570.0	25.3		
											25.0	570.0	25.3	25.4	
											25.0	575.0	25.6		
7260	25-09-2019	Sitemix	M25	repl		45d(VSC)	col	2	1-10-19	6	17.5	400.0	17.8		
											17.5	395.0	17.6	17.7	
											17.5	400.0	17.8		
7260	25-09-2019	Sitemix	M25	repl		45d(VSC)	col	2	22-10-19	27	25.0	565.0	25.1		
											25.0	570.0	25.3	25.3	
											25.0	575.0	25.6		
7261	27-09-2019	Sitemix	M25	repl		45c(VSC)	col	2	4-10-19	7	17.5	400.0	17.8		
											17.5	395.0	17.6	17.6	
											17.5	395.0	17.6		
7261	27-09-2019	Sitemix	M25	repl		45c(VSC)	col	2	25-10-19	28	25.0	570.0	25.3		
											25.0	575.0	25.6	25.4	
											25.0	570.0	25.3		
7262	28-09-2019	Sitemix	M25	repl		45c(VSC)	col	2	4-10-19	6	17.5	400.0	17.8		
											17.5	395.0	17.6	17.7	
											17.5	400.0	17.8		
7262	28-09-2019	Sitemix	M25	repl		45c(VSC)	col	2	25-10-19	27	25.0	565.0	25.1		
											25.0	575.0	25.6	25.3	
											25.0	570.0	25.3		

7263	03-10-2019	Sitemix	M25	rcpl	45b(VSC)	col	2	10-10-19	7	17.5	395.0	17.6		
										17.5	395.0	17.6	17.6	
										17.5	400.0	17.8		
7263	03-10-2019	Sitemix	M25	repl	45b(VSC)	col	2	31-10-19	28	25.0	565.0	25.1		
										25.0	575.0	25.6	25.3	
										25.0	565.0	25.1		
7264	03-10-2019	Rmc	M20	Ksr	76	Slab	3	10-10-19	7	14.0	325.0	14.4		
										14.0	325.0	14.4	14.4	
										14.0	320.0	14.2		
7264	03-10-2019	Rmc	M20	Ksr	76	Slab	3	31-10-19	28	20.0	465.0	20.7		
										20.0	460.0	20.4	20.6	
										20.0	465.0	20.7		
7265	03-10-2019	Rmc	M20	Ksr	73	Slab	3	10-10-19	7	14.0	325.0	14.4		
										14.0	320.0	14.2	14.3	
										14.0	320.0	14.2		
7265	03-10-2019	Rmc	M20	Ksr	73	Slab	3	31-10-19	28	20.0	470.0	20.9		
										20.0	460.0	20.4	20.7	
										20.0	465.0	20.7		
7266	06-10-2019	Rmc	M20	Scpl	30	Slab	2	12-10-19	6	14.0	325.0	14.4		
										14.0	320.0	14.2	14.4	
										14.0	325.0	14.4		
7266	06-10-2019	Rmc	M20	Scpl	30	Slab	2	4-11-19	29	20.0	470.0	20.9		
										20.0	470.0	20.9	20.8	
										20.0	465.0	20.7		
7267	06-10-2019	Rmc	M20	Scpl	31	Slab	2	12-10-19	6	14.0	320.0	14.2		
										14.0	325.0	14.4	14.4	
										14.0	330.0	14.7		
7267	06-10-2019	Rmc	M20	Scpl	31	Slab	2	4-11-19	29	20.0	470.0	20.9		
										20.0	465.0	20.7	20.9	
										20.0	475.0	21.1		
7268	06-10-2019	Rmc	M20	Mallesh	97	Slab	1	12-10-19	6	14.0	325.0	14.4		
										14.0	325.0	14.4	14.5	
										14.0	330.0	14.7		
7268	06-10-2019	Rmc	M20	Mallesh	97	Slab	1	4-11-19	29	20.0	480.0	21.3		
										20.0	475.0	21.1	21.2	
										20.0	475.0	21.1		

7269	15-10-2019	Rmc	M20	Scpl	29	Slab	2	22-10-19	7	14.0	325.0	14.4		
										14.0	325.0	14.4	14.4	
										14.0	320.0	14.2		
7269	15-10-2019	Rmc	M20	Scpl	29	Slab	2	13-11-19	29	20.0	465.0	20.7		
										20.0	470.0	20.9	20.8	
										20.0	470.0	20.9		
7270	15-10-2019	Rmc	M20	Tirupathi	Club House	Slab	7	22-10-19	7	14.0	330.0	14.7		
										14.0	325.0	14.4	14.4	
										14.0	320.0	14.2		
7270	15-10-2019	Rmc	M20	Tirupathi	Club House	Slab	7	13-11-19	29	20.0	470.0	20.9		
										20.0	475.0	21.1	21.1	
										20.0	480.0	21.3		
7271	18-10-2019	Rmc	M20	repl	45b(VSC)	Slab	2	25-10-19	7	14.0	320.0	14.2		
										14.0	325.0	14.4	14.3	
										14.0	320.0	14.2		
7271	18-10-2019	Rmc	M20	repl	45b(VSC)	Slab	2	16-11-19	29	20.0	475.0	21.1		
										20.0	470.0	20.9	20.9	
										20.0	465.0	20.7		
7272	18-10-2019	Rmc	M20	repl	45c(VSC)	Slab	2	25-10-19	7	14.0	325.0	14.4		
										14.0	325.0	14.4	14.5	
										14.0	330.0	14.7		
7272	18-10-2019	Rmc	M20	repl	45c(VSC)	Slab	2	16-11-19	29	20.0	475.0	21.1		
										20.0	480.0	21.3	21.1	
										20.0	470.0	20.9		
7273	19-10-2019	Rmc	M25	Scpl	31	col	3	25-10-19	6	17.5	415.0	18.4		
										17.5	410.0	18.2	18.4	
										17.5	420.0	18.7		
7273	19-10-2019	Rmc	M25	Scpl	31	col	3	16-11-19	28	25.0	580.0	25.8		
										25.0	590.0	26.2	26.1	
										25.0	595.0	26.4		
7274	19-10-2019	Rmc	M25	Scpl	30	col	3	25-10-19	6	17.5	420.0	18.7		
										17.5	415.0	18.4	18.5	
										17.5	415.0	18.4		
7274	19-10-2019	Rmc	M25	Scpl	30	col	3	16-11-19	28	25.0	590.0	26.2		
										25.0	590.0	26.2	26.3	
										25.0	595.0	26.4		

7275	26-10-2019	Sitemix	M25	Scpl		97	col	2	2-11-19	7	17.5	400.0	17.8		
											17.5	400.0	17.8	17.7	
											17.5	395.0	17.6		
7275	26-10-2019	Sitemix	M25	Scpl		97	col	2	23-11-19	28	25.0	570.0	25.3		
											25.0	570.0	25.3	25.3	
											25.0	565.0	25.1		
7276	05-11-2019	Rmc	M20	Scpl		29	Slab	3	12-11-19	7	14.0	320.0	14.2		
											14.0	325.0	14.4	14.3	
											14.0	320.0	14.2		
7276	05-11-2019	Rmc	M20	Scpl		29	Slab	3	3-12-19	28	20.0	465.0	20.7		
											20.0	465.0	20.7	20.6	
											20.0	460.0	20.4		
7277	05-11-2019	Rmc	M20	Scpl		30	Slab	3	12-11-19	7	14.0	325.0	14.4		
											14.0	325.0	14.4	14.4	
											14.0	320.0	14.2		
7277	05-11-2019	Rmc	M20	Scpl		30	Slab	3	3-12-19	28	20.0	470.0	20.9		
											20.0	465.0	20.7	20.7	
											20.0	460.0	20.4		
7278	05-11-2019	Rmc	M20	Scpl		31	Slab	3	12-11-19	7	14.0	325.0	14.4		
											14.0	325.0	14.4	14.4	
											14.0	320.0	14.2		
7278	05-11-2019	Rmc	M20	Scpl		31	Slab	3	3-12-19	28	20.0	465.0	20.7		
											20.0	470.0	20.9	20.8	
											20.0	470.0	20.9		
7279	05-11-2019	Rmc	M20	Scpl		32	Slab	3	12-11-19	7	14.0	325.0	14.4		
											14.0	325.0	14.4	14.5	
											14.0	330.0	14.7		
7279	05-11-2019	Rmc	M20	Scpl		32	Slab	3	3-12-19	28	20.0	475.0	21.1		
											20.0	465.0	20.7	20.9	
											20.0	470.0	20.9		