

QC - Concrete Cube Testing Report.															
Company:	SOVLLP	Project:	SOV	Report for Month:	May&June-19	Prepared By:	S.Sunil Kumar	Date:	05-07-2019						
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7170	14-05-2019	Rmc	M20	Scpl		29	footing		11-6-19	28	20.0	465.0	20.7	20.8	
7171	14-05-2019	Rmc	M20	Scpl		30	footing		21-5-19	7	14.0	325.0	14.2	14.5	
7171	14-05-2019	Rmc	M20	Scpl		30	footing		21-5-19	7	14.0	325.0	14.2	14.4	
7171	14-05-2019	Rmc	M20	Scpl		30	footing		11-6-19	28	20.0	465.0	20.2	20.5	
7172	16-05-2019	Rmc	M20	Scpl		36	Slab		23-5-19	7	14.0	335.0	14.9	14.9	
7172	16-05-2019	Rmc	M20	Scpl		36	Slab		13-6-19	28	20.0	480.0	21.3	21.1	
7173	16-05-2019	Rmc	M20	Scpl		37	Slab		23-5-19	7	14.0	320.0	14.2	14.4	
7173	16-05-2019	Rmc	M20	Scpl		37	Slab		13-6-19	28	20.0	475.0	21.1	20.9	

7174	17-05-2019	Site mix	M25	Scpl	35	col	2	23-5-19	6	17.5	405.0	18.0	17.8	400.0	17.5	17.8	17.9	
7174	17-05-2019	Site mix	M25	Scpl	35	col	2											
7174	17-05-2019	Site mix	M25	Scpl	35	col	2	13-6-19	27	25.0	570.0	25.3	25.6	575.0	25.0	25.6	25.5	
7175	19-05-2019	Site mix	M25	Scpl	40	col	1	27-5-19	8	17.5	410.0	18.2	18.4	400.0	17.5	17.8	18.1	
7175	19-05-2019	Site mix	M25	Scpl	40	col	1	17-6-19	29	25.0	575.0	25.6	25.6	575.0	25.0	25.6	25.6	
7176	21-05-2019	Rmc	M20	Scpl	68	Slab	2	29-5-19	8	14.0	330.0	14.7	14.7	330.0	14.0	14.9	14.7	
7176	21-05-2019	Rmc	M20	Scpl	68	Slab	2	18-6-19	28	20.0	465.0	20.7	20.7	465.0	20.0	20.9	20.7	
7177	21-05-2019	Site mix	M25	Scpl	67	col	2	29-5-19	8	17.5	415.0	18.4	17.8	400.0	17.5	18.2	18.1	
7177	21-05-2019	Site mix	M25	Scpl	67	col	2	18-6-19	28	25.0	575.0	25.6	25.6	580.0	25.0	25.8	25.6	
7178	21-05-2019	Rmc	M20	Scpl	29	footing		29-5-19	8	14.0	330.0	14.7	14.9	335.0	14.0	15.1	14.9	
7178	21-05-2019	Rmc	M20	Scpl	29	footing		18-6-19	28	20.0	475.0	21.1	21.1	470.0	20.0	20.9	20.9	
										20.0	465.0	20.7						

9/7
w

7179	21-05-2019	Rmc	M20	Scpl	30	footing	29-5-19	8	14.0	325.0	14.4	14.2	14.4	
7179	21-05-2019	Rmc	M20	Scpl	30	footing			14.0	320.0	14.2		14.4	
									14.0	325.0	14.4			
7179	21-05-2019	Rmc	M20	Scpl	30	footing	18-6-19	28	20.0	470.0	20.9	20.9		
									20.0	470.0	20.9			
									20.0	465.0	20.7		20.8	
7180	22-05-2019	Stemix	M25	Scpl	55	col	29-5-19	7	17.5	415.0	18.4	18.4		
									17.5	410.0	18.2		18.4	
									17.5	415.0	18.4			
7180	22-05-2019	Stemix	M25	Scpl	55	col	18-6-19	27	25.0	570.0	25.3			
									25.0	575.0	25.6	25.5		
									25.0	575.0	25.6			
7181	30-05-2019	Rmc	M20	Scpl	39	Slab	6-6-19	7	14.0	330.0	14.7			
									14.0	335.0	14.9	14.8		
									14.0	335.0	14.9			
7181	30-05-2019	Rmc	M20	Scpl	39	Slab	27-6-19	28	20.0	480.0	21.3	21.3		
									20.0	485.0	21.6			
									20.0	475.0	21.1			