

aruna@modiproperties.com

From: "Soham Modi" <sohammodi@modiproperties.com>
Date: 21-02-2019 10:27 AM
To: "aruna" <aruna@modiproperties.com>
Attach: V.no-39 PB.jpg
Subject: Fw: Cancel the ID no-32971 at SOV Site. reg-

Print

Regards,
Soham Modi

From: qc@modiproperties.com
Sent: 21 February 2019 10:21 am
To: aruna@modiproperties.com
Cc: sohammodi@modiproperties.com; sov@modiproperties.com; qc@modiproperties.com; ashaiya@modiproperties.com
Subject: Cancel the ID no-32971 at SOV Site. reg-

To,

Aruna Madam.

Please Cancel the ID no-32971 raised for Villa no-39 (Before Plinthbeam) at SOV Site. Pending Works are as below.

- 1) Staircase Rods not Provided.
- 2) Instead of PB-1 beam they tied PB-2 Beam.
- 3) Covering blocks not Provided in all beams.
- 4) Rod-bending Work was very Poor.
- 5) Beams Sides Shuttering Work not done Properly.
- 6) Plinthbeam QC Check Plan Enclosed.

Note: Without Making Self-Check Site-Engineer (Veerabramam) Simply raised QC Request. After Completion of All Works Send Self-Check Report to QC Team and then raise New Request.

Regards,
QC Team.

23-02-2019

