


sohammodi@modiproperties.com



From:
Sent:
To:
Cc:
Subject:

QC <qc@modiproperties.com>
18 03 2019 3.26 PM
aruna
soham modi; Ashaiya; QC; SOV
Cancel the Following ID.no-33198 (OHT Top Slab) Residential Apartment at SOV
Site. reg-

To,

Aruna Madam.

Please Cancel the Following ID.no-33198 (OHT Top Slab) Residential Apartment at SOV Site. OHT Retaining Wall
not Casted as per Drawing, Instead of (5'-9") Clear Height, they Casted (5'-3") only.

NOTE: Veerabrahmam Concerned Engineer without making Self-Check Simply Raised QC Request. After
Completion of all Works Send Self-Check Report to QC Team and then raise New QC Request.

Regards,
QC Team.