

File

QC - Concrete Cube Testing Report.															
Company:		SOVLLP													
Project:		SOV													
Report for Month:		Oct & Nov-18													
Prepared By:		S.Samir Kumar													
Date:		12-01-2019													
S No	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No	Used for Slab / Columns	Slab No or Column No.	Date of Testing	No of days	Specified Strength	Tested Strength in Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7849	13-11-2018	Rmc	M20	Repl		83	Pb		21-11-18	8	14.0	325.0	14.4	14.4	
7849	13-11-2018	Rmc	M20	Repl		83	Pb		11-12-18	28	20.0	455.0	20.2		
											20.0	460.0	20.4	20.4	
											20.0	465.0	20.7		
7850	13-11-2018	Site mix	M25	Repl		57	col	2	21-11-18	8	17.5	405.0	18.0		
											17.5	400.0	17.8	17.8	
											17.5	395.0	17.6		
7850	13-11-2018	Site mix	M25	Repl		57	col	2	11-12-18	28	25.0	570.0	25.3		
											25.0	560.0	24.9	25.2	
											25.0	570.0	25.3		
7851	14-11-2018	Site mix	M25	Repl		59	col	3	21-11-18	7	17.5	405.0	18.0		
											17.5	400.0	17.8	17.9	
											17.5	400.0	17.8		
7851	14-11-2018	Site mix	M25	Repl		59	col	3	11-12-18	27	25.0	565.0	25.1		
											25.0	570.0	25.3	25.3	
											25.0	575.0	25.6		
7852	14-11-2018	Site mix	M25	KSR		80	col	3	21-11-18	7	17.5	395.0	17.6		
											17.5	400.0	17.8	17.6	
											17.5	395.0	17.6		
7852	14-11-2018	Site mix	M25	KSR		80	col	3	11-12-18	27	25.0	570.0	25.3		
											25.0	575.0	25.6	25.5	
											25.0	575.0	25.6		
7853	16-11-2018	Site mix	M25	Repl		90	col	2	24-11-18	8	17.5	400.0	17.8		
											17.5	400.0	17.8	17.7	
											17.5	395.0	17.6		
7853	16-11-2018	Site mix	M25	Repl		90	col	2	15-12-18	29	25.0	570.0	25.3		
											25.0	570.0	25.3	25.4	
											25.0	575.0	25.6		

7854	16-11-2018	Rmc	M20	KSR		77	44b	2	24-11-18	8	14.0	325.0	14.4		
											14.0	320.0	14.2	14.4	
											14.0	330.0	14.7		
7854	16-11-2018	Rmc	M20	KSR		77	44b	2	15-12-18	29	20.0	465.0	20.7		
											20.0	470.0	20.9	20.7	
											20.0	460.0	20.4		
7855	16-11-2018	Rmc	M25	KSR		79	col	3	24-11-18	8	17.5	405.0	18.0		
											17.5	400.0	17.8	17.9	
											17.5	400.0	17.8		
7855	16-11-2018	Rmc	M25	KSR		79	col	3	15-12-18	29	25.0	565.0	25.1		
											25.0	570.0	25.3	25.3	
											25.0	575.0	25.6		
7856	18-11-2018	Site max	M25	KSR		72	col	1	27-11-18	9	17.5	400.0	17.8		
											17.5	395.0	17.6	17.7	
											17.5	400.0	17.8		
7856	18-11-2018	Site max	M25	KSR		72	col	1	17-12-18	29	25.0	575.0	25.6		
											25.0	565.0	25.1	25.4	
											25.0	575.0	25.6		
7857	17-11-2018	Rmc	M20	KSR		74	Pb		24-11-18	7	14.0	325.0	14.4		
											14.0	320.0	14.2	14.4	
											14.0	325.0	14.4		
7857	17-11-2018	Rmc	M20	KSR		74	Pb		15-12-18	28	20.0	465.0	20.7		
											20.0	455.0	20.2	20.4	
											20.0	460.0	20.4		
7858	18-11-2018	Site max	M25	Scpl		43	col	2	24-11-18	6	17.5	405.0	18.0		
											17.5	400.0	17.8	17.9	
											17.5	405.0	18.0		
7858	18-11-2018	Site max	M25	Scpl		43	col	2	15-12-18	27	25.0	565.0	25.1		
											25.0	570.0	25.3	25.2	
											25.0	565.0	25.1		
7859	19-11-2018	Site max	M25	Scpl		45	col	2	27-11-18	8	17.5	400.0	17.8		
											17.5	395.0	17.6	17.8	
											17.5	405.0	18.0		
7859	19-11-2018	Site max	M25	Scpl		45	col	2	17-12-18	28	25.0	575.0	25.6		
											25.0	565.0	25.1	25.3	
											25.0	570.0	25.3		
7860	20-11-2018	Site max	M25	Scpl		91	col	2	27-11-18	7	17.5	405.0	18.0		
											17.5	400.0	17.8	17.9	
											17.5	405.0	18.0		

7860	20-11-2018	Site max	M25	Rcpt		91	col	2	17-12-18	27	250	565.0	25.1	
											250	565.0	25.1	25.2
											250	570.0	25.3	
7861	20-11-2018	Rnc	M20	Scpl		85	Pb		27-11-18	7	140	325.0	14.4	
											140	320.0	14.2	14.4
											140	325.0	14.4	
7861	20-11-2018	Rnc	M20	Scpl		85	Pb		17-12-18	27	200	465.0	20.7	
											200	470.0	20.9	20.7
											200	460.0	20.4	
7862	20-11-2018	Rnc	M20	KSR		54	Pb		27-11-18	7	140	320.0	14.7	
											140	325.0	14.4	14.5
											140	325.0	14.4	
7862	20-11-2018	Rnc	M20	KSR		54	Pb		17-12-18	27	200	455.0	20.2	
											200	470.0	20.9	20.5
											200	460.0	20.4	
7863	20-11-2018	Site max	M25	KSR		72	col	1	27-11-18	7	17.5	405.0	18.0	
											17.5	395.0	17.6	17.8
											17.5	400.0	17.8	
7863	20-11-2018	Site max	M25	KSR		72	col	1	17-12-18	27	250	565.0	25.1	
											250	565.0	25.1	25.2
											250	570.0	25.3	
7864	21-11-2018	Site max	M25	KSR		73	col	1	27-11-18	6	17.5	410.0	18.2	
											17.5	400.0	17.8	18.0
											17.5	405.0	18.0	
7864	21-11-2018	Site max	M25	KSR		73	col	1	17-12-18	26	250	575.0	25.6	
											250	570.0	25.3	25.5
											250	575.0	25.6	
7865	21-11-2018	Site max	M25	Scpl		44	col	2	27-11-18	6	17.5	405.0	18.0	
											17.5	400.0	17.8	17.9
											17.5	400.0	17.8	
7865	21-11-2018	Site max	M25	Scpl		44	col	2	17-12-18	26	250	570.0	25.3	
											250	570.0	25.3	25.3
											250	565.0	25.1	
7866	22-11-2018	Rnc	M20	KSR		76	Pb		30-11-18	8	140	325.0	14.4	
											140	320.0	14.2	14.3
											140	320.0	14.2	

7866	22-11-2018	Rmc	M20	KSR		76	Pb		20-12-18	28	20.0	460.0	20.4		
											20.0	465.0	20.7	20.5	
											20.0	460.0	20.4		
7867	23-11-2018	Rmc	M20	KSR		80	slab	3	30-11-18	7	14.0	320.0	14.2		
											14.0	325.0	14.4	14.4	
											14.0	325.0	14.4		
7868	23-11-2018	Rmc	M20	KSR		80	slab	3	20-12-18	27	20.0	465.0	20.7		
											20.0	470.0	20.9	20.7	
											20.0	465.0	20.7		
7869	23-11-2018	Rmc	M20	Scpl		38	footing		30-11-18	7	14.0	320.0	14.2		
											14.0	315.0	14.0	14.2	
											14.0	325.0	14.4		
7870	23-11-2018	Rmc	M20	Scpl		38	footing		20-12-18	27	20.0	465.0	20.7		
											20.0	455.0	20.2	20.3	
											20.0	450.0	20.0		
7869	23-11-2018	Rmc	M20	Scpl		59	slab	2	30-11-18	7	14.0	325.0	14.4		
											14.0	320.0	14.2	14.4	
											14.0	325.0	14.4		
7869	23-11-2018	Rmc	M20	Scpl		59	slab	2	20-12-18	27	20.0	465.0	20.7		
											20.0	455.0	20.2	20.5	
											20.0	465.0	20.7		
7870	23-11-2018	Rmc	M20	Scpl		57	slab	2	30-11-18	7	14.0	325.0	14.4		
											14.0	310.0	14.7	14.5	
											14.0	325.0	14.4		
7870	23-11-2018	Rmc	M20	Scpl		57	slab	2	20-12-18	27	20.0	465.0	20.7		
											20.0	460.0	20.4		
7871	24-11-2018	Site max	M25	Scpl		56	col	2	30-11-18	6	17.5	405.0	18.0		
											17.5	400.0	17.8	17.9	
											17.5	400.0	17.8		
7871	24-11-2018	Site max	M25	Scpl		56	col	2	20-12-18	26	25.0	570.0	25.3		
											25.0	575.0	25.6	25.4	
											25.0	570.0	25.3		
7872	26-11-2018	Site max	M25	Scpl		42	col	2	3-12-18	7	17.5	400.0	17.8		
											17.5	395.0	17.6	17.8	
											17.5	405.0	18.0		
7872	26-11-2018	Site max	M25	Scpl		42	col	2	24-12-18	28	25.0	565.0	25.1		
											25.0	570.0	25.3	25.2	
											25.0	565.0	25.1		

7873	26-11-2018	Site max	M25	Sept		41	col	1	3-12-18	7	17.5	405.0	18.0		
											17.5	395.0	17.6	17.9	
											17.5	405.0	18.0		
7873	26-11-2018	Site max	M25	Sept		41	col	1	24-12-18	28	25.0	570.0	25.3		
											25.0	575.0	25.6	25.3	
											25.0	565.0	25.1		
7874	26-11-2018	Rmc	M20	Sept		19	slab	3	3-12-18	7	14.0	325.0	14.4		
											14.0	330.0	14.7	14.5	
											14.0	325.0	14.4		
7874	26-11-2018	Rmc	M20	Sept		19	slab	3	24-12-18	28	20.0	465.0	20.7		
											20.0	465.0	20.7	20.7	
											20.0	470.0	20.9		
7875	28-11-2018	Rmc	M20	Sept		62	Pb		6-12-18	8	14.0	320.0	14.2		
											14.0	325.0	14.4	14.4	
											14.0	325.0	14.4		
7875	28-11-2018	Rmc	M20	Sept		62	Pb		26-12-18	28	20.0	465.0	20.4	20.6	
											20.0	460.0	20.4		
											20.0	465.0	20.7		
7876	28-11-2018	Rmc	M20	Sept		63	Pb		6-12-18	8	14.0	325.0	14.4		
											14.0	320.0	14.2	14.4	
											14.0	325.0	14.4		
7876	28-11-2018	Rmc	M20	Sept		63	Pb		26-12-18	28	20.0	470.0	20.9		
											20.0	465.0	20.7	20.7	
											20.0	465.0	20.7		
7877	28-11-2018	Rmc	M20	Sept		48	Pb		6-12-18	8	14.0	330.0	14.7		
											14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
7877	28-11-2018	Rmc	M20	Sept		48	Pb		26-12-18	28	20.0	465.0	20.7		
											20.0	455.0	20.2	20.4	
											20.0	460.0	20.4		
7878	28-11-2018	Rmc	M20	Tinayiti		Apartment	slab	5	6-12-18	8	14.0	325.0	14.4		
											14.0	320.0	14.2	14.4	
											14.0	325.0	14.4		

7878	28-11-2018	Rmc	M20	Truqpu		Aparent	slab	5	26-12-18	28	20.0	455.0	20.2	
											20.0	460.0	20.4	20.3
											20.0	455.0	20.2	
7879	29-11-2018	Rmc	M20	repl		90	slab	2	6-12-18	7	14.0	315.0	14.0	
											14.0	325.0	14.4	14.2
											14.0	320.0	14.2	
7879	29-11-2018	Rmc	M20	repl		90	slab	2	27-12-18	28	20.0	460.0	20.4	
											20.0	455.0	20.2	20.3
											20.0	455.0	20.2	
7880	29-11-2018	Rmc	M20	repl		95	slab	3	6-12-18	7	14.0	325.0	14.4	
											14.0	335.0	14.4	14.4
											14.0	320.0	14.2	
7880	29-11-2018	Rmc	M20	repl		95	slab	3	27-12-18	28	20.0	465.0	20.7	
											20.0	460.0	20.4	20.6
											20.0	465.0	20.7	
7881	29-11-2018	Rmc	M20	repl		93	slab	3	6-12-18	7	14.0	325.0	14.4	
											14.0	330.0	14.7	14.5
											14.0	325.0	14.4	
7881	29-11-2018	Rmc	M20	repl		93	slab	3	27-12-18	28	20.0	465.0	20.7	
											20.0	470.0	20.9	20.7
											20.0	460.0	20.4	
7882	29-11-2018	Rmc	M25	Sepl		56	col	2	6-12-18	7	17.5	405.0	18.0	
											17.5	400.0	17.8	17.9
											17.5	405.0	18.0	
7882	29-11-2018	Rmc	M25	Sepl		56	col	2	26-12-18	27	25.0	575.0	25.6	
											25.0	585.0	25.1	25.3
											25.0	570.0	25.3	
7883	30-11-2018	Rmc	M25	Sepl		51	col	1	6-12-18	6	17.5	405.0	18.0	
											17.5	410.0	18.2	18.0
											17.5	400.0	17.8	
7883	30-11-2018	Rmc	M25	Sepl		51	col	1	26-12-18	26	25.0	575.0	25.6	
											25.0	580.0	25.8	25.6
											25.0	575.0	25.6	

7884	02-12-2018	Rmc	M20	Scpl		46	Pb		10-12-18	8	14.0	330.0	14.7	
											14.0	320.0	14.2	14.3
											14.0	315.0	14.0	
7884	02-12-2018	Rmc	M20	Scpl		46	Pb		29-12-18	27	20.6	465.0	20.7	
											20.0	455.0	20.2	20.4
											20.0	460.0	20.4	
7885	02-12-2018	Rmc	M20	Scpl		65	Pb		10-12-18	8	14.0	315.0	14.0	
											14.0	320.0	14.2	14.2
											14.0	325.0	14.4	
7885	02-12-2018	Rmc	M20	Scpl		65	Pb		29-12-18	27	20.0	470.0	20.9	
											20.0	465.0	20.7	20.7
											20.0	460.0	20.4	
7886	02-12-2018	Site max	M25	Scpl		52	col	1	10-12-18	8	17.5	405.0	18.0	
											17.5	400.0	17.8	17.9
											17.5	405.0	18.0	
7886	02-12-2018	Site max	M25	Scpl		52	col	1	29-12-18	27	25.0	575.0	25.6	
											25.0	565.0	25.1	25.2
											25.0	560.0	24.9	
7887	03-12-2018	Site max	M25	Repl		92	col	2	10-12-18	7	17.5	400.0	17.8	
											17.5	400.0	17.8	17.7
											17.5	395.0	17.6	
7887	03-12-2018	Site max	M25	Repl		92	col	2	29-12-18	26	25.0	570.0	25.3	
											25.0	575.0	25.6	25.3
											25.0	565.0	25.1	
7888	04-12-2018	Rmc	M20	KSR		69	slab	2	12-12-18	8	14.0	325.0	14.4	
											14.0	325.0	14.4	14.5
											14.0	330.0	14.7	
7888	04-12-2018	Rmc	M20	KSR		69	slab	2	2-1-19	29	20.0	470.0	20.9	
											20.0	465.0	20.7	20.7
											20.0	460.0	20.4	
7889	04-12-2018	Rmc	M20	KSR		71	slab	1	12-12-18	8	14.0	330.0	14.7	
											14.0	330.0	14.7	14.6
											14.0	325.0	14.4	
7889	04-12-2018	Rmc	M20	KSR		71	slab	1	2-1-19	29	20.0	470.0	20.9	
											20.0	465.0	20.7	20.9
											20.0	475.0	21.1	

7890	05-12-2018	Site mix	M25	Rcpt		88	col	1	12-12-18	7	17.5	395.0	17.6	
											17.5	405.0	18.0	17.8
											17.5	480.0	17.8	
7890	05-12-2018	Site mix	M25	Rcpt		88	col	1	2-1-19	28	25.0	565.0	25.1	
											25.0	570.0	25.3	25.1
											25.0	560.0	24.9	
7891	05-12-2018	Site mix	M25	KSR		74	col	1	12-12-18	7	17.5	410.0	18.2	
											17.5	405.0	18.0	17.9
											17.5	395.0	17.6	
7891	05-12-2018	Site mix	M25	KSR		74	col	1	2-1-19	28	25.0	580.0	25.8	
											25.0	570.0	25.3	25.4
											25.0	565.0	25.1	
7892	05-12-2018	Rmc	M20	Sepl		50	Pb		12-12-18	7	14.0	330.0	14.7	
											14.0	325.0	14.4	14.6
											14.0	330.0	14.7	
7892	05-12-2018	Rmc	M20	Sepl		50	Pb		2-1-19	28	20.0	465.0	20.7	
											20.0	470.0	20.9	20.7
											20.0	460.0	20.4	
7893	05-12-2018	Rmc	M20	Sepl		47	Pb		12-12-18	7	14.0	325.0	14.4	
											14.0	320.0	14.2	14.4
											14.0	325.0	14.4	
7893	05-12-2018	Rmc	M20	Sepl		47	Pb		2-1-19	28	20.0	455.0	20.2	
											20.0	460.0	20.4	20.4
											20.0	460.0	20.4	
7894	06-12-2018	Rmc	M20	Sepl		43	slab	2	12-12-18	6	14.0	320.0	14.2	
											14.0	325.0	14.4	14.3
											14.0	320.0	14.2	
7894	06-12-2018	Rmc	M20	Sepl		43	slab	2	2-1-19	27	20.0	470.0	20.9	
											20.0	465.0	20.7	20.8
											20.0	470.0	20.9	
7895	06-12-2018	Rmc	M20	Sepl		45	slab	2	12-12-18	6	14.0	325.0	14.4	
											14.0	330.0	14.7	14.6
											14.0	330.0	14.7	
7895	06-12-2018	Rmc	M20	Sepl		45	slab	2	2-1-19	27	20.0	475.0	21.1	
											20.0	465.0	20.7	20.9
											20.0	470.0	20.9	
7896	06-12-2018	Rmc	M20	Sepl		59	slab	3	12-12-18	6	14.0	335.0	14.4	
											14.0	330.0	14.7	14.5
											14.0	335.0	14.4	

7896	06-12-2018	Rmc	M20	Scpl		59	slab	3	2-1-19	27	20.0	455.0	20.2	
											20.0	460.0	20.4	20.4
											20.0	465.0	20.7	
7897	06-12-2018	Rmc	M20	Scpl		41	slab	1	12-12-18	6	14.0	325.0	14.4	
											14.0	315.0	14.0	14.3
											14.0	325.0	14.4	
7897	06-12-2018	Rmc	M20	Scpl		41	slab	1	2-1-19	27	20.0	475.0	21.1	
											20.0	465.0	20.7	20.9
											20.0	470.0	20.9	
7898	06-12-2018	Site max	M25	KSR		75	col	1	12-12-18	6	17.5	395.0	17.6	
											17.5	405.0	18.0	17.8
											17.5	400.0	17.8	
7898	06-12-2018	Site mix	M25	KSR		75	col	1	2-1-19	27	35.0	575.0	25.6	
											35.0	575.0	25.6	25.5
											35.0	570.0	25.3	
7899	12-12-2018	Rmc	M20	KSR		72	slab	1	20-12-18	8	14.0	325.0	14.4	
											14.0	325.0	14.4	14.3
											14.0	315.0	14.0	
7899	12-12-2018	Rmc	M20	KSR		72	slab	1	9-1-19	28	20.0	455.0	20.2	
											20.0	460.0	20.4	20.4
											20.0	465.0	20.7	
7900	12-12-2018	Site max	M25	KSR		77	col	3	20-12-18	8	17.5	395.0	17.6	
											17.5	405.0	18.0	17.8
											17.5	400.0	17.8	
7900	12-12-2018	Site max	M25	KSR		77	col	3	9-1-19	28	35.0	570.0	25.3	
											35.0	565.0	25.1	25.2
											35.0	565.0	25.1	
7901	12-12-2018	Rmc	M20	KSR		81	slab	3	20-12-18	8	14.0	330.0	14.7	
											14.0	325.0	14.4	14.5
											14.0	325.0	14.4	
7901	12-12-2018	Rmc	M20	KSR		81	slab	3	9-1-19	28	20.0	465.0	20.7	
											20.0	460.0	20.4	20.7
											20.0	470.0	20.9	
7902	12-12-2018	Rmc	M20	Scpl		49	Pe		20-12-18	8	14.0	325.0	14.4	
											14.0	315.0	14.0	14.3
											14.0	325.0	14.4	
7902	12-12-2018	Rmc	M20	Scpl		49	Pe		9-1-19	28	20.0	460.0	20.4	
											20.0	465.0	20.7	20.4
											20.0	455.0	20.2	

7903	12-12-2018	Site max	M25	Repl		87	col	1	20-12-18	8	17.5	405.0	18.0	
											17.5	405.0	18.0	17.9
											17.5	400.0	17.8	
7903	12-12-2018	Site max	M25	Repl		87	col	1	9-1-19	28	25.0	580.0	25.8	
											25.0	570.0	25.3	25.4
											25.0	565.0	25.1	
7904	13-12-2018	Site max	M25	Repl		86	col	1	22-12-18	9	17.5	395.0	17.6	
											17.5	405.0	18.0	17.7
											17.5	395.0	17.6	
7904	13-12-2018	Site max	M25	Repl		86	col	1	10-1-19	28	25.0	575.0	25.6	
											25.0	565.0	25.1	25.2
											25.0	560.0	24.9	
7905	15-12-2018	Rmc	M20	Trumpet		Clubhouse	slab	1	22-12-18	7	14.0	330.0	14.7	
											14.0	325.0	14.4	14.5
											14.0	325.0	14.4	
7905	15-12-2018	Rmc	M20	Trumpet		Clubhouse	slab	1	10-1-19	26	20.0	465.0	20.7	
											20.0	460.0	20.4	20.7
											20.0	470.0	20.9	
7906	15-12-2018	Rmc	M20	Scpl		66	Pb		22-12-18	7	14.0	325.0	14.4	
											14.0	330.0	14.7	14.5
											14.0	335.0	14.4	
7906	15-12-2018	Rmc	M20	Scpl		66	Pb		10-1-19	26	20.0	460.0	20.4	
											20.0	455.0	20.2	20.4
											20.0	465.0	20.7	