

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
7907	16-12-2018	Rmc	M20	Scpl		56	slab	2	14-1-19	29	20.0	465.0	20.7	20.5	
7908	17-12-2018	Site mix	M25	Rcpl		84	col	1	24-12-18	7	17.5	395.0	17.6	17.8	
7908	17-12-2018	Site mix	M25	Rcpl		84	col	1	24-12-18	7	17.5	400.0	17.8	17.8	
7908	17-12-2018	Site mix	M25	Rcpl		84	col	1	14-1-19	28	25.0	575.0	25.6	25.2	
7909	18-12-2018	Site mix	M25	Scpl		61	col	1	24-12-18	6	17.5	405.0	18.0	18.1	
7909	18-12-2018	Site mix	M25	Scpl		61	col	1	14-1-19	27	25.0	575.0	25.6	25.3	
7910	19-12-2018	Site mix	M25	Rcpl		83	col	1	26-12-18	7	17.5	405.0	18.0	17.9	
7910	19-12-2018	Site mix	M25	Rcpl		83	col	1	16-1-19	28	25.0	580.0	25.8	25.4	
7911	20-12-2018	Site mix	M25	Rcpl		85	col	1	26-12-18	6	17.5	410.0	18.2	18.1	
7911	20-12-2018	Site mix	M25	Rcpl		85	col	1	16-1-19	27	25.0	575.0	25.6	25.3	

[illegible]

	7918	22-12-2018	Site mix	M25	Rcpl	89	col	2	18-1-19	27	25.0	575.0	25.6	25.2			
	7919	22-12-2018	Site mix	M25	KSR	74	col	1	28-12-18	6	17.5	405.0	18.0	17.6	17.3	17.6	
	7919	22-12-2018	Site mix	M25	KSR	74	col	1	18-1-19	27	25.0	575.0	25.6	25.5			
	7920	22-12-2018	Rmc	M20	KSR	73	slab	1	28-12-18	6	14.0	330.0	14.7	14.5			
	7920	22-12-2018	Rmc	M20	KSR	73	slab	1	18-1-19	27	20.0	470.0	20.9				
	7920	22-12-2018	Rmc	M20	KSR	73	slab	1	18-1-19	27	20.0	470.0	20.9	20.7			
	7921	22-12-2018	Site mix	M25	Tirupati	Clubhouse	col	2	28-12-18	6	17.5	410.0	18.2	18.0			
	7921	22-12-2018	Site mix	M25	Tirupati	Clubhouse	col	2	18-1-19	27	25.0	565.0	25.1	25.3			
	7921	22-12-2018	Site mix	M25	KSR	75	col	1	28-12-18	6	17.5	395.0	17.6	17.8			
	7922	22-12-2018	Site mix	M25	KSR	75	col	1	18-1-19	27	25.0	565.0	25.1	17.8			
	7922	22-12-2018	Site mix	M25	KSR	75	col	1	18-1-19	27	25.0	565.0	25.1	25.2			
	7923	22-12-2018	Site mix	M25	Sepi		col	2	28-12-18	6	17.5	405.0	18.0	17.6			
	7923	22-12-2018	Site mix	M25	Sepi		col	2	18-1-19	27	25.0	575.0	25.6	25.3			
	7924	22-12-2018	Rmc	M20	Sepi		slab	2	28-12-18	6	14.0	325.0	14.4	14.2			
	7924	22-12-2018	Rmc	M20	Sepi		slab	2	18-1-19	27	20.0	455.0	20.2	20.4			

[illegible]

7931	27-12-2018	Site mix	M25	Scpl	47	col	1	22-1-19	26	25.0	565.0	25.1	25.3	
7933	31-12-2018	Rmc	M25	KSR	74	col	1	7-1-19	7	17.5	400.0	17.8		
										17.5	395.0	17.6	17.8	
										17.5	405.0	18.0		
7933	31-12-2018	Rmc	M25	KSR	74	col	1	28-1-19	28	25.0	575.0	25.6		
										25.0	560.0	24.9	25.2	
										25.0	565.0	25.1		
7934	31-12-2018	Rmc	M25	Scpl	54	col	1	7-1-19	7	17.5	395.0	17.6	17.7	
										17.5	405.0	18.0		
7934	31-12-2018	Rmc	M25	Scpl	54	col	1	28-1-19	28	25.0	565.0	25.1	25.2	
										25.0	570.0	25.3		
7935	02-01-2019	Rmc	M25	Scpl	50	col	1	10-1-19	8	17.5	405.0	18.0	17.8	
										17.5	395.0	17.6		
										17.5	400.0	17.8		
7935	02-01-2019	Rmc	M25	Scpl	50	col	1	28-1-19	26	25.0	575.0	25.6	25.3	
										25.0	565.0	25.1	25.3	
										25.0	570.0	25.3		
7936	02-01-2019	Rmc	M20	Scpl	office buildi	slab	5	10-1-19	8	14.0	330.0	14.7	14.5	
										14.0	325.0	14.4		
										14.0	325.0	14.4		
7936	02-01-2019	Rmc	M20	Scpl	office buildi	slab	5	28-1-19	26	20.0	465.0	20.7	20.7	
										20.0	470.0	20.9		
										20.0	460.0	20.4		
7937	03-01-2019	Rmc	M25	Scpl	49	col	1	10-1-19	7	17.5	400.0	17.8		
										17.5	395.0	17.6	17.7	
										17.5	400.0	17.8		
7937	03-01-2019	Rmc	M25	Scpl	49	col	1	30-1-19	27	25.0	565.0	25.1	25.2	
										25.0	570.0	25.3		

7938	03-01-2019	Rmc	M20	Rcpl	83	slab	1	10-1-19	7	14.0	325.0	14.4	14.2	14.3	
7938	03-01-2019	Rmc	M20	Rcpl	83	slab	1	30-1-19	27	20.0	455.0	20.2	20.4	20.3	
7939	03-01-2019	Site mix	M25	KSR	71	col	2	10-1-19	7	17.5	405.0	18.0	17.8	17.8	
7939	03-01-2019	Site mix	M25	KSR	71	col	2	30-1-19	27	25.0	565.0	25.1	25.1	25.2	
7940	03-01-2019	Site mix	M25	KSR	72	col	2	10-1-19	7	17.5	405.0	18.0	18.0	17.9	
7940	03-01-2019	Site mix	M25	KSR	72	col	2	30-1-19	27	25.0	570.0	25.3	25.3	25.3	
7941	07-01-2019	Rmc	M25	Scpl	63	col	1	14-1-19	7	17.5	405.0	18.0	17.8	17.9	
7941	07-01-2019	Rmc	M25	Scpl	63	col	1	5-2-19	29	25.0	575.0	25.6	25.3	25.4	
7942	07-01-2019	Rmc	M20	Scpl	46	slab	1	14-1-19	7	14.0	320.0	14.2	14.2	14.3	
7942	07-01-2019	Rmc	M20	Scpl	46	slab	1	5-2-19	29	20.0	460.0	20.4	20.4	20.6	

7943	08-01-2019	Rmc	M25	Scpl	64	col	1	14-1-19	6	17.5	405.0	18.0	18.1
7943	08-01-2019	Rmc	M25	Scpl	64	col	1	5-2-19	28	25.0	565.0	25.1	25.2
7943	08-01-2019	Rmc	M25	Scpl	64	col	1	17-1-19	7	17.5	395.0	17.6	17.6
7944	10-01-2019	Rmc	M25	Scpl	66	col	1	17-1-19	7	17.5	400.0	17.8	17.6
7944	10-01-2019	Rmc	M25	Scpl	66	col	1	5-2-19	26	25.0	570.0	25.3	25.4
7945	12-01-2019	Rmc	M20	Scpl	44	slab	2	19-1-19	7	14.0	325.0	14.4	14.5
7945	12-01-2019	Rmc	M20	Scpl	44	slab	2	8-2-19	27	20.0	465.0	20.2	20.4
7946	12-01-2019	Rmc	M25	Scpl	67	col	1	19-1-19	7	17.5	400.0	17.8	17.8
7946	12-01-2019	Rmc	M25	Scpl	67	col	1	8-2-19	27	25.0	575.0	25.6	25.2
7947	12-01-2019	Stemix	M20	Rcpl	89	slab	2	19-1-19	7	14.0	325.0	14.4	14.3
7947	12-01-2019	Stemix	M20	Rcpl	89	slab	2	8-2-19	27	20.0	455.0	20.2	20.4
7948	16-01-2019	Rmc	M25	Scpl	68	col	1	24-1-19	8	17.5	400.0	17.8	17.8
7948	16-01-2019	Rmc	M25	Scpl	68	col	1	13-2-19	28	25.0	565.0	25.1	25.3
7948	16-01-2019	Rmc	M25	Scpl	68	col	1	5-2-19	26	25.0	570.0	25.3	25.3

7949	17-01-2019	Rmc	M25	Scpl		53	col	1	24-1-19	7	17.5	410.0	18.2	17.9
											17.5	400.0	17.8	
											17.5	395.0	17.6	
7949	17-01-2019	Rmc	M25	Scpl		53	col	1	13-2-19	27	25.0	565.0	25.1	
											25.0	570.0	25.3	
											25.0	565.0	25.1	
7950	17-01-2019	Rmc	M20	Scpl		48	slab	1	24-1-19	7	14.0	320.0	14.2	
											14.0	320.0	14.2	
											14.0	325.0	14.4	
7950	17-01-2019	Rmc	M20	Scpl		48	slab	1	13-2-19	27	20.0	465.0	20.7	
											20.0	460.0	20.4	
											20.0	470.0	20.9	
7951	17-01-2019	Rmc	M20	Scpl		41	slab	2	24-1-19	7	14.0	320.0	14.2	
											14.0	325.0	14.4	
											14.0	315.0	14.0	
7951	17-01-2019	Rmc	M20	Scpl		41	slab	2	13-2-19	27	20.0	455.0	20.2	
											20.0	470.0	20.9	
											20.0	460.0	20.4	
7952	18-01-2019	Rmc	M20	Rcpl		88	slab	1	24-1-19	6	14.0	325.0	14.4	
											14.0	320.0	14.2	
											14.0	325.0	14.4	
7952	18-01-2019	Rmc	M20	Rcpl		88	slab	1	13-2-19	26	20.0	455.0	20.2	
											20.0	460.0	20.4	
											20.0	460.0	20.4	
7953	18-01-2019	Rmc	M20	KSR		75	slab	1	24-1-19	6	14.0	325.0	14.4	
											14.0	320.0	14.4	
											14.0	330.0	14.7	
7953	18-01-2019	Rmc	M20	KSR		75	slab	1	13-2-19	26	20.0	470.0	20.9	
											20.0	465.0	20.7	