

QC - Concrete Cube Testing Report														
Project Name		Client		Contract No.		Drawing No.		Report No.		Report Date				
7809		21-10-2018		Rmc		M20		Specified Grade		Supplier / Contractor				
7810		22-10-2018		Site mix		M25		M25		Site Mix or RMC				
7811		22-10-2018		Site mix		M25		M25		Site Mix or RMC				
7812		23-10-2018		Site mix		M25		M25		Site Mix or RMC				
7813		23-10-2018		Rmc		M20		M20		Rmc				
7814		23-10-2018		Rmc		M20		M20		Rmc				
7815		24-10-2018		Rmc		M20		M20		Rmc				
7816		24-10-2018		Rmc		M20		M20		Rmc				
7817		24-10-2018		Rmc		M20		M20		Rmc				
7818		25-10-2018		Site mix		M25		M25		Site mix				
7819		26-10-2018		Rmc		M20		M20		Rmc				
7820		27-10-2018		Rmc		M20		M20		Rmc				
7821		27-10-2018		Rmc		M20		M20		Rmc				
No.	Date of casting	Specified Grade	Supplier / Contractor	D. C. No.	Block No. / Bungalow No.	Slab No. / Column	Slab No. / Column	Date of Testing	No. of days	Specified Strength	Tested Strength	Tested Strength	Avg. of three tests	Remarks
7809	21-10-2018	Rmc	Scpl		68	Feeding	18-11-18	28	20.0	470.0	20.9	20.7	20.7	
7810	22-10-2018	Site mix	Scpl		56	col	18-11-18	27	25.0	565.0	25.1	25.1	25.1	
7811	22-10-2018	Site mix	Scpl		92	col	18-11-18	27	25.0	570.0	25.3	25.3	25.3	
7812	23-10-2018	Site mix	Scpl		93	col	18-11-18	26	25.0	575.0	25.6	25.6	25.5	
7813	23-10-2018	Rmc	Ker		70	slab	18-11-18	26	20.0	460.0	20.4	20.4	20.4	
7814	23-10-2018	Rmc	Ker		79	slab	18-11-18	26	20.0	455.0	20.2	20.4	20.4	
7815	24-10-2018	Rmc	Scpl		57	slab	20-11-18	27	20.0	470.0	20.9	20.7	20.7	
7816	24-10-2018	Rmc	Scpl		35	Feeding	20-11-18	27	20.0	455.0	20.2	20.3	20.3	
7817	24-10-2018	Rmc	Tringathi		Club house	P.B.	20-11-18	27	20.0	465.0	20.7	20.6	20.6	
7818	25-10-2018	Site mix	Ker		71	col	20-11-18	26	25.0	565.0	25.1	25.1	25.2	
7819	26-10-2018	Rmc	Ker		72	Pinth	23-11-18	27	20.0	460.0	20.4	20.4	20.4	
7820	27-10-2018	Rmc	Ker		Apartment	slab	23-11-18	26	20.0	460.0	20.4	20.4	20.4	
7821	27-10-2018	Rmc	Scpl		53	Pinth	23-11-18	26	20.0	465.0	20.7	20.7	20.5	

7828	30-10-2018	Renc	M20	KSR		82	slab	3	23-11-18	28	20.0	460.0	20.4	20.5
											20.0	460.0	20.4	
7829	30-10-2018	Renc	M20	Sept		42	slab	1	8-11-18	9	14.0	320.0	14.2	
											14.0	325.0	14.4	14.3
											14.0	330.0	14.2	
7829	30-10-2018	Renc	M20	Sept		42	slab	1	23-11-18	28	20.0	465.0	20.7	
											20.0	470.0	20.9	20.7
											20.0	460.0	20.4	
7830	01-11-2018	Renc	M20	Repl		89	slab	1	8-11-18	7	14.0	320.0	14.2	
											14.0	325.0	14.4	14.4
7830	01-11-2018	Renc	M20	Repl		89	slab	1	23-11-18	26	20.0	455.0	20.2	
											20.0	470.0	20.9	20.6
											20.0	465.0	20.7	
7831	02-11-2018	Renc	M20	Repl		88	Pb		8-11-18	6	14.0	330.0	14.7	
											14.0	330.0	14.7	14.6
											14.0	335.0	14.4	
7831	02-11-2018	Renc	M20	Repl		88	Pb		30-11-18	28	20.0	465.0	20.7	
											20.0	470.0	20.9	20.7
											20.0	465.0	20.7	
7832	02-11-2018	Site mix	M25	KSR		69	col	2	10-11-18	8	17.5	405.0	18.0	
											17.5	400.0	17.8	18.0
											17.5	410.0	18.2	
7832	02-11-2018	Site mix	M25	KSR		69	col	2	30-11-18	28	25.0	575.0	25.6	
											25.0	570.0	25.3	25.3
											25.0	565.0	25.1	
7833	02-11-2018	Renc	M20	KSR		88	Pb		10-11-18	8	14.0	330.0	14.7	
											14.0	330.0	14.7	14.6
											14.0	335.0	14.4	
7833	02-11-2018	Renc	M20	KSR		88	Pb		30-11-18	28	20.0	465.0	20.7	
											20.0	470.0	20.9	20.7
											20.0	465.0	20.7	
7834	03-11-2018	Site mix	M25	Target										
7834	03-11-2018	Site mix	M25	Target										
7835	05-11-2018	Renc	M20	Sept		36	footing		13-11-18	8	14.0	320.0	14.2	
											14.0	325.0	14.4	14.5
											14.0	325.0	14.4	
7835	05-11-2018	Renc	M20	Sept		36	footing		4-12-18	29	20.0	460.0	20.4	
											20.0	455.0	20.2	20.3
											20.0	455.0	20.2	

7836	05-11-2018	Rmc	M20	Scpl		37	footing		13-11-18	8	14.0	320.0	14.2	
											14.0	320.0	14.4	
7836	05-11-2018	Rmc	M20	Scpl		37	footing		4-12-18	29	20.0	465.0	20.7	
											20.0	455.0	20.2	20.4
7837	05-11-2018	Rmc	M20	Scpl		45	slab	1	13-11-18	8	14.0	325.0	14.4	
											14.0	325.0	14.4	
7837	05-11-2018	Rmc	M20	Scpl		45	slab	1	4-12-18	29	20.0	460.0	20.4	
											20.0	465.0	20.7	
7838	05-11-2018	Site mix	M25	KSR		81	col	3	13-11-18	8	17.5	405.0	18.0	
											17.5	400.0	17.8	17.9
7838	05-11-2018	Site mix	M25	KSR		81	col	3	4-12-18	29	25.0	570.0	25.3	
											25.0	565.0	25.1	25.2
7839	06-11-2018	Rmc	M20	Scpl		56	slab	1	13-11-18	7	14.0	320.0	14.2	
											14.0	325.0	14.4	14.4
7839	06-11-2018	Rmc	M20	Scpl		56	slab	1	4-12-18	28	20.0	455.0	20.2	
											20.0	460.0	20.4	20.4
7840	06-11-2018	Rmc	M20	Scpl		Office build	slab	4	13-11-18	7	14.0	320.0	14.2	
											14.0	320.0	14.7	
7840	06-11-2018	Rmc	M20	Scpl		Office build	slab	4	4-12-18	28	20.0	470.0	20.9	
											20.0	460.0	20.4	20.7
7841	06-11-2018	Site mix	M25	Triganti		Apartment	col	5	13-11-18	7	17.5	405.0	18.0	
											17.5	400.0	17.8	17.9
7841	06-11-2018	Site mix	M25	Triganti		Apartment	col	5	4-12-18	28	25.0	570.0	25.3	
											25.0	565.0	25.1	25.2
7842	06-11-2018	Rmc	M20	KSR		75	Pb		13-11-18	7	14.0	325.0	14.4	
											14.0	325.0	14.4	14.5
7842	06-11-2018	Rmc	M20	KSR		75	Pb		4-12-18	28	20.0	465.0	20.7	
											20.0	460.0	20.4	20.6
7843	09-11-2018	Rmc	M20	Rcpl		87	Pb		18-11-18	9	14.0	320.0	14.2	
											14.0	325.0	14.4	14.4
7843	09-11-2018	Rmc	M20	Rcpl		87	Pb		8-12-18	29	20.0	455.0	20.2	
											20.0	460.0	20.4	20.4

7844	09-11-2018	Rnc	M20	Rcpl	86	Pb		18-11-18	9	140	320.0	14.2	
										140	325.0	14.4	14.3
7844	09-11-2018	Rnc	M20	Rcpl	86	Pb		8-12-18	29	20.0	465.0	20.7	
										20.0	460.0	20.4	20.6
										20.0	465.0	20.7	
7845	09-11-2018	Rnc	M20	Sepi	61	Pb		18-11-18	9	140	325.0	14.4	
										140	320.0	14.4	14.5
7845	09-11-2018	Rnc	M20	Sepi	61	Pb		8-12-18	29	20.0	470.0	20.9	
										20.0	465.0	20.7	20.7
										20.0	465.0	20.7	
7846	09-11-2018	Sis max	M25	Sepi	55	col	1	18-11-18	9	17.5	405.0	18.0	
										17.5	400.0	17.8	17.8
										17.5	395.0	17.6	
7846	09-11-2018	Sis max	M25	Sepi	55	col	1	8-12-18	29	25.0	570.0	25.3	
										25.0	560.0	25.1	25.3
										25.0	575.0	25.6	
7847	10-11-2018	Sis max	M25	Traqun	clubhouse	col	1	18-11-18	8	17.5	400.0	17.8	
										17.5	400.0	17.8	17.8
										17.5	400.0	17.8	
7847	10-11-2018	Sis max	M25	Traqun	clubhouse	col	1	8-12-18	28	25.0	570.0	25.3	
										25.0	560.0	25.1	25.4
										25.0	575.0	25.6	
7848	11-11-2018	Rnc	M20	Sepi	52	Pb		18-11-18	7	140	325.0	14.4	
										140	320.0	14.2	14.3
										140	320.0	14.2	
7848	11-11-2018	Rnc	M20	Sepi	52	Pb		8-12-18	27	20.0	460.0	20.4	
										20.0	455.0	20.3	20.3
										20.0	455.0	20.2	