

QC - Concrete Cube Testing Report														
Project Name:			SOVILP											
Report for Month:			August & September											
Prepared By:			Sami Kumar											
Date:			16-10-2018											
S. No.	Date of casting	Specified Grade of Concrete	Supplier / Contractor	D. C. No.	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength (Kilo-Newtons)	Tested Strength (N per sq. mm)	Avg. of three tests	Remarks
7736	21-08-2018	RMC	KSR		19	col	2	29-8-18	8	17.5	400.0	18.0	17.9	
7736	21-08-2018	RMC	KSR		19	col	2	18-9-18	28	25.0	570.0	25.3	25.5	
7737	22-08-2018	RMC	KSR		81	col	1	29-8-18	7	17.5	395.0	17.6	17.8	
7737	22-08-2018	RMC	KSR		81	col	1	18-9-18	27	25.0	570.0	25.3	25.2	
7738	22-08-2018	RMC	KSR		92	slabbeam		29-8-18	7	14.0	320.0	14.4	14.4	
7738	22-08-2018	RMC	KSR		92	slabbeam		18-9-18	27	20.0	465.0	20.7	20.4	
7739	23-08-2018	RMC	KSR		80	slabbeam		29-8-18	6	14.0	330.0	14.7	14.5	
7739	23-08-2018	RMC	KSR		80	slabbeam		18-9-18	26	20.0	470.0	20.9	20.8	
7740	24-08-2018	RMC	KSR		91	slabbeam		31-8-18	7	14.0	330.0	14.4	14.5	
7740	24-08-2018	RMC	KSR		91	slabbeam		20-9-18	27	20.0	470.0	20.9	20.7	
7741	25-08-2018	RMC	KSR		86	footings		5-9-18	7	14.0	325.0	14.4	14.3	
7741	25-08-2018	RMC	KSR		86	footings		26-9-18	28	20.0	470.0	20.9	20.9	

7742	29-08-2018	RMC	M20	RCTL		85	Rooming		5-2-18	7	140	325.9	144	
											140	330.0	147	145
											140	325.0	144	
7743	29-08-2018	RMC	M20	RCTL		85	Rooming		26-2-18	28	200	465.0	207	
											200	465.0	207	
											200	460.0	204	206
											200	460.0	204	
7744	29-08-2018	RMC	M20	KSR		74	Rooming		5-2-18	7	140	330.0	147	
											140	325.0	144	145
											140	325.0	144	
7745	29-08-2018	RMC	M20	KSR		74	Rooming		26-2-18	28	200	465.0	207	
											200	460.0	204	207
											200	460.0	204	
7746	02-09-2018	RMC	M25	RCTL		93	ed	2	10-2-18	8	175	465.0	180	
											175	395.0	178	175
											175	460.0	178	
7747	02-09-2018	RMC	M15	RCTL		90	ed	2	30-2-18	28	250	570.0	253	
											250	565.0	251	252
											250	565.0	251	
7748	03-09-2018	RMC	M20	KSR		82	ab	1	10-2-18	7	140	325.0	144	
											140	325.0	144	145
											140	325.0	144	
7749	03-09-2018	RMC	M20	KSR		82	ab	1	30-2-18	27	230	455.0	202	
											230	465.0	204	204
											230	460.0	204	
7750	04-09-2018	RMC	M20	RCTL		19	ab	2	10-2-18	6	140	330.0	147	
											140	325.0	144	145
											140	325.0	144	
7751	04-09-2018	RMC	M20	RCTL		19	ab	2	30-2-18	26	200	470.0	209	
											200	460.0	204	207
											200	465.0	207	
7752	04-09-2018	RMC	M20	RCTL		20	ab	2	10-2-18	6	140	330.0	147	
											140	325.0	144	145
											140	325.0	144	
7753	04-09-2018	RMC	M20	RCTL		20	ab	2	30-2-18	26	200	470.0	209	
											200	460.0	204	207
											200	465.0	207	
7754	04-09-2018	RMC	M20	RCTL		24	ab	3	10-2-18	6	140	330.0	147	
											140	325.0	144	146
											140	325.0	144	
7755	04-09-2018	RMC	M20	RCTL		24	ab	1	30-2-18	26	200	470.0	209	
											200	465.0	207	208
											200	465.0	207	
7756	04-09-2018	RMC	M20	KSR		77	fb		10-2-18	6	140	330.0	147	
											140	325.0	144	145
											140	325.0	144	

✓

7749	04-09-2018	RMC	M20	KSR		77	Pb		30-9-18	26	20.0	470.0	20.9	
											20.0	460.0	20.4	20.5
7750	04-09-2018	RMC	M20	SI infn			slab	2	10-9-18	6	14.0	315.0	14.4	
											14.0	310.0	14.0	14.4
											14.0	330.0	14.7	
7750	04-09-2018	RMC	M20	SI infn			slab	2	30-9-18	26	20.0	465.0	20.7	
											20.0	460.0	20.7	20.7
											20.0	470.0	20.9	
7751	04-09-2018	RMC	M20	RCTL		E7	footings		14-9-18	3	14.0	330.0	14.2	14.2
											14.0	315.0	14.0	
7751	04-09-2018	RMC	M20	RCTL		E7	footings		4-10-18	28	20.0	455.0	20.2	
											20.0	460.0	20.4	20.3
											20.0	450.0	20.1	
7752	06-09-2018	RMC	M20	RCTL		R8	footings		14-9-18	6	14.0	325.0	14.4	
											14.0	325.0	14.4	14.4
											14.0	320.0	14.2	
7753	06-09-2018	RMC	M20	RCTL		R8	footings		4-10-18	28	20.0	460.0	20.4	
											20.0	460.0	20.4	20.4
											20.0	460.0	20.4	
7753	07-09-2018	RMC	M20	SCPL		S9	slab/beam		14-9-18	7	14.0	330.0	14.2	
											14.0	325.0	14.4	14.3
											14.0	330.0	14.2	
7753	07-09-2018	RMC	M20	SCPL		S9	slab/beam		4-10-18	27	20.0	461.0	20.7	
											20.0	460.0	20.4	20.6
7754	08-09-2018	RMC	M20	KSR		F1	slab	1	15-9-18	7	14.0	325.0	14.4	
											14.0	320.0	14.2	14.3
											14.0	320.0	14.2	
7754	08-09-2018	RMC	M20	KSR		F1	slab	1	5-10-18	27	20.0	453.0	20.2	
											20.0	460.0	20.4	20.3
											20.0	455.0	20.2	
7755	10-09-2018	RMC	M20	KSR		E9	slab/beam		17-9-18	7	14.0	330.0	14.7	
											14.0	325.0	14.2	14.4
											14.0	325.0	14.4	
7755	10-09-2018	RMC	M20	KSR		E9	slab/beam		8-10-18	28	20.0	460.0	20.4	
											20.0	465.0	20.7	20.4
											20.0	450.0	20.2	
7756	10-09-2018	RMC	M20	SCPL		S8	slab/beam		17-9-18	7	14.0	330.0	14.2	
											14.0	325.0	14.4	14.3
											14.0	325.0	14.4	
7756	10-09-2018	RMC	M20	SCPL		S8	slab/beam		8-10-18	28	20.0	460.0	20.4	
											20.0	465.0	20.7	20.5
											20.0	460.0	20.4	
7757	11-09-2018	slab+col	M25	bequal		A8	col	3	18-9-18	7	17.5	395.0	17.6	
											17.5	400.0	17.8	17.7
											17.5	400.0	17.8	

7753	11-09-2018	RMG	M25	Signal	Ats	col	3	4-10-18	27	25.0	585.0	26.0	
										25.0	570.0	25.3	25.8
										25.0	585.0	26.0	
7754	12-09-2018	RMG	M20	FCPL	90	Northham		14-2-18	7	14.0	320.0	14.2	14.4
										14.0	320.0	14.2	
										14.0	320.0	14.2	
7756	12-09-2018	RMG	M20	FCPL	90	Northham		10-10-18	35	20.0	465.0	20.7	
										20.0	465.0	20.7	20.6
										20.0	465.0	20.7	
7759	12-09-2018	RMG	M20	KSR	79	ash	1	10-2-18	7	14.0	335.0	14.4	
										14.0	320.0	14.2	14.4
										14.0	320.0	14.2	
7759	12-09-2018	RMG	M20	KSR	79	ash	1	10-10-18	28	20.0	470.0	20.9	
										20.0	465.0	20.7	20.7
										20.0	465.0	20.7	
7760	15-09-2018	RMG	M20	SCPL	44	ash	1	22-2-18	7	14.0	330.0	14.4	
										14.0	325.0	14.4	
										14.0	325.0	14.4	
7760	15-09-2018	RMG	M20	SCPL	44	ash	1	13-10-18	28	20.0	450.0	20.7	
										20.0	450.0	20.7	20.8
										20.0	465.0	20.7	
7761	15-09-2018	RMG	M20	SCPL	17	ash	2	22-2-18	7	14.0	330.0	14.7	
										14.0	325.0	14.4	14.5
										14.0	325.0	14.4	
7761	15-09-2018	RMG	M20	SCPL	17	ash	2	13-10-18	28	20.0	450.0	20.7	
										20.0	450.0	20.7	
										20.0	465.0	20.7	
7762	15-09-2018	RMG	M20	SCPL	18	ash	2	22-2-18	7	14.0	330.0	14.2	
										14.0	325.0	14.4	14.3
										14.0	320.0	14.2	
7762	15-09-2018	RMG	M20	SCPL	18	ash	2	13-10-18	28	20.0	465.0	20.7	
										20.0	455.0	20.2	20.6
										20.0	470.0	20.9	
7763	15-09-2018	RMG	M20	SCPL	67	Booming		22-2-18	7	14.0	325.0	14.4	
										14.0	325.0	14.4	14.4
										14.0	325.0	14.4	
7763	15-09-2018	RMG	M20	SCPL	67	Booming		13-10-18	28	20.0	465.0	20.7	
										20.0	460.0	20.4	20.6
										20.0	465.0	20.7	

✓