

## Complaints And Suggestions from Paramount Avenue

 **Paramount Avenue** <info@modiproperties.com>

To: cr@modiproperties.com, feedback@modiproperties.com, kprasad@modiproperties.com, gbrambabu@modiproperties.com, pmr@modiproperties.com more...

kprasad@modipro.../Inbox

Sep 18 at 8:45 AM

Complaint Id : 5308

Project Name : Paramount Avenue

Block No / Phase : Phase II

Flat No/Villa : 115

Nature of complaint :Construction

Customer Name : Chiranjay Roy

Email : chiranjay.roy@gmail.com

Complaints :

1. Extreme Foul smell coming from all the drain pipe of Attach Bathroom, Common Bathroom, Hall wash Basin, utility and kitchen sink drain pipe
2. No water coming in RO water tank tap
3. RO water tank overflowing after water filled in full

## Note:

1. Please allow atleast two weeks for us to attend your complaint.
2. In general written response / reply to complaints shall not be given.
3. In case the complaint is not attended to for over two weeks customers are requested to send a reminder using the form given.

add vent pipe  
m  
19/9

pmr

file