

sohammodi@modiproperties.com

From: Paramount Avenue <paramount.avenue@gmail.com>
Sent: 25 07 2019 9:54 AM
To: soham modi; shirish modi
Cc: Krishna Prasad; Vinay K
Subject: Re: Water pipeline issue tower 27 Paramount Avenue - Reg

Dear Sir,

Greetings from Paramount Avenue..!!

With reference to the Mr. Vinay - 427 email; we also brought this issue to your notice during our meeting. However after your suggestions Mr. Shirish tried and attempted to fix the issues. But those are not giving results.

Tower No: 10, 12, 13, 27 & 28 etc are effected majorly (Tower No: 10 i.e 110, 210, 310.....810)

We request you to please treat this issue as emergency and provide the solution.

Thanks in advance,

With warm regards,

PAOA EC-Members

On Thu, Jul 25, 2019 at 8:15 AM Vinay K <vinay.kondaparthi@gmail.com> wrote:

Dear Sir,

This is with reference to my earlier mails on water pipeline issue in tower 27. Though some measures were taken by Mr Shirish by adjusting the valves but the situation is becoming worse day by day since the valve are adjusted frequently for various reasons.especially the problem started after introduction of interconnecting valve.

The purpose of interconnecting valve is to transfer water from A&B to C&D tanks and vice versa.unfortunately it's not used for that purpose and kept ON during water release time and the water is getting diverted to A&B also and the pressure is very less to the end towers and coming shorter duration. The reason for doing this may be anything but ultimately we are the suffering and every day we can't check valve positions to ensure water coming to our flats and even we don't have access to terrace. every day it's becoming very painful to wait in the morning & night by waiting whether are we get water or not and the rest others are getting the water at the same time.

I request you to kindly look into a permanent solution for this by providing a seperate tank for the last two towers atleast.i.e. tower 27 & 28 or by providing a direct line from the tank.

Request you to kindly do the needful otherwise it become very difficult to stay under the current situation and the only option left for me is to sell the flat or relocate as a tennet to other area. Hope you can understand the pain and request you to do the needful.

Thanks & Regards
Vinay Kumar
F.No D 427
9848980684

----- Forwarded message -----

From: **Vinay K** <vinay.kondaparthi@gmail.com>

Date: Thu 11 Jul, 2019, 6:48 PM

Subject: Water pipeline issue tower 27 Paramount Avenue - Reg

To: Krishna Prasad <xprasad@modiproperties.com>, shirish modi <shirish@modiproperties.com>, Paramount Avenue <paramount.avenue@gmail.com>

Dear sir,

This is with reference to my earlier mail regarding the pipeline issue.

Your site in charge shirish tried to rectify the issue by adjusting the valves and for few days it was ok but unfortunately the valve positions were disturbed frequently because of various reasons and for the past couple of days again we are facing non adequate supply of water.

We are getting only either of the sides especially in the evening hours and earlier I informed to your site engineers, the slope of pipeline was not maintained properly and to rectify it the supporting rod which was fixed was removed. However this is not resolving the issue..and water is not coming under low tank level & low pressure conditions.request you to kindly adjust the pipe line slope so that we will get the water in low pressure & low tank level situations..... request you to kindly do the needful.

Thanks & regards

Vinay Kumar K

F.No D427

sohammodi@modiproperties.com

From: Vinay K <vinay.kondaparthi@gmail.com>
Sent: 25 07 2019 8.15 AM
To: Krishna Prasad; shirish modi
Cc: sohammodi@modiproperties.com; Paramount Avenue
Subject: Fwd: Water pipeline issue tower 27 Paramount Avenue - Reg

Dear Sir,

This is with reference to my earlier mails on water pipeline issue in tower 27. Though some measures were taken by Mr Shirish by adjusting the valves but the situation is becoming worse day by day since the valve are adjusted frequently for various reasons.especially the problem started after introduction of interconnecting valve.

The purpose of interconnecting valve is to transfer water from A&B to C&D tanks and vice versa.unfortunately it's not used for that purpose and kept ON during water release time and the water is getting diverted to A&B also and the pressure is very less to the end towers and coming shorter duration. The reason for doing this may be anything but ultimately we are the suffering and every day we can't check valve positions to ensure water coming to our flats and even we don't have access to terrace. every day it's becoming very painful to wait in the morning & night by waiting whether are we get water or not and the rest others are getting the water at the same time.

I request you to kindly look into a permanent solution for this by providing a seperate tank for the last two towers atleast.i.e. tower 27 & 28 or by providing a direct line from the tank.

Request you to kindly do the needful otherwise it become very difficult to stay under the current situation and the only option left for me is to sell the flat or relocate as a tennet to other area. Hope you can understand the pain and request you to do the needful.

Thanks & Regards
Vinay Kumar
F.No D 427
9848980684

----- Forwarded message -----

From: Vinay K <vinay.kondaparthi@gmail.com>
Date: Thu 11 Jul, 2019, 6:48 PM
Subject: Water pipeline issue tower 27 Paramount Avenue - Reg
To: Krishna Prasad <kprasad@modiproperties.com>, shirish modi <shirish@modiproperties.com>, Paramount Avenue <paramount.avenue@gmail.com>

Dear sir,

This is with reference to my earlier mail regarding the pipeline issue.

Your site in charge shirish tried to rectify the issue by adjusting the valves and for few days it was ok but unfortunately the valve positions were disturbed frequently because of various reasons and for the past couple of days again we are facing non adequate supply of water.

We are getting only either of the sides especially in the evening hours and earlier I informed to your site engineers, the slope of pipeline was not maintained properly and to rectify it the supporting rod which was fixed was removed. However this is not resolving the issue..and water is not coming under low tank level & low pressure conditions.request you to kindly adjust the pipe line slope so that we will get the water in low pressure & low tank level situations..... request you to kindly do the needful.

Thanks & regards
Vinay Kumar K
F.No D427

sohammodi@modiproperties.com

From: Paramount Avenue <paramount.avenue@gmail.com>
Sent: 12 07 2019 9:38 AM
To: soham modi
Subject: Fwd: Water pipeline issue tower 27 Paramount Avenue - Reg

Dear Sir,

Request you to please go through the forwarded mail and do the needful.

Regards,

Soma Kiran Kumar

----- Forwarded message -----

From: Vinay K <vinay.kondaparthi@gmail.com>
Date: Thu, Jul 11, 2019 at 6:48 PM
Subject: Water pipeline issue tower 27 Paramount Avenue - Reg
To: Krishna Prasad <kprasad@modiproperties.com>, shirish modi <shirish@modiproperties.com>, Paramount Avenue <paramount.avenue@gmail.com>

Dear sir,

This is with reference to my earlier mail regarding the pipeline issue.

Your site in charge shirish tried to rectify the issue by adjusting the valves and for few days it was ok but unfortunately the valve positions were disturbed frequently because of various reasons and for the past couple of days again we are facing non adequate supply of water. We are getting only either of the sides especially in the evening hours and earlier I informed to your site engineers, the slope of pipeline was not maintained properly and to rectify it the supporting rod which was fixed was removed. However this is not resolving the issue..and water is not coming under low tank level & low pressure conditions.request you to kindly adjust the pipe line slope so that we will get the water in low pressure & low tank level situations..... request you to kindly do the needful.

Thanks & regards
Vinay Kumar K
F.No D427