

QC - Concrete Cube Testing Report.

Company: PMR II

Project: PMR-II

Report for Month: Mar, April & May-17

Prepared By: P.Sai Kumar

Date: 12-06-2017

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
3206	23-03-2017	Site mix	M25	Bikshapathi		C	Col	1	30-3-17	7	17.5	385.0	17.1	17.3	
											17.5	390.0	17.3		
											17.5	395.0	17.6		
3206	23-03-2017	Site mix	M25	Bikshapathi		C	Col	1	20-4-17	28	25.0	560.0	24.9	25.1	
											25.0	570.0	25.3		
											25.0	565.0	25.1		
3207	01-04-2017	Site mix	M25	Bikshapathi		D(25 to 28)fl	Col	4	9-4-17	8	17.5	395.0	17.6	17.4	
											17.5	385.0	17.1		
											17.5	395.0	17.6		
3207	01-04-2017	Site mix	M25	Bikshapathi		D(25 to 28)fl	Col	4	29-4-17	28	25.0	565.0	25.1	25.3	
											25.0	575.0	25.6		
											25.0	565.0	25.1		
3208	02-04-2017	Site mix	M25	Bikshapathi		D(22 to 24)fl	Col	4	9-4-17	7	17.5	395.0	17.6	17.5	
											17.5	390.0	17.3		
											17.5	395.0	17.6		
3208	02-04-2017	Site mix	M25	Bikshapathi		D(22 to 24)fl	Col	4	29-4-17	27	25.0	570.0	25.3	25.5	
											25.0	575.0	25.6		
											25.0	575.0	25.6		
3209	11-04-2017	RMC	M20	SL INFRA		C	Slab	1	19-4-17	8	14.0	345.0	15.3	14.8	
											14.0	330.0	14.7		
											14.0	325.0	14.4		
3209	11-04-2017	RMC	M20	SL INFRA		C	Slab	1	10-5-17	29	20.0	460.0	20.4	20.7	
											20.0	475.0	21.1		
											20.0	465.0	20.7		

3210	14-04-2017	Site mix	M25	Bikshapathi	C(19,20,21) f	Col	2	22-4-17	8	17.5	385.0	17.1	17.2	
										17.5	380.0	16.9		
										17.5	395.0	17.6		
3210	14-04-2017	Site mix	M25	Bikshapathi	C(19,20,21) f	Col	2	13-5-17	29	25.0	565.0	25.1	24.8	✓
										25.0	560.0	24.9		
										25.0	550.0	24.4		
3211	18-04-2017	Site mix	M25	Bikshapathi	C(15,16) fla	Col	2	26-4-17	8	17.5	390.0	17.3	17.3	
										17.5	380.0	16.9		
										17.5	395.0	17.6		
3211	18-04-2017	Site mix	M25	Bikshapathi	C(15,16) fla	Col	2	16-5-17	28	25.0	565.0	25.1	25.1	✓
										25.0	560.0	24.9		
										25.0	570.0	25.3		
3212	19-04-2017	RMC	M20	SL INFRA	D	Slab	4	26-4-17	7	14.0	335.0	14.9	14.7	✓
										14.0	330.0	14.7		
										14.0	325.0	14.4		
3212	19-04-2017	RMC	M20	SL INFRA	D	Slab	4	17-5-17	28	20.0	470.0	20.9	20.9	✓
										20.0	475.0	21.1		
										20.0	465.0	20.7		
3213	03-05-2017	Site mix	M25	Bikshapathi	D(26 to 28) f	Col	5	10-5-17	7	17.5	390.0	17.3	17.3	
										17.5	385.0	17.1		
										17.5	395.0	17.6		
3213	03-05-2017	Site mix	M25	Bikshapathi	D(26 to 28) f	Col	5	30-5-17	27	25.0	565.0	25.1	25.1	✓
										25.0	560.0	24.9		
										25.0	570.0	25.3		
3214	04-05-2017	Site mix	M25	Bikshapathi	D(22 to 25) f	Col	5	11-5-17	7	17.5	395.0	17.6	17.2	
										17.5	390.0	17.3		
										17.5	375.0	16.7		
3214	04-05-2017	Site mix	M25	Bikshapathi	D(22 to 25) f	Col	5	30-5-17	26	25.0	570.0	25.3	25.2	✓
										25.0	560.0	24.9		
										25.0	570.0	25.3		