

QC - Concrete Cube Testing Report.															
Company:		MRM LLP													
Project:		AGH MLG													
Report for Month:		Nov&Dec-19													
Prepared By:		Sunil Kumar													
Date:		06-01-2020													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
13567	22-09-2019	Site mix	M20	ashok		81	Slab	3	30-9-19	8	14.0 14.0 14.0	320.0 315.0 325.0	14.2 14.0 14.4	14.2	
13567	22-09-2019	Site mix	M20	ashok		81	Slab	3	21-10-19	29	20.0 20.0 20.0	465.0 460.0 455.0	20.7 20.4 20.2	20.4	
13568	23-09-2019	Site mix	M25	ashok		55	Col	2	30-9-19	7	17.5 17.5 17.5	395.0 400.0 400.0	17.6 17.8 17.8	17.7	
13568	23-09-2019	Site mix	M25	ashok		55	Col	2	21-10-19	28	25.0 25.0 25.0	570.0 565.0 570.0	25.3 25.1 25.3	25.3	
13569	25-09-2019	Site mix	M25	ashok		47	Col	1	3-10-19	8	17.5 17.5 17.5	390.0 395.0 400.0	17.3 17.6 17.8	17.6	
13569	25-09-2019	Site mix	M25	ashok		47	Col	1	25-10-19	30	25.0 25.0 25.0	565.0 565.0 570.0	25.1 25.1 25.3	25.2	
13570	28-09-2019	Site mix	M20	ashok		90	Slab	1	5-10-19	7	14.0 14.0 14.0	320.0 315.0 325.0	14.2 14.0 14.4	14.2	
13570	28-09-2019	Site mix	M20	ashok		90	Slab	1	25-10-19	27	20.0 20.0 20.0	465.0 460.0 455.0	20.7 20.4 20.2	20.4	
13571	29-09-2019	Site mix	M20	ashok		54	PB		7-10-19	8	14.0 14.0 14.0	320.0 320.0 325.0	14.2 14.2 14.4	14.3	
13571	29-09-2019	Site mix	M20	ashok		54	PB		25-10-19	26	20.0 20.0 20.0	455.0 460.0 460.0	20.2 20.4 20.4	20.4	

Certified by

[Signature]

Asst. Project Manager/Engineer
Modi Realty (Miryalaguda) LLP

13572	01-10-2019	Site mix	M20	ashok	68	Slab	1	10-10-19	9	14.0	320.0	14.2	
										14.0	315.0	14.0	14.2
										14.0	325.0	14.4	
13572	01-10-2019	Site mix	M20	ashok	68	Slab	1	31-10-19	30	20.0	455.0	20.2	
										20.0	460.0	20.4	20.3
										20.0	455.0	20.2	
13573	01-10-2019	Site mix	M25	ashok	Club House	Col	4	10-10-19	9	17.5	395.0	17.6	
										17.5	395.0	17.6	17.6
										17.5	400.0	17.8	
13573	01-10-2019	Site mix	M25	ashok	Club House	Col	4	31-10-19	30	25.0	570.0	25.3	
										25.0	565.0	25.1	25.3
										25.0	570.0	25.3	
13574	02-10-2019	Site mix	M20	ashok	52	PB		10-10-19	8	14.0	320.0	14.2	
										14.0	320.0	14.2	14.1
										14.0	315.0	14.0	
13574	02-10-2019	Site mix	M20	ashok	52	PB		31-10-19	29	20.0	455.0	20.2	
										20.0	460.0	20.4	20.3
										20.0	455.0	20.2	
13575	03-10-2019	Site mix	M20	ashok	83	Slab	2	10-10-19	7	14.0	320.0	14.2	
										14.0	315.0	14.0	14.2
										14.0	325.0	14.4	
13575	03-10-2019	Site mix	M20	ashok	83	Slab	2	31-10-19	28	20.0	460.0	20.4	
										20.0	460.0	20.4	20.4
										20.0	455.0	20.2	
13576	03-10-2019	Site mix	M25	ashok	90	Col	2	10-10-19	7	17.5	405.0	18.0	
										17.5	400.0	17.8	17.9
										17.5	400.0	17.8	
13576	03-10-2019	Site mix	M25	ashok	90	Col	2	31-10-19	28	25.0	575.0	25.6	
										25.0	570.0	25.3	25.4
										25.0	570.0	25.3	
13577	06-10-2019	Site mix	M20	ashok	47	Slab	1	15-10-19	9	14.0	320.0	14.2	
										14.0	325.0	14.4	14.3
										14.0	320.0	14.2	
13577	06-10-2019	Site mix	M20	ashok	47	Slab	1	4-11-19	29	20.0	460.0	20.4	
										20.0	460.0	20.4	20.5
										20.0	465.0	20.7	

Certified by

[Signature]

Asst. Project Manager/Engineer
Modi Realty (Miryalaguda) LLP

13578	07-10-2019	Site mix	M20	ashok		1	PB		15-10-19	8	14.0	320.0	14.2	
											14.0	325.0	14.4	14.4
											14.0	325.0	14.4	
13578	07-10-2019	Site mix	M20	ashok		1	PB		6-11-19	30	20.0	465.0	20.7	
											20.0	460.0	20.4	20.6
											20.0	465.0	20.7	
13579	11-10-2019	Site mix	M25	ashok		68	Col	2	21-10-19	10	17.5	405.0	18.0	
											17.5	400.0	17.8	17.8
											17.5	395.0	17.6	
13579	11-10-2019	Site mix	M25	ashok		68	Col	2	9-11-19	29	25.0	575.0	25.6	
											25.0	565.0	25.1	25.3
											25.0	570.0	25.3	
13580	13-10-2019	Site mix	M25	ashok		1	Col	1	20-10-19	7	17.5	400.0	17.8	
											17.5	400.0	17.8	17.7
											17.5	395.0	17.6	
13580	13-10-2019	Site mix	M25	ashok		1	Col	1	9-11-19	27	25.0	575.0	25.6	
											25.0	575.0	25.6	25.5
											25.0	570.0	25.3	
13581	15-10-2019	Site mix	M25	ashok		54	Col	1	24-10-19	9	17.5	395.0	17.6	
											17.5	400.0	17.8	17.6
											17.5	395.0	17.6	
13581	15-10-2019	Site mix	M25	ashok		54	Col	1	13-11-19	29	25.0	565.0	25.1	
											25.0	570.0	25.3	25.3
											25.0	570.0	25.3	
13582	16-10-2019	Site mix	M20	ashok		46	PB		24-10-19	8	14.0	320.0	14.2	
											14.0	325.0	14.4	14.2
											14.0	315.0	14.0	
13582	16-10-2019	Site mix	M20	ashok		46	PB		13-11-19	28	20.0	455.0	20.2	
											20.0	460.0	20.4	20.4
											20.0	465.0	20.7	
13583	17-10-2019	Site mix	M25	ashok		52	Col	1	24-10-19	7	17.5	400.0	17.8	
											17.5	405.0	18.0	17.8
											17.5	395.0	17.6	
13583	17-10-2019	Site mix	M25	ashok		52	Col	1	13-11-19	27	25.0	565.0	25.1	
											25.0	575.0	25.6	25.3
											25.0	570.0	25.3	

Certified by

Assl. Project Manager/Engineer
Modi Realty (Miryalaguda) LLP

13584	17-10-2019	Site mix	M20	asbok	55	Slab	2	24-10-19	7	14.0	315.0	14.0	14.2
										14.0	315.0	14.4	14.2
										14.0	320.0	14.2	
13584	17-10-2019	Site mix	M20	asbok	55	Slab	2	13-11-19	27	20.0	460.0	20.4	
										20.0	460.0	20.4	20.5
										20.0	465.0	20.7	
13585	21-10-2019	Site mix	M25	asbok	47	Col	2	28-10-19	7	17.5	400.0	17.8	
										17.5	400.0	17.8	17.7
										17.5	395.0	17.6	
13585	21-10-2019	Site mix	M25	asbok	47	Col	2	19-11-19	29	25.0	565.0	25.1	
										25.0	575.0	25.6	25.3
										25.0	570.0	25.3	
13586	23-10-2019	Site mix	M25	asbok	46	Col	1	31-10-19	8	17.5	400.0	17.8	
										17.5	405.0	18.0	17.8
										17.5	395.0	17.6	
13586	23-10-2019	Site mix	M25	asbok	46	Col	1	21-11-19	29	25.0	575.0	25.6	
										25.0	575.0	25.6	25.5
										25.0	570.0	25.3	
13587	25-10-2019	Site mix	M25	asbok	55	Col	3	2-11-19	8	17.5	395.0	17.6	
										17.5	400.0	17.8	17.6
										17.5	395.0	17.6	
13587	25-10-2019	Site mix	M25	asbok	55	Col	3	21-11-19	27	25.0	575.0	25.6	
										25.0	565.0	25.1	25.3
										25.0	570.0	25.3	
13588	26-10-2019	Site mix	M20	asbok	90	Slab	2	2-11-19	7	14.0	315.0	14.0	
										14.0	315.0	14.0	14.1
										14.0	320.0	14.2	
13588	26-10-2019	Site mix	M20	asbok	90	Slab	2	21-11-19	26	20.0	455.0	20.2	
										20.0	460.0	20.4	20.4
										20.0	460.0	20.4	
13589	26-10-2019	Site mix	M20	asbok	45	PB		2-11-19	7	14.0	320.0	14.2	
										14.0	325.0	14.4	14.2
										14.0	315.0	14.0	
13589	26-10-2019	Site mix	M20	asbok	45	PB		21-11-19	26	20.0	465.0	20.7	
										20.0	450.0	20.0	20.3
										20.0	455.0	20.2	

Certified by



Asst. Project Manager/Engineer
Modi Realty (Miryalaguda) LLP