

QC - Concrete Cube Testing Report.
 Company: MRM LLP
 Project: AGH MLG
 Report for Month: Dec&Jan-20
 Prepared By: Sunil Kumar
 Date: 06-02-2020

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-Newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
13590	28-10-2019	Site mix	M25	ashok		Club House	Col	5	5-11-19	8	17.5	400.0	17.8		
											17.5	400.0	17.8	17.7	
											17.5	395.0	17.6		
13590	28-10-2019	Site mix	M25	ashok		Club House	Col	5	27-11-19	30	25.0	575.0	25.6		
											25.0	570.0	25.3	25.4	
											25.0	570.0	25.3		
13591	31-10-2019	Site mix	M20	ashok		44	PB		7-11-19	7	14.0	320.0	14.2		
											14.0	315.0	14.0	14.1	
											14.0	320.0	14.2		
13591	31-10-2019	Site mix	M20	ashok		44	PB		27-11-19	27	20.0	460.0	20.4		
											20.0	450.0	20.0	20.2	
											20.0	455.0	20.2		
13592	31-10-2019	Site mix	M25	ashok		90	Col	3	7-11-19	7	17.5	395.0	17.6		
											17.5	395.0	17.6	17.7	
											17.5	405.0	18.0		
13592	31-10-2019	Site mix	M25	ashok		90	Col	3	27-11-19	27	25.0	575.0	25.6		
											25.0	565.0	25.1	25.3	
											25.0	570.0	25.3		
13593	01-11-2019	Site mix	M25	ashok		45	Col	1	9-11-19	8	17.5	400.0	17.8		
											17.5	395.0	17.6	17.6	
											17.5	395.0	17.6		
13593	01-11-2019	Site mix	M25	ashok		45	Col	1	27-11-19	26	25.0	565.0	25.1		
											25.0	565.0	25.1	25.2	
											25.0	570.0	25.3		
13594	03-11-2019	Site mix	M20	ashok		68	Slab	2	9-11-19	6	14.0	320.0	14.2		
											14.0	315.0	14.0	14.1	
											14.0	320.0	14.2		
13594	03-11-2019	Site mix	M20	ashok		68	Slab	2	30-11-19	27	20.0	455.0	20.2		
											20.0	460.0	20.4	20.3	
											20.0	455.0	20.2		

Certified by

[Signature]

Asst. Project Manager/Engineer
 Modi Realty (Miryalaguda) LLP

13595	04-11-2019	Site mix	M20	ashok		43	PB		13-11-19	9	14.0	325.0	14.4	
											14.0	315.0	14.0	14.2
											14.0	320.0	14.2	
13595	04-11-2019	Site mix	M20	ashok		43	PB		2-12-19	28	20.0	460.0	20.4	
											20.0	455.0	20.2	20.3
											20.0	455.0	20.2	
13596	04-11-2019	Site mix	M25	ashok		44	Col	I	13-11-19	9	17.5	400.0	17.8	
											17.5	395.0	17.6	17.7
											17.5	400.0	17.8	
13596	04-11-2019	Site mix	M25	ashok		44	Col	I	2-12-19	28	25.0	570.0	25.3	
											25.0	565.0	25.1	25.3
											25.0	570.0	25.3	
13597	06-11-2019	Site mix	M25	ashok		43	Col	I	13-11-19	7	17.5	405.0	18.0	
											17.5	395.0	17.6	17.8
											17.5	400.0	17.8	
13597	06-11-2019	Site mix	M25	ashok		43	Col	I	2-12-19	26	25.0	565.0	25.1	
											25.0	570.0	25.3	25.3
											25.0	570.0	25.3	
13598	06-11-2019	Site mix	M20	ashok		55	Slab	3	13-11-19	7	14.0	325.0	14.4	
											14.0	315.0	14.0	14.2
											14.0	320.0	14.2	
13598	06-11-2019	Site mix	M20	ashok		55	Slab	3	2-12-19	26	20.0	460.0	20.4	
											20.0	460.0	20.4	20.4
											20.0	455.0	20.2	
13599	08-11-2019	Site mix	M20	ashok		90	Slab	3	16-11-19	8	14.0	325.0	14.4	
											14.0	320.0	14.2	14.3
											14.0	320.0	14.2	
13599	08-11-2019	Site mix	M20	ashok		90	Slab	3	5-12-19	27	20.0	465.0	20.7	
											20.0	460.0	20.4	20.5
											20.0	460.0	20.4	
13600	08-11-2019	Site mix	M20	ashok		47	Slab	2	16-11-19	8	14.0	315.0	14.0	
											14.0	320.0	14.2	14.1
											14.0	320.0	14.2	
13600	08-11-2019	Site mix	M20	ashok		47	Slab	2	5-12-19	27	20.0	455.0	20.2	
											20.0	460.0	20.4	20.3
											20.0	455.0	20.2	

Certified by

Jak

Asst. Project Manager/Engineer
Modi Realty (Miryalaguda) LLP

13601	09-11-2019	file mlx	M20	aslock		68	Cool	3	16-11-19	7	17.5	400.0	17.8	
											17.5	395.0	17.6	17.7
											17.5	400.0	17.8	
13601	09-11-2019	file mlx	M20	aslock		68	Cool	3	5-12-19	26	25.0	565.0	25.1	25.2
											25.0	565.0	25.1	
											25.0	570.0	25.3	
13602	12-11-2019	file mlx	M20	aslock		42	PIB		19-11-19	7	14.0	315.0	14.0	14.2
											14.0	325.0	14.4	
											14.0	320.0	14.2	
13602	12-11-2019	file mlx	M20	aslock		42	PIB		12-12-19	30	20.0	460.0	20.4	
											20.0	455.0	20.2	20.4
											20.0	460.0	20.4	
13603	13-11-2019	file mlx	M20	aslock		Club House	Slab	5	19-11-19	6	14.0	325.0	14.4	14.5
											14.0	320.0	14.2	
											14.0	320.0	14.2	
13603	13-11-2019	file mlx	M20	aslock		Club House	Slab	5	12-12-19	29	20.0	460.0	20.4	20.5
											20.0	460.0	20.4	
											20.0	465.0	20.7	
13604	13-11-2019	file mlx	M20	aslock		47	Cool	3	19-11-19	6	17.5	395.0	17.6	17.6
											17.5	395.0	17.6	
											17.5	400.0	17.8	
13604	13-11-2019	file mlx	M20	aslock		47	Cool	3	12-12-19	29	25.0	565.0	25.1	25.2
											25.0	565.0	25.1	
											25.0	570.0	25.3	
13605	14-11-2019	file mlx	M20	aslock		85	Slab	1	22-11-19	8	14.0	320.0	14.2	14.1
											14.0	315.0	14.0	
											14.0	315.0	14.0	
13605	14-11-2019	file mlx	M20	aslock		85	Slab	1	12-12-19	28	20.0	460.0	20.4	20.4
											20.0	460.0	20.4	
											20.0	455.0	20.2	

Certified by

[Signature]

Aest. Project Manager/Engineer
Modi Realty (Miyagunda) LLP