

QC - Concrete Cube Testing Report															
Company:		MRM LLP													
Project:		AGH MLO													
Report for Month:		Jan&Feb-20													
Prepared By:		Sumi Kumar													
Date:		07-03-2020													
S. No.	Date of casting	Site Mix or JMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No.	Block No. / Framing No.	Used for Slab / Column	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Subsequent to 28 days	Tested Strength 7 days	Avg. of three tests	Remarks
13606	15-11-2019	Site mix	M20	ashok		68	Slab	3	22-11-19	7	14.0 14.0 14.0	315.0 325.0 320.0	14.0 14.4 14.2	14.2	
13606	15-11-2019	Site mix	M20	ashok		68	Slab	3	12-12-19	27	20.0 20.0 20.0	460.0 460.0 465.0	20.4 20.4 20.7	20.5	
13607	18-11-2019	Site mix	M20	ashok		69	Slab	1	26-11-19	8	14.0 14.0 14.0	325.0 320.0 320.0	14.4 14.2 14.2	14.3	
13607	18-11-2019	Site mix	M20	ashok		69	Slab	1	18-12-19	30	20.0 20.0 20.0	455.0 460.0 460.0	20.2 20.4 20.4	20.4	
13608	18-11-2019	Site mix	M20	ashok		ClubHouse	Slab	6	26-11-19	8	14.0 14.0 14.0	325.0 320.0 325.0	14.4 14.2 14.4	14.4	
13608	18-11-2019	Site mix	M20	ashok		ClubHouse	Slab	6	18-12-19	30	20.0 20.0 20.0	465.0 465.0 460.0	20.7 20.7 20.4	20.6	
13609	18-11-2019	Site mix	M25	ashok		ClubHouse	Col	7	26-11-19	8	17.5 17.5 17.5	400.0 395.0 400.0	17.8 17.6 17.8	17.7	
13609	18-11-2019	Site mix	M25	ashok		ClubHouse	Col	7	18-12-19	30	25.0 25.0 25.0	570.0 575.0 570.0	25.3 25.6 25.3	25.4	
13610	19-11-2019	Site mix	M25	ashok		85	Col	2	26-11-19	7	17.5 17.5 17.5	395.0 395.0 400.0	17.6 17.6 17.8	17.6	
13610	19-11-2019	Site mix	M25	ashok		85	Col	2	18-12-19	29	25.0 25.0 25.0	570.0 565.0 570.0	25.3 25.1 25.3	25.3	
13611	21-11-2019	Site mix	M20	ashok		89	Slab	1	28-11-19	7	14.0 14.0 14.0	325.0 315.0 320.0	14.4 14.0 14.2	14.2	

Certified by

John

Asst. Project Manager/Engineer
Modi Realty (Miryalaguda) LLP

13619	29-11-2019	Site mix	M20	ashok		24	PB		6-12-19	7	14.0	320.0	14.2	
											14.0	325.0	14.4	14.3
											14.0	320.0	14.2	
13619	29-11-2019	Site mix	M20	ashok		24	PB		27-12-19	28	20.0	460.0	20.4	
											20.0	455.0	20.2	20.4
											20.0	460.0	20.4	
13620	30-11-2019	Site mix	M25	ashok		43	Col	2	6-12-19	6	17.5	395.0	17.6	
											17.5	395.0	17.6	17.6
											17.5	400.0	17.8	
13620	30-11-2019	Site mix	M25	ashok		43	Col	2	27-12-19	27	25.0	570.0	25.3	
											25.0	565.0	25.1	25.2
											25.0	565.0	25.1	
13621	02-12-2019	Site mix	M20	ashok		85	Slab	2	10-12-19	8	14.0	320.0	14.2	
											14.0	315.0	14.0	14.1
											14.0	320.0	14.2	
13621	02-12-2019	Site mix	M20	ashok		85	Slab	2	30-12-19	28	20.0	455.0	20.2	
											20.0	455.0	20.2	20.3
											20.0	460.0	20.4	
13622	03-12-2019	Site mix	M20	ashok		89	Slab	2	10-12-19	7	14.0	320.0	14.2	
											14.0	325.0	14.4	14.3
											14.0	320.0	14.2	
13622	03-12-2019	Site mix	M20	ashok		89	Slab	2	30-12-19	27	20.0	465.0	20.7	
											20.0	465.0	20.7	20.6
											20.0	460.0	20.4	
13623	05-12-2019	Site mix	M20	ashok		Club House	Slab	7	13-12-19	8	14.0	320.0	14.2	
											14.0	325.0	14.4	14.4
											14.0	330.0	14.7	
13623	05-12-2019	Site mix	M20	ashok		Club House	Slab	7	2-1-20	28	20.0	465.0	20.7	
											20.0	465.0	20.7	20.7
											20.0	470.0	20.9	
13624	05-12-2019	Site mix	M25	ashok		19	Col	1	13-12-19	8	17.5	400.0	17.8	
											17.5	405.0	18.0	17.9
											17.5	400.0	17.8	
13624	05-12-2019	Site mix	M25	ashok		19	Col	1	2-1-20	28	25.0	575.0	25.6	
											25.0	570.0	25.3	25.5
											25.0	575.0	25.6	
13625	06-12-2019	Site mix	M25	ashok		89	Col	3	13-12-19	7	17.5	400.0	17.8	
											17.5	395.0	17.6	17.7
											17.5	400.0	17.8	
13625	06-12-2019	Site mix	M25	ashok		89	Col	3	2-1-20	27	25.0	575.0	25.6	
											25.0	565.0	25.1	25.3
											25.0	570.0	25.3	

Certified by

Jale

Asst. Project Manager/Engineer
Modi Realty (Miryalaguda) LLP