

QC - Concrete Cube Testing Report.															
Company:		MRMa (LLP)													
Project:		GMR													
Report for Month:		Feb to Jun-2020													
Prepared By:		Sunil Kumar													
Date:		06-07-2020													
S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
16032	12-01-2020	RMC	M20	SCPL		A(3,4,6,7,8)	Slab	1	17-1-20	7	14.0	325.0	14.4		
											14.0	320.0	14.2	14.3	
											14.0	320.0	14.2		
16032	12-01-2020	RMC	M20	SCPL		A(3,4,6,7,8)	Slab	1	10-2-20	29	20.0	460.0	20.4		
											20.0	465.0	20.7	20.6	
											20.0	465.0	20.7		
16033	13-01-2020	RMC	M25	SSVC		B(3,4,5,6)	Col	1	17-1-20	7	17.5	405.0	18.0		
											17.5	405.0	18.0	17.9	
											17.5	400.0	17.8		
16033	13-01-2020	RMC	M25	SSVC		B(3,4,5,6)	Col	1	10-2-20	28	25.0	580.0	25.8		
											25.0	585.0	26.0	25.9	
											25.0	585.0	26.0		
16034	14-01-2020	RMC	M25	SCPL		A(3,4,5,6,7)	Col	1	17-1-20	7	17.5	405.0	18.0		
											17.5	400.0	17.8	17.9	
											17.5	405.0	18.0		
16034	14-01-2020	RMC	M25	SCPL		A(3,4,5,6,7)	Col	1	10-2-20	27	25.0	575.0	25.6		
											25.0	575.0	25.6	25.6	
											25.0	580.0	25.8		
16035	27-01-2020	RMC	M20	SSVC		B(2,3,4,5,6)	Slab-02		4-2-20	7	14.0	325.0	14.4		
											14.0	320.0	14.2	14.3	
											14.0	320.0	14.2		
16035	27-01-2020	RMC	M20	SSVC		B(2,3,4,5,6)	Slab-02		24-2-20	28	20.0	460.0	20.4		
											20.0	465.0	20.7	20.6	
											20.0	465.0	20.7		
16036	01-02-2020	RMC	M25	SCPL		A(2,8,9,1)	Col	1	7-2-20	7	17.5	405.0	18.0		
											17.5	400.0	17.8	17.8	
											17.5	395.0	17.6		
16036	01-02-2020	RMC	M25	SCPL		A(2,8,9,1)	Col	1	28-2-20	27	25.0	580.0	25.8		
											25.0	575.0	25.6	25.6	
											25.0	570.0	25.3		
16037	10-02-2020	RMC	M25	SSVC		B(3,4,5,6)	Col	3	7-2-20	7	17.5	405.0	18.0		
											17.5	400.0	17.8	17.9	
											17.5	405.0	18.0		

16037	10-02-2020	RMC	M25	SSVC	B(3,4,5,6)	Col	3	28-2-20	18	25.0	585.0	26.0		
										25.0	575.0	25.6	25.8	
										25.0	580.0	25.8		
16038	15-02-2020	Site Mix	M25	SSVC	B(1,2,7,8)	Col	3	22-2-20	7	17.5	395.0	17.6		
										17.5	400.0	17.8	17.6	
										17.5	395.0	17.6		
16038	15-02-2020	Site Mix	M25	SSVC	B(1,2,7,8)	Col	3	13-3-20	27	25.0	570.0	25.3		
										25.0	570.0	25.3	25.3	
										25.0	565.0	25.1		
16039	13-03-2020	RMC	M20	SSVC	B(1,2,6,7,8)	Slab	3	20-3-20	7	14.0	325.0	14.4		
										14.0	320.0	14.2	14.4	
										14.0	330.0	14.7		
16041	24-05-2020	RMC	M25	SCPL	A(2,3,4,6)	Col	2	1-6-20	7	17.5	405.0	18.0		
										17.5	400.0	17.8	17.9	
										17.5	400.0	17.8		
16041	24-05-2020	RMC	M25	SCPL	A(2,3,4,6)	Col	2	20-6-20	27	25.0	575.0	25.6		
										25.0	575.0	25.6	25.5	
										25.0	570.0	25.3		
16042	30-05-2020	RMC	M20	SCPL	A(1,9)	Slab	2	6-6-20	7	14.0	325.0	14.4		
										14.0	320.0	14.2	14.4	
										14.0	330.0	14.7		
16042	30-05-2020	RMC	M20	SCPL	A(1,9)	Slab	2	27-6-20	28	20.0	470.0	20.9		
										20.0	465.0	20.7	20.7	
										20.0	465.0	20.7		
16043	01-06-2020	RMC	M25	SSVC	B(4,7)	Col	4	6-6-20	7	17.5	410.0	18.2		
										17.5	410.0	18.2	18.1	
										17.5	405.0	18.0		
16043	01-06-2020	RMC	M25	SSVC	B(4,7)	Col	4	28-6-20	27	25.0	585.0	26.0		
										25.0	575.0	25.6	25.8	
										25.0	580.0	25.8		
16044	10-06-2020	RMC	M25	SCPL	A(7,3)	Col	3	17-6-20	7	17.5	410.0	18.2		
										17.5	405.0	18.0	18.1	
										17.5	405.0	18.0		
16044	10-06-2020	RMC	M25	SCPL	A(7,3)	Col	3	7-7-20	27	25.0	585.0	26.0		
										25.0	585.0	26.0	26.1	
										25.0	590.0	26.2		