

QC - Concrete Cube Testing Report															
Company:	Kajati Estates														
Project:	Nigeti Homes-II														
Report for Month:	Jun & Jul 16														
Prepared By:	SS Sami Kumar														
Date:	09-09-2016														
S No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier : Contractor	D. C. No	Block No. / Bungalow No	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength In N per sq. mm	Avg. of three tests	Remarks
5544	09-06-2016	Site Mix	M25	Amrad		78	col	1	16-6-16	(7)	17.5	395.0	17.6	17.6	✓
											17.5	400.0	17.8	17.6	
											17.5	390.0	17.3		
5544	09-06-2016	Site Mix	M25	Amrad		78	col	1	5-7-16	(20)	25.0	575.0	25.6	25.0	✓
											25.0	585.0	26.0	25.9	
											25.0	590.0	26.2		
5546	09-06-2016	Site Mix	M20	Amrad		1	Plinthbeam		17-6-16	(8)	14.0	355.0	15.8	15.3	✓
											14.0	340.0	15.1	15.3	
											14.0	335.0	14.9		
5546	09-06-2016	Site Mix	M20	Amrad		1	Plinthbeam		5-7-16	(20)	20.0	475.0	21.1	21.1	✓
											20.0	490.0	21.8	21.4	
											20.0	480.0	21.3		
5547	09-06-2016	Site Mix	M20	Amrad		2	Plinthbeam		17-6-16	(8)	14.0	355.0	15.8	15.4	✓
											14.0	340.0	15.1	15.4	
											14.0	315.0	15.3		
5547	09-06-2016	Site Mix	M20	Amrad		2	Plinthbeam		5-7-16	(20)	20.0	490.0	21.8	21.4	✓
											20.0	475.0	21.1	21.4	
											20.0	480.0	21.3		
5548	09-06-2016	Site Mix	M25	Amrad		20	col	1	16-6-16	(7)	17.5	395.0	17.6	17.3	✓
											17.5	385.0	17.1	17.3	
											17.5	390.0	17.3		
5548	09-06-2016	Site Mix	M25	Amrad		20	col	1	5-7-16	(20)	25.0	580.0	25.6	25.7	✓
											25.0	585.0	26.0	25.7	
											25.0	570.0	25.3		
5549	10-06-2016	Site Mix	M25	Amrad		3	col	1	16-6-16	(9)	17.5	395.0	17.6	17.6	✓
											17.5	385.0	17.6	17.6	
											17.5	390.0	17.6		
5549	10-06-2016	Site Mix	M25	Amrad		3	col	1	8-7-16	(28)	25.0	595.0	26.4	26.1	✓
											25.0	585.0	26.0	26.1	
											25.0	580.0	26.0	26.1	

12/9/16

5550	11-06-2016	Site Mix	M20	Arand	3	Punibeam	17-6-16	(6)	140	355.0	13.8	15.6	✓
									140	350.0	15.6	15.6	
									140	345.0	15.3		
5550	11-06-2016	Site Mix	M20	Arand	3	Punibeam	9-7-16	(28)	200	495.0	22.0		✓
									200	475.0	21.1	21.5	
									200	480.0	21.3		
5551	11-06-2016	Site Mix	M20	Arand	48	Punibeam	17-6-16	(6)	140	360.0	16.0		✓
									140	350.0	15.6	15.7	
									140	350.0	15.6		
5551	11-06-2016	Site Mix	M20	Arand	48	Punibeam	9-7-16	(28)	200	490.0	21.8		✓
									200	490.0	21.8	21.6	
									200	480.0	21.3		
5552	11-06-2016	Site Mix	M25	Arand	15	col	18-6-16	(7)	175	385.0	17.1		✓
									175	395.0	17.6	17.6	
									175	405.0	18.0		
5552	11-06-2016	Site Mix	M25	Arand	15	col	8-7-16	(27)	250	595.0	26.4		✓
									250	590.0	26.2	26.2	
									250	585.0	26.0		
5556	11-06-2016	Site Mix	M25	Arand	2	col	21-6-16	(7)	175	385.0	17.1		✓
									175	395.0	17.6	17.6	
									175	405.0	18.0		
5556	11-06-2016	Site Mix	M25	Arand	2	col	13-7-16	(29)	250	585.0	26.0		✓
									250	590.0	26.2	26.1	
									250	585.0	26.0		
5557	11-06-2016	Site Mix	M20	Arand	19	Punibeam	21-6-16	(7)	140	345.0	16.3		✓
									140	350.0	16.6	15.5	
									140	350.0	16.6		
5557	11-06-2016	Site Mix	M20	Arand	49	Punibeam	13-7-16	(29)	200	495.0	22.0		✓
									200	490.0	21.8	21.7	
									200	480.0	21.3		
5558	11-06-2016	Site Mix	M20	Arand	50	Punibeam	21-6-16	(7)	140	345.0	16.3		✓
									140	350.0	16.6	15.3	
									140	350.0	16.6		
5558	11-06-2016	Site Mix	M20	Arand	50	Punibeam	12-7-16	(28)	200	485.0	21.6		✓
									200	485.0	21.6	21.3	
									200	475.0	21.1		
5560	11-06-2016	Site Mix	M20	Arand	58	col	11-9-16	(7)	175	385.0	17.1		✓
									175	395.0	17.6	17.6	
									175	405.0	18.0		
5570	11-06-2016	Site Mix	M20	Arand	68	col	13-7-16	(29)	250	570.0	25.3		

5560	15-06-2016	Site Mix	M25	Around		69	col	1	21-6-16	(6)	25.0	575.0	25.6	25.6	✓
											25.0	585.0	26.0		
											17.5	385.0	17.1		
											17.5	395.0	17.6	17.5	✓
											17.5	400.0	17.8		
5561	15-06-2016	Site Mix	M25	Around		69	col	1	13-7-16	(28)	25.0	590.0	26.2		✓
											25.0	595.0	26.0	26.1	
											25.0	585.0	26.0		
5561	15-06-2016	Site Mix	M25	Around		70	col	1	21-6-16	(6)	17.5	395.0	17.6		✓
											17.5	390.0	17.3	17.6	
											17.5	405.0	18.0		
5561	15-06-2016	Site Mix	M25	Around		70	col	1	13-7-16	(28)	25.0	590.0	26.2		✓
											25.0	590.0	26.2	26.3	
											25.0	595.0	26.4		
5562	17-06-2016	Site Mix	M20	Around		77	slab	1	25-6-16	(8)	14.0	345.0	15.3		✓
											14.0	340.0	15.1	15.2	
											14.0	350.0	15.6		
5562	17-06-2016	Site Mix	M20	Around		77	slab	1	15-7-16	(29)	20.0	475.0	21.1		✓
											20.0	485.0	21.6	21.3	
											20.0	475.0	21.1		
5563	17-06-2016	Site Mix	M20	Around		78	slab	1	25-6-16	(8)	14.0	355.0	15.8		✓
											14.0	340.0	15.1	15.5	
											14.0	350.0	15.6		
5563	17-06-2016	Site Mix	M20	Around		78	slab	1	15-7-16	(29)	20.0	490.0	21.8		✓
											20.0	485.0	21.6	21.6	
											20.0	480.0	21.3		
5564	19-06-2016	Site Mix	M25	Around		35	col	1	26-6-16	(7)	12.5	360.0	17.6		✓
											17.5	390.0	17.3	17.7	
											17.5	405.0	18.0		
5564	19-06-2016	Site Mix	M25	Around		35	col	1	16-7-16	(27)	25.0	570.0	25.3		✓
											25.0	585.0	26.0	26.0	
											25.0	575.0	25.0		
5565	19-06-2016	Site Mix	M20	Around		15	slab	1	26-6-16	(3)	14.0	340.0	15.1		✓
											14.0	350.0	15.6	15.3	
5565	19-06-2016	Site Mix	M20	Around		15	slab	1	16-7-16	(27)	20.0	485.0	21.0		✓
											20.0	480.0	20.8	21.2	
											20.0	480.0	21.3		
5566	21-06-2016	Site Mix	M25	Around		8	col	1	26-6-16	(6)	17.5	400.0	17.8		✓
											17.5	390.0	17.3	17.6	

[illegible]

5574	23-06-2016	Site Mix	M25	Arand	37	col	1	30.6-16	(7)	17.5	490.0	17.8	✓
										17.5	390.0	17.3	17.7
										17.5	405.0	18.0	
5574	23-06-2016	Site Mix	M25	Arand	37	col	1	22.7-16	(29)	25.0	570.0	25.3	✓
										25.0	565.0	25.1	25.4
										25.0	580.0	25.8	
5576	24-06-2016	Site Mix	M25	Arand	19	col	1	2-7-16	(8)	17.5	390.0	17.3	✓
										17.5	405.0	18.0	17.8
										17.5	405.0	18.0	
5576	24-06-2016	Site Mix	M25	Arand	19	col	1	22-7-16	(28)	25.0	585.0	26.0	✓
										25.0	580.0	25.8	25.9
										25.0	580.0	25.8	
5577	24-06-2016	Rmc	M20	SI Infa	clubhouse	slab	2	3-7-16	(9)	14.0	360.0	16.0	✓
										14.0	345.0	15.3	15.6
										14.0	350.0	15.6	
5577	24-06-2016	Rmc	M20	SI Infa	clubhouse	slab	2	22-7-16	(28)	20.0	485.0	21.6	✓
										20.0	480.0	21.3	21.4
										20.0	480.0	21.3	