

OC - Concrete Cube Testing Report

Company: Nigiri Estates

Project: Nigiri Homes-II

Report for Month: Oct & Nov-17

Prepared By: P. Sai Kumar

Date: 09-12-2017

Handwritten signature/initials

S. No.	Date of casting	Site Mix or RMC	Specified Grade of Concrete	Supplier / Contractor	D. C. No	Block No. / Bungalow No.	Used for Slab / Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo-newtons	Tested Strength in N per sq. mm	Avg. of three tests	Remarks
5877	14-10-2017	Site Mix	M20	Anand		111	slab	1	10-11-17	27	20.0	475.0	21.1	20.8	
											20.0	470.0	20.9		
											20.0	460.0	20.4		
5878	14-10-2017	Site Mix	M25	Anand		112	col	2	10-11-17	27	25.0	575.0	25.6	25.3	
											25.0	565.0	25.1		
											25.0	570.0	25.3		
5879	16-10-2017	Site Mix	M25	Anand		80B	col	2	12-11-17	27	25.0	570.0	25.3	25.5	
											25.0	575.0	25.6		
											25.0	575.0	25.6		
5880	16-10-2017	Site Mix	M20	Anand		80D	slab	1	12-11-17	27	20.0	465.0	20.7	20.4	
											20.0	455.0	20.2		
											20.0	460.0	20.4		
5881	17-10-2017	Site Mix	M20	Anand		82	slab	1	24-10-17	7	14.0	325.0	14.4	14.5	
											14.0	325.0	14.4		
											14.0	330.0	14.7		
5881	17-10-2017	Site Mix	M20	Anand		82	slab	1	12-11-17	26	20.0	460.0	20.4	20.4	
											20.0	455.0	20.2		
											20.0	460.0	20.4		
5882	20-10-2017	Site Mix	M25	Anand		133	col	1	27-10-17	7	17.5	400.0	17.8	17.9	
											17.5	405.0	18.0		
											17.5	400.0	17.8		
5882	20-10-2017	Site Mix	M25	Anand		133	col	1	16-11-17	27	25.0	570.0	25.3	25.4	
											25.0	565.0	25.1		
											25.0	580.0	25.8		
5883	20-10-2017	Site Mix	M20	Anand		166	slab	1	27-10-17	7	14.0	325.0	14.4	14.3	
											14.0	325.0	14.4		
											14.0	315.0	14.0		
5883	20-10-2017	Site Mix	M20	Anand		166	slab	1	16-11-17	27	20.0	475.0	21.1	20.6	
											20.0	455.0	20.2		

5884	20-10-2017	Site Mix	M20	Anand	167	slab	1	27-10-17	7	20.0	460.0	20.4	
										14.0	330.0	14.7	
										14.0	325.0	14.4	14.4
										14.0	320.0	14.2	
5884	20-10-2017	Site Mix	M20	Anand	167	slab	1	16-11-17	27	20.0	475.0	21.1	
										20.0	475.0	21.1	20.9
										20.0	460.0	20.4	
5885	24-10-2017	Site Mix	M25	Anand	166	col	2	1-11-17	8	17.5	395.0	17.6	
										17.5	405.0	18.0	17.8
										17.5	400.0	17.8	
5885	24-10-2017	Site Mix	M25	Anand	166	col	2	21-11-17	28	25.0	565.0	25.1	
										25.0	570.0	25.3	25.3
										25.0	575.0	25.6	
5886	25-10-2017	Site Mix	M25	Anand	167	col	2	1-11-17	7	17.5	400.0	17.8	
										17.5	405.0	18.0	17.9
										17.5	400.0	17.8	
5886	25-10-2017	Site Mix	M25	Anand	167	col	2	21-11-17	27	25.0	580.0	25.8	
										25.0	565.0	25.1	25.6
										25.0	580.0	25.8	
5887	26-10-2017	Site Mix	M20	Anand	85	slab	2	1-11-17	6	14.0	335.0	14.9	
										14.0	330.0	14.7	14.7
										14.0	330.0	14.7	
5887	26-10-2017	Site Mix	M20	Anand	85	slab	2	21-11-17	26	20.0	465.0	20.7	
										20.0	465.0	20.7	20.6
										20.0	460.0	20.4	
5888	26-10-2017	Site Mix	M20	Anand	86	slab	2	1-11-17	6	14.0	325.0	14.4	
										14.0	330.0	14.7	14.4
										14.0	320.0	14.2	
5888	26-10-2017	Site Mix	M20	Anand	86	slab	2	21-11-17	26	20.0	475.0	21.1	
										20.0	470.0	20.9	20.7
										20.0	455.0	20.2	
5889	26-10-2017	Site Mix	M20	Anand	87	slab	2	1-11-17	6	14.0	335.0	14.9	
										14.0	330.0	14.7	14.7
										14.0	325.0	14.4	
5889	26-10-2017	Site Mix	M20	Anand	87	slab	2	21-11-17	26	20.0	460.0	20.4	
										20.0	470.0	20.9	20.6
										20.0	460.0	20.4	
5890	26-10-2017	Site Mix	M20	Anand	88	slab	2	1-11-17	6	14.0	325.0	14.4	

5890	26-10-2017	Site Mix	M20	Anand	88	slab	2	21-11-17	26	14.0	330.0	14.7	14.5
										14.0	325.0	14.4	
5891	27-10-2017	Site Mix	M25	Anand	90	col	1	3-11-17	7	17.5	405.0	18.0	
										17.5	405.0	18.0	18.1
										17.5	410.0	18.2	
5891	27-10-2017	Site Mix	M25	Anand	90	col	1	24-11-17	28	25.0	575.0	25.6	
										25.0	565.0	25.1	25.3
										25.0	570.0	25.3	
5892	27-10-2017	Site Mix	M25	Anand	110	col	1	3-11-17	7	17.5	395.0	17.6	
										17.5	400.0	17.8	17.7
										17.5	400.0	17.8	
5892	27-10-2017	Site Mix	M25	Anand	110	col	1	24-11-17	28	25.0	570.0	25.3	
										25.0	575.0	25.6	25.6
										25.0	580.0	25.8	
5893	28-10-2017	Site Mix	M20	Anand	134	slab	1	3-11-17	6	14.0	325.0	14.4	
										14.0	330.0	14.7	14.5
										14.0	325.0	14.4	
5893	28-10-2017	Site Mix	M20	Anand	134	slab	1	24-11-17	27	20.0	470.0	20.9	
										20.0	450.0	20.0	20.4
										20.0	455.0	20.2	
5894	28-10-2017	Site Mix	M20	Anand	137	slab	1	3-11-17	6	14.0	330.0	14.7	
										14.0	330.0	14.7	14.7
										14.0	335.0	14.9	
5894	28-10-2017	Site Mix	M20	Anand	137	slab	1	24-11-17	27	20.0	465.0	20.7	
										20.0	455.0	20.2	20.4
										20.0	460.0	20.4	
5895	28-10-2017	Site Mix	M20	Anand	144	footings		3-11-17	6	14.0	325.0	14.4	
										14.0	330.0	14.7	14.6
										14.0	330.0	14.7	
5895	28-10-2017	Site Mix	M20	Anand	144	footings		24-11-17	27	20.0	475.0	21.1	
										20.0	470.0	20.9	20.8
										20.0	460.0	20.4	
5896	28-10-2017	Site Mix	M25	Anand	89	col	1	3-11-17	6	17.5	410.0	18.2	
										17.5	400.0	17.8	18.0
										17.5	405.0	18.0	