

Concrete Cube Testing Report

Project: Nijm Homen II

Report for Month: June July & Aug 17

Prepared By: P. Sri Kumar

Date: 08-09-2017

Handwritten signature

No	Date of casting	Site Mix or R.M.	Specified Grade of Concrete	Supplier/Contractor	ID No.	Block No	Bar galow No	Used for Slab Columns	Slab No. or Column No.	Date of Testing	No. of days	Specified Strength	Tested Strength Kilo newtons	Tested Strength in N per sq mm	Avg. of three tests	Remarks
5765	27-03-2017	Site Mix	M20	Amud		92		slab	1	23-4-17	(7)	14.0	3150	14.0	14.2	✓
5765	27-03-2017	Site Mix	M20	Amud		92		slab	1	23-4-17	(27)	20.0	4550	20.2	20.2	✓
5766	27-03-2017	Site Mix	M20	Amud		97		column		3-4-17	(7)	14.0	3100	13.8	14.0	✓
5766	27-03-2017	Site Mix	M20	Amud		97		column		3-4-17	(27)	20.0	4500	20.0	20.1	✓
5767	27-03-2017	Site Mix	M20	Amud		98		column		3-4-17	(7)	14.0	3200	14.2	14.4	✓
5767	27-03-2017	Site Mix	M20	Amud		98		column		23-4-17	(27)	20.0	4500	20.0	20.2	✓
5768	27-03-2017	Site Mix	M20	Amud		145		column		3-4-17	(7)	14.0	3200	14.2	14.4	✓
5768	27-03-2017	Site Mix	M20	Amud		145		column		23-4-17	(27)	20.0	4500	20.0	20.4	✓
5769	27-03-2017	Site Mix	M20	Amud		146		column		3-4-17	(7)	14.0	3100	13.8	14.0	✓
5769	27-03-2017	Site Mix	M20	Amud		146		column		23-4-17	(27)	20.0	4500	20.0	20.4	✓
5770	27-03-2017	Site Mix	M20	Amud		147		column		3-4-17	(7)	14.0	3150	14.0	14.2	✓
5770	27-03-2017	Site Mix	M20	Amud		147		column		23-4-17	(27)	20.0	4500	20.0	20.4	✓
5771	27-03-2017	Site Mix	M20	Amud		148		column		3-4-17	(7)	14.0	3100	13.8	14.0	✓
5771	27-03-2017	Site Mix	M20	Amud		148		column		23-4-17	(27)	20.0	4500	20.0	20.4	✓

5771	07-04-2017	Sie Mix	M25	Amend					17.5	395.0	17.6	17.8	✓
					92	col	2	4-5-17	(27)	25.0	575.0	25.6	✓
										25.0	595.0	25.1	✓
										25.0	579.0	25.3	✓
5772	07-04-2017	Sie Mix	M25	Amend						17.5	400.0	18.0	✓
					94	col	2	14-4-17	(7)	17.5	400.0	18.0	✓
										17.5	400.0	17.8	✓
										17.5	400.0	17.8	✓
5773	11-04-2017	Sie Mix	M20	Amend						25.0	570.0	25.3	✓
					96	col	2	4-5-17	(27)	25.0	570.0	25.6	✓
										25.0	570.0	25.3	✓
5774	11-04-2017	Sie Mix	M20	Amend						14.0	330.0	14.7	✓
					95	slab	1	18-4-17	(7)	14.0	330.0	15.1	✓
										14.0	330.0	14.7	✓
5775	11-04-2017	Sie Mix	M20	Amend						20.0	465.0	20.7	✓
					95	slab	1	8-5-17	(27)	20.0	465.0	20.7	✓
										20.0	470.0	20.9	✓
										20.0	465.0	20.7	✓
5776	20-04-2017	Sie Mix	M20	Amend						14.0	325.0	14.4	✓
					96	slab	1	27-4-17	(7)	14.0	325.0	14.4	✓
										14.0	330.0	14.2	✓
										14.0	315.0	14.0	✓
5777	20-04-2017	Sie Mix	M20	Amend						20.0	455.0	20.2	✓
					96	slab	1	18-5-17	(28)	20.0	455.0	20.9	✓
										20.0	470.0	20.9	✓
										20.0	460.0	20.4	✓
5778	21-04-2017	Sie Mix	M20	Amend						14.0	320.0	14.2	✓
					91	slab	1	27-4-17	(6)	14.0	315.0	14.0	✓
										14.0	315.0	14.2	✓
										14.0	315.0	14.2	✓
5779	21-04-2017	Sie Mix	M20	Amend						20.0	455.0	20.2	✓
					91	slab	1	18-5-17	(27)	20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5780	22-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					91	slab	2	28-4-17	(6)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5781	22-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					91	slab	2	18-5-17	(26)	20.0	470.0	20.9	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5782	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					91	slab	2	28-4-17	(6)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5783	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					91	slab	2	18-5-17	(26)	20.0	470.0	20.9	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5784	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					91	slab	2	28-4-17	(6)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5785	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5786	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5787	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5788	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5789	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5790	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5791	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5792	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5793	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5794	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5795	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5796	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5797	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5798	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓
5799	23-04-2017	Sie Mix	M20	Amend						20.0	470.0	20.9	✓
					94	slab	2	28-4-17	(30)	20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
										20.0	460.0	20.4	✓
										20.0	455.0	20.2	✓
5800	23-04-2017	Sie Mix	M20	Amend						14.0	310.0	14.2	✓
					94	slab	2	28-4-17	(30)	14.0	310.0	14.2	✓
										14.0	315.0	14.2	✓
										14.0	310.0	14.2	✓

5777	23-04-2017	Sie Mix	M25	Almond	56	col	2	30.4-17	175	408.0	18.0	17.9	✓
5777	23-04-2017	Sie Mix	M25	Almond	46	col	2	20.5-17	175	400.0	17.8	17.9	✓
5778	25-04-2017	Sie Mix	M25	Almond	93	col	2	25.4-17	175	410.0	18.3	18.0	✓
5778	25-04-2017	Sie Mix	M25	Almond	95	col	2	22.8-17	175	405.0	18.0	17.9	✓
5779	02-05-2017	Sie Mix	M25	Almond	99	col	1	9.5-17	175	400.0	17.8	17.8	✓
5779	02-05-2017	Sie Mix	M25	Almond	99	col	1	29.5-17	175	405.0	18.0	17.8	✓
5780	03-05-2017	Sie Mix	M20	Almond	91	col	1	10.5-17	175	405.0	18.0	17.8	✓
5780	03-05-2017	Sie Mix	M20	Almond	91	col	1	29.5-17	175	405.0	18.0	17.8	✓
5781	03-05-2017	Sie Mix	M20	Almond	81	col	1	30.5-17	175	405.0	18.0	17.8	✓
5781	03-05-2017	Sie Mix	M20	Almond	81	col	1	10.5-17	175	405.0	18.0	17.8	✓
5782	03-05-2017	Sie Mix	M20	Almond	83	col	1	30.5-17	175	405.0	18.0	17.8	✓
5782	03-05-2017	Sie Mix	M20	Almond	83	col	1	10.5-17	175	405.0	18.0	17.8	✓
5783	04-05-2017	Sie Mix	M25	Almond	100	col	2	20.5-17	175	405.0	18.0	17.8	✓
5783	04-05-2017	Sie Mix	M25	Almond	100	col	2	20.5-17	175	405.0	18.0	17.8	✓
5784	04-05-2017	Sie Mix	M25	Almond	101	col	2	20.5-17	175	405.0	18.0	17.8	✓
5784	04-05-2017	Sie Mix	M25	Almond	101	col	2	20.5-17	175	405.0	18.0	17.8	✓
5785	04-05-2017	Sie Mix	M25	Almond	102	col	2	20.5-17	175	405.0	18.0	17.8	✓
5785	04-05-2017	Sie Mix	M25	Almond	102	col	2	20.5-17	175	405.0	18.0	17.8	✓
5786	04-05-2017	Sie Mix	M25	Almond	103	col	2	20.5-17	175	405.0	18.0	17.8	✓
5786	04-05-2017	Sie Mix	M25	Almond	103	col	2	20.5-17	175	405.0	18.0	17.8	✓
5787	04-05-2017	Sie Mix	M25	Almond	104	col	2	20.5-17	175	405.0	18.0	17.8	✓
5787	04-05-2017	Sie Mix	M25	Almond	104	col	2	20.5-17	175	405.0	18.0	17.8	✓
5788	04-05-2017	Sie Mix	M25	Almond	105	col	2	20.5-17	175	405.0	18.0	17.8	✓
5788	04-05-2017	Sie Mix	M25	Almond	105	col	2	20.5-17	175	405.0	18.0	17.8	✓
5789	04-05-2017	Sie Mix	M25	Almond	106	col	2	20.5-17	175	405.0	18.0	17.8	✓
5789	04-05-2017	Sie Mix	M25	Almond	106	col	2	20.5-17	175	405.0	18.0	17.8	✓
5790	04-05-2017	Sie Mix	M25	Almond	107	col	2	20.5-17	175	405.0	18.0	17.8	✓
5790	04-05-2017	Sie Mix	M25	Almond	107	col	2	20.5-17	175	405.0	18.0	17.8	✓
5791	04-05-2017	Sie Mix	M25	Almond	108	col	2	20.5-17	175	405.0	18.0	17.8	✓
5791	04-05-2017	Sie Mix	M25	Almond	108	col	2	20.5-17	175	405.0	18.0	17.8	✓
5792	04-05-2017	Sie Mix	M25	Almond	109	col	2	20.5-17	175	405.0	18.0	17.8	✓
5792	04-05-2017	Sie Mix	M25	Almond	109	col	2	20.5-17	175	405.0	18.0	17.8	✓
5793	04-05-2017	Sie Mix	M25	Almond	110	col	2	20.5-17	175	405.0	18.0	17.8	✓
5793	04-05-2017	Sie Mix	M25	Almond	110	col	2	20.5-17	175	405.0	18.0	17.8	✓

5785	08-05-2017	Site Mix	M25	Amend		46	col	1	15.5-17	17	17.5	405.0	52.0		✓
											17.5	405.0	18.0	17.9	
5785	08-05-2017	Site Mix	M25	Amend		86	col	1	4.6-17	127	25.0	570.0	25.3		✓
											25.0	600.0	24.9	25.2	
											25.0	570.0	25.3		
5786	09-05-2017	Site Mix	M25	Amend		85	col	1	15.5-17	69	17.5	400.0	17.8		✓
											17.5	400.0	18.0	17.8	
											17.5	398.0	17.6		
5786	09-05-2017	Site Mix	M25	Amend		85	col	1	4.6-17	120	25.0	575.0	25.6		✓
											25.0	560.0	24.9	25.3	
											25.0	570.0	25.3		
5787	10-05-2017	Site Mix	M20	Amend		96	slab	2	17.5-17	171	14.0	330.0	14.7		✓
											14.0	325.0	14.4	14.7	
											14.0	335.0	14.9		
5787	10-05-2017	Site Mix	M20	Amend		26	slab	2	17.5-17	127	20.0	465.0	20.7		✓
											20.0	455.0	20.2	20.4	
											20.0	460.0	20.4		
5788	10-05-2017	Site Mix	M25	Amend		84	col	1	17.5-17	171	17.5	395.0	17.6		✓
											17.5	405.0	18.0	17.7	

5788	10-05-2017	Site Mix	M25	Amend						17.5	3850	17.6		✓
					col	1	6-6-17	(27)		25.0	5350	25.6		
										25.0	5650	25.1		
										25.0	5550	24.7		
5789	11-05-2017	Site Mix	M25	Amend						17.5	3900	17.3		✓
					col	2	18-5-17	(7)		17.5	4050	18.0	17.6	
										17.5	3950	17.8		
5789	11-05-2017	Site Mix	M25	Amend						17.5	3950	17.8		
					col	2	8-6-17	(28)		25.0	5750	25.6		
										25.0	5650	25.1		✓
										25.0	5700	25.3		
5790	12-05-2017	Site Mix	M25	Amend						17.5	4050	17.8		✓
					col	2	19-5-17	(7)		17.5	4050	18.0	17.8	
										17.5	3950	17.6		
5790	12-05-2017	Site Mix	M25	Amend						25.0	5800	25.8		✓
					col	2	8-6-17	(27)		25.0	5750	25.6		
										25.0	5700	25.3		
5791	12-05-2017	Site Mix	M20	Amend						14.0	3300	14.7		✓
					slab	2	16-5-17	(7)		14.0	3250	14.4	14.7	
										14.0	3350	14.9		

5794	12-05-2017	Site Mix	M20	Almond	96	88b	2	8.6-17	(27)	20.0	46.5	20.7	20.4	✓
										20.0	45.0	20.2	20.4	
5794	10-05-2017	Site Mix	M20	Almond	96	88b	2	17.5-17	(7)	14.0	33.0	14.2	14.7	✓
										14.0	33.0	14.4	14.7	
5793	10-05-2017	Site Mix	M20	Almond	96	88b	2	4.6-17	(27)	20.0	46.5	20.7	20.4	✓
										20.0	45.0	20.2	20.4	
5791	13-05-2017	Site Mix	M20	Almond	116	88b	1	20.5-17	(7)	14.0	33.0	14.9	14.8	✓
										14.0	33.0	14.7	14.8	
5793	13-05-2017	Site Mix	M20	Almond	136	88b	1	9.6-17	(27)	20.0	47.0	20.9	20.6	✓
										20.0	46.0	20.4	20.6	
5794	13-05-2017	Site Mix	M20	Almond	175	88b		20.5-17	(7)	14.0	33.0	14.7	14.6	✓
										14.0	32.0	14.4	14.6	
5794	11-05-2017	Site Mix	M20	Almond	175	88b		9.6-17	(27)	20.0	46.5	20.7	20.7	✓
										20.0	47.0	20.9	20.7	
5795	17-05-2017	Site Mix	M20	Almond	90	88b		24.5-17	(7)	14.0	33.0	14.7	14.6	✓
										14.0	33.0	14.9	14.6	
5795	17-05-2017	Site Mix	M20	Almond	90	88b		13.6-17	(27)	20.0	47.0	20.9	20.6	✓
										20.0	46.0	20.4	20.6	
5796	17-05-2017	Site Mix	M20	Almond	136	88b		24.5-17	(7)	14.0	33.0	14.7	14.6	✓
										14.0	33.0	14.9	14.6	
5796	17-05-2017	Site Mix	M20	Almond	136	88b		13.6-17	(27)	20.0	47.0	20.9	20.6	✓
										20.0	46.0	20.4	20.6	
5797	18-05-2017	Site Mix	M20	Almond	175	88b		24.5-17	(7)	14.0	33.0	14.7	14.6	✓
										14.0	33.0	14.9	14.6	
5797	18-05-2017	Site Mix	M20	Almond	175	88b		13.6-17	(27)	20.0	47.0	20.9	20.6	✓
										20.0	46.0	20.4	20.6	
5798	18-05-2017	Site Mix	M20	Almond	175	88b		24.5-17	(7)	14.0	33.0	14.7	14.6	✓
										14.0	33.0	14.9	14.6	
5798	18-05-2017	Site Mix	M20	Almond	175	88b		13.6-17	(27)	20.0	47.0	20.9	20.6	✓
										20.0	46.0	20.4	20.6	
5799	18-05-2017	Site Mix	M20	Almond	175	88b		24.5-17	(7)	14.0	33.0	14.7	14.6	✓
										14.0	33.0	14.9	14.6	
5799	18-05-2017	Site Mix	M20	Almond	175	88b		13.6-17	(27)	20.0	47.0	20.9	20.6	✓
										20.0	46.0	20.4	20.6	

5798	18-05-2017	Site Mix	M20	Amend		119	col	1	28.5-17	140	340.0	15.1	14.6	✓
										14.0	335.0	14.9	14.6	
5798	18-05-2017	Site Mix	M20	Amend		119	col	1	11.6-17	28.0	473.0	21.1	20.8	✓
										20.0	470.0	20.9	20.8	
5799	19-05-2017	Site Mix	M25	Amend		119	col	1	26.5-17	17.5	480.0	17.8	17.6	✓
										17.5	480.0	17.8	17.6	
5799	19-05-2017	Site Mix	M25	Amend		119	col	1	13.0-17	28.0	578.0	25.6	25.3	✓
										28.0	565.0	25.1	25.3	
5800	20-05-2017	Site Mix	M25	Amend		120	col	1	26.5-17	17.5	410.0	18.2	18.1	✓
										17.5	405.0	18.0	18.1	
5800	20-05-2017	Site Mix	M25	Amend		120	col	1	15.6-17	26.0	470.0	25.3	25.5	✓
										25.0	570.0	25.3	25.5	
5801	20-05-2017	Site Mix	M25	Amend		135	col	2	27.2-17	17.5	400.0	17.8	17.9	✓
										17.5	405.0	18.0	17.9	
5801	20-05-2017	Site Mix	M25	Amend		135	col	2	16.6-17	25.0	580.0	25.8	25.7	✓
										25.0	570.0	25.5	25.7	
5802	22-05-2017	Site Mix	M25	Amend		112	col	1	29.5-17	17.5	405.0	17.8	17.7	✓
										17.5	395.0	17.6	17.7	
5802	22-05-2017	Site Mix	M25	Amend		112	col	1	18.6-17	25.0	575.0	25.6	25.4	✓
										25.0	565.0	25.1	25.4	
5803	23-05-2017	Site Mix	M20	Amend		92	col	1	28.5-17	14.0	340.0	15.1	14.6	✓
										14.0	335.0	14.9	14.6	
5804	23-05-2017	Site Mix	M25	Amend		119	col	1	26.5-17	17.5	480.0	17.8	17.6	✓
										17.5	480.0	17.8	17.6	
5805	24-05-2017	Site Mix	M25	Amend		120	col	1	26.5-17	17.5	410.0	18.2	18.1	✓
										17.5	405.0	18.0	18.1	
5806	24-05-2017	Site Mix	M25	Amend		120	col	1	15.6-17	26.0	470.0	25.3	25.5	✓
										25.0	570.0	25.3	25.5	

5806	26-05-2017	Sic Mix	M25	Amnd	98	col	2	3-0-17	(8)	175	400.0	178	175	225	175	175	✓
5806	26-05-2017	Sic Mix	M25	Amnd	98	col	2	3-0-17	(27)	175	400.0	178	175	225	175	175	✓
5807	27-05-2017	Sic Mix	M20	Amnd	83	slab	1	6-6-17	(8)	14.0	120.0	15.1	14.0	155.0	14.9	14.9	✓
5807	27-05-2017	Sic Mix	M20	Amnd	83	slab	1	6-6-17	(28)	20.0	475.0	21.1	20.0	465.0	20.7	20.7	✓
5808	29-05-2017	Sic Mix	M20	Amnd	84	slab	1	6-6-17	(8)	14.0	120.0	14.2	14.0	125.0	14.4	14.4	✓
5808	29-05-2017	Sic Mix	M20	Amnd	84	slab	1	6-6-17	(28)	20.0	465.0	20.7	20.0	460.0	20.4	20.4	✓
5808	29-05-2017	Sic Mix	M20	Amnd	84	slab	1	6-6-17	(28)	20.0	465.0	20.7	20.0	460.0	20.4	20.4	✓
5809	01-06-2017	Sic Mix	M20	Amnd	120	slab	2	6-6-17	(1)	14.0	140.0	15.1	14.0	115.0	14.0	14.6	✓
5809	01-06-2017	Sic Mix	M20	Amnd	120	slab	2	6-6-17	(27)	20.0	455.0	20.2	20.0	455.0	20.2	20.2	✓
5809	01-06-2017	Sic Mix	M20	Amnd	120	slab	2	6-6-17	(27)	20.0	455.0	20.2	20.0	455.0	20.2	20.2	✓
5810	02-06-2017	Sic Mix	M25	Amnd	101	col	1	9-6-17	(7)	175	400.0	178	175	395.0	17.6	17.7	✓
5810	02-06-2017	Sic Mix	M25	Amnd	101	col	1	9-6-17	(27)	20.0	455.0	20.2	20.0	455.0	20.2	20.2	✓
5810	02-06-2017	Sic Mix	M25	Amnd	101	col	1	9-6-17	(27)	20.0	455.0	20.2	20.0	455.0	20.2	20.2	✓
5811	03-06-2017	Sic Mix	M20	Amnd	83	col	2	9-6-17	(28)	20.0	465.0	20.7	20.0	460.0	20.4	20.4	✓
5811	03-06-2017	Sic Mix	M20	Amnd	83	col	2	9-6-17	(28)	20.0	465.0	20.7	20.0	460.0	20.4	20.4	✓
5812	04-06-2017	Sic Mix	M20	Amnd	117	slab	1	18-6-17	(8)	14.0	125.0	14.4	14.0	130.0	14.7	14.7	✓
5813	14-06-2017	Sic Mix	M25	Amnd	120	slab	2	6-6-17	(28)	20.0	465.0	20.7	20.0	460.0	20.4	20.4	✓

5813	12-06-2017	Sie Mix	M20	Amend	136	phibbean	18-6-17	101	140	335.0	14.4	✓
									140	330.3	14.7	✓
5813	12-06-2017	Sie Mix	M20	Amend	136	phibbean	8-7-17	100	140	316.0	14.7	✓
									20.6	460.0	20.4	✓
									20.0	465.0	20.7	✓
									20.0	475.0	21.1	✓
5814	14-06-2017	Sie Mix	M20	Amend	92	slab	8-6-17	7	140	159.4	14.4	✓
									140	320.0	14.2	✓
									14.0	230.0	14.7	✓
5814	15-06-2017	Sie Mix	M20	Amend	92	slab	12-7-17	1271	20.0	455.0	20.2	✓
									20.0	455.0	20.2	✓
									20.0	455.0	20.2	✓
5815	15-06-2017	Sie Mix	M20	Amend	101	slab	8-6-17	7	140	315.0	14.0	✓
									140	320.0	14.2	✓
									140	315.0	14.0	✓
5815	15-06-2017	Sie Mix	M20	Amend	101	slab	12-7-17	1271	20.0	455.0	20.2	✓
									20.0	455.0	20.2	✓
									20.0	455.0	20.2	✓
5816	18-06-2017	Sie Mix	M20	Amend	93	slab	26-6-17	181	140	328.0	14.4	✓
									140	325.0	14.4	✓
									140	330.0	14.7	✓
5816	18-06-2017	Sie Mix	M20	Amend	93	slab	16-7-17	1281	20.0	460.0	20.4	✓
									20.0	465.0	20.7	✓
									20.0	460.0	20.4	✓
5817	18-06-2017	Sie Mix	M20	Amend	98	slab	26-6-17	181	140	315.0	14.0	✓
									140	320.0	14.7	✓
									140	330.0	14.7	✓
5817	18-06-2017	Sie Mix	M20	Amend	98	slab	16-7-17	1281	20.0	470.0	20.9	✓
									20.0	465.0	20.7	✓
									20.0	460.0	20.4	✓
5818	18-06-2017	Sie Mix	M20	Amend	99	slab	16-7-17	1281	20.0	460.0	20.4	✓
									20.0	465.0	20.7	✓
									20.0	460.0	20.4	✓
5819	18-06-2017	Sie Mix	M20	Amend	138	slab	26-6-17	181	140	320.0	14.2	✓
									140	330.0	14.7	✓
									140	320.0	14.2	✓
5819	18-06-2017	Sie Mix	M20	Amend	138	slab	16-7-17	1281	20.0	465.0	20.7	✓
									20.0	460.0	20.4	✓
									20.0	465.0	20.7	✓

C	18-06-2017	Site Mix	M20	Armed	110	slab	2	26-6-17	(81)	14.0	320.0	14.7	14.3
5820	18-06-2017	Site Mix	M20	Armed	116	slab	2	16-7-17	(28)	20.0	455.0	20.2	20.4
5821	27-06-2017	Site Mix	M20	Armed	89	footing		4-7-17	(7)	14.0	320.0	14.2	14.4
5821	27-06-2017	Site Mix	M20	Armed	89	footing		25-1-17	(28)	20.0	460.0	20.4	20.4
5822	27-06-2017	Site Mix	M20	Armed	110	footing		4-7-17	(7)	14.0	320.0	14.4	14.6
5822	27-06-2017	Site Mix	M20	Armed	110	footing		25-7-17	(28)	20.0	460.0	20.4	20.4
5823	04-07-2017	Site Mix	M20	Armed	123	footing		11-7-17	(7)	14.0	320.0	14.7	14.5
5824	06-07-2017	Site Mix	M20	Armed	89	footing		13-7-17	(7)	14.0	320.0	14.9	14.9
5824	06-07-2017	Site Mix	M20	Armed	89	footing		2-8-17	(29)	20.0	455.0	20.2	20.4
5825	13-07-2017	Site Mix	M20	Armed	101	slab	2	30-7-17	(7)	14.0	320.0	14.7	14.6
5825	13-07-2017	Site Mix	M20	Armed	101	slab	2	11-8-17	(29)	20.0	455.0	19.8	20.1

5826	06-07-2017	Site Mix	M20	Amend	89	Facing	14-7-17	(8)	14.0	145.0	15.3	12.0	
									14.0	455.0	15.9	14.7	
5826	06-07-2017	Site Mix	M20	Amend	89	Facing	5-8-17	(39)	20.0	465.0	20.7	20.3	
									20.0	455.0	20.2	20.4	
5827	14-07-2017	Site Mix	M20	Amend	101	Sub	20-7-17	(7)	14.0	355.0	14.0	14.9	
									14.0	340.0	15.1	14.9	
5827	13-07-2017	Site Mix	M20	Amend	101	Sub	11-8-17	(429)	20.0	465.0	20.7	20.4	
									20.0	455.0	20.2	20.4	
5828	14-07-2017	Site Mix	M20	Amend	808	Plinthbeam	20-7-17	(6)	14.0	355.0	14.4	14.7	
									14.0	340.0	14.7	14.7	
5828	14-07-2017	Site Mix	M20	Amend	808	Plinthbeam	11-8-17	(28)	20.0	455.0	20.2	20.1	
									20.0	455.0	20.2	20.1	
5829	14-07-2017	Site Mix	M20	Amend	809	Plinthbeam	20-7-17	(6)	14.0	355.0	14.4	14.4	
									14.0	340.0	14.7	14.4	
5830	13-07-2017	Site Mix	M20	Amend	95	Sub	21-7-17	(6)	14.0	355.0	14.9	14.6	
									14.0	320.0	14.2	14.6	
5830	13-07-2017	Site Mix	M20	Amend	95	Sub	11-8-17	(72)	20.0	465.0	20.7	20.4	
									20.0	460.0	20.4	20.4	
5831	13-07-2017	Site Mix	M20	Amend	97	Sub	21-7-17	(6)	14.0	355.0	14.9	14.7	
									14.0	320.0	14.2	14.7	
5831	13-07-2017	Site Mix	M20	Amend	97	Sub	11-8-17	(72)	20.0	465.0	20.7	20.4	
									20.0	460.0	20.4	20.4	

5832	24-07-2017	Sig Mix	M20	Armed	90°	plinthbeam	30.7-17	(6)	14.0	315.0	14.0	14.4
5832	24-07-2017	Sig Mix	M20	Armed	80°	plinthbeam	21.8-17	(25)	20.6	465.0	20.7	20.3
5833	24-07-2017	Sig Mix	M20	Armed	167	plinthbeam	30.7-17	(6)	14.0	315.0	14.9	14.5
5833	24-07-2017	Sig Mix	M20	Armed	142	plinthbeam	21.8-17	(26)	20.6	465.0	20.7	20.4
5834	24-07-2017	Sig Mix	M20	Armed	145	plinthbeam	30.7-17	(6)	14.0	315.0	14.0	14.1
5834	24-07-2017	Sig Mix	M20	Armed	140	plinthbeam	30.0	14.0	310.0	13.8	14.0	14.7
5834	24-07-2017	Sig Mix	M20	Armed	145	plinthbeam	21.8-17	(28)	20.6	465.0	20.2	20.3
5835	31-07-2017	Sig Mix	M20	Armed	85	slab	7.8-17	(7)	14.6	315.0	14.0	14.3
5835	31-07-2017	Sig Mix	M20	Armed	140	slab	30.0	14.0	310.0	14.2	14.2	14.7
5835	31-07-2017	Sig Mix	M20	Armed	85	slab	27.8-17	(27)	20.0	460.0	20.4	20.4
5835	31-07-2017	Sig Mix	M20	Armed	290	slab	29.7	29.0	445.0	29.7	29.7	29.4
5835	31-07-2017	Sig Mix	M20	Armed	30.0	slab	30.2	30.0	455.0	30.2	30.2	30.3
5836	31-07-2017	Sig Mix	M20	Armed	96	slab	7.8-17	(7)	14.0	315.0	14.4	14.4
5836	31-07-2017	Sig Mix	M20	Armed	140	slab	30.0	14.0	315.0	14.4	14.4	14.4
5836	31-07-2017	Sig Mix	M20	Armed	86	slab	27.8-17	(27)	20.0	460.0	20.4	20.4
5836	31-07-2017	Sig Mix	M20	Armed	290	slab	29.7	29.0	445.0	29.7	29.7	29.4
5836	31-07-2017	Sig Mix	M20	Armed	30.0	slab	30.2	30.0	455.0	30.2	30.2	30.3
5837	04-08-2017	Sig Mix	M20	Armed	100	slab	7	(7)	14.0	310.0	14.2	14.8
5837	04-08-2017	Sig Mix	M20	Armed	140	slab	30.0	14.0	310.0	14.2	14.2	14.7
5837	04-08-2017	Sig Mix	M20	Armed	100	slab	7	(7)	14.0	310.0	14.2	14.8
5837	04-08-2017	Sig Mix	M20	Armed	140	slab	30.0	14.0	310.0	14.2	14.2	14.7

5844	05-08-2017	Sie Mix	M20	Amund	138	footing	11.8-17	60	14.0	340.0	15.7	14.9	✓
5838	05-08-2017	Sie Mix	M20	Amund	138	footing	31.8-17	76	20.0	465.0	28.7	20.7	✓
5832	18-08-2017	Sie Mix	M20	Amund	165	footing	25.8-17	73	14.0	335.0	14.9	14.9	✓
5840	18-08-2017	Sie Mix	M20	Amund	131	footing	25.8-17	73	14.0	335.0	14.9	14.9	✓
5844	18-08-2017	Sie Mix	M20	Amund	134	footing	25.8-17	73	14.0	335.0	14.9	14.9	✓
5842	25-08-2017	Sie Mix	M20	Amund	84	sub	2.9-17	18	14.0	330.0	14.7	14.4	✓
5843	25-08-2017	Sie Mix	M20	Amund	108	footing	2.9-17	68	14.0	340.0	15.1	15.0	✓
5844	26-08-2017	Sie Mix	M25	Amund	160	col	2.9-17	73	17.5	505.0	18.0	17.7	✓
5845	27-08-2017	Sie Mix	M20	Amund	87	sub	4.9-17	81	14.0	330.0	14.7	14.4	✓
5846	27-08-2017	Sie Mix	M20	Amund	88	sub	4.9-17	81	14.0	330.0	14.7	14.4	✓
5847	28-08-2017	Sie Mix	M20	Amund	83	sub	4.9-17	77	14.0	330.0	14.7	14.4	✓